

NUCLEAR SAFETY DIVISION

ARCHIVES


CSNI Report 147
Restricted

OECD
NEA

SYSTEMATIC COLLECTION OF
STATISTICAL DATA ON REACTOR SCRAMS

Prepared by the CSNI PWG 1
Operating Experiences and Human Factors

APRIL 1988





SYSTEMATIC COLLECTION OF
STATISTICAL DATA ON
REACTOR SCRAMS

Prepared by the
CSNI PWG 1
Operating Experiences and Human Factors

APRIL 1988

(ii)

The NEA Committee on the Safety of Nuclear Installations (CSNI) is an international committee made up of scientists and engineers who have responsibilities for nuclear safety research and nuclear licensing. The Committee was set up in 1973 to develop and co-ordinate the Nuclear Energy Agency's work in nuclear safety matters, replacing the former Committee on Reactor Safety Technology (CREST) with its more limited scope.

The Committee's purpose is to foster international co-operation in nuclear safety amongst the OECD Member countries. This is done in a number of ways. Full use is made of the traditional methods of co-operation, such as information exchanges, establishment of working groups, and organisation of conferences. Some of these arrangements are of immediate benefit to Member countries, for example by enriching the data base available to national regulatory authorities and to the scientific community at large. Other questions may be taken up by the Committee itself with the aim of achieving an international consensus wherever possible. The traditional approach to co-operation is increasingly being reinforced by the creation of co-operative (international) research projects, such as PISC and LOFT, and by a novel form of collaboration known as the international standard problem exercise, for testing the performance of computer codes, test methods, etc. used in safety assessments. These exercises are now being conducted in most sectors of the nuclear safety programme.

The greater part of the CSNI co-operative programme is concerned with safety technology for water reactors. The principal areas covered are operating experience and the human factor, reactor system response during abnormal transients, various aspects of primary circuit integrity, the phenomenology of radioactive releases in reactor accidents, and risk assessment. The Committee also studies the safety of the fuel cycle, conducts periodic surveys of reactor safety research programmes and operates an international mechanism for exchanging reports on power plant incidents.

The Committee has set up a sub-Committee on Licensing which examines a variety of nuclear regulatory problems, provides a forum for the free discussion of licensing questions and reviews the regulatory impact of the conclusions reached by CSNI.

* * * * *

A "Restricted" OECD document should not be communicated except for official purposes. The Secretariat and Member governments of the OECD are requested to take the necessary action to ensure the security of these documents.


The opinions expressed and arguments employed in this document are the responsibility of the authors and do not necessarily represent those of the OECD.

Requests for additional copies of this report should be addressed to:

Nuclear Safety Division
OECD Nuclear Energy Agency
38 boulevard Suchet
F-75016 Paris
FRANCE

TABLE OF CONTENTS

	<u>Page No.</u>
FOREWARD.....	1
QUESTIONNAIRE.....	3
STATISTICAL DATA ON REACTOR SCRAM.....	19
OPERATIONAL RECORDS (1986).....	25



F O R E W A R D

A reactor scram can be defined as a manual or automatic actuation of the Reactor Protection System resulting in the most rapid possible insertion of the control rods. In spite of its vital importance as a safety function to bring the plant to a safe and stable condition in case of an emergency, negative side effects of too frequent scrams on plant operations have been a matter of concern for OECD Member countries. Reactor scrams not only challenge the safety systems but also result in undesirable thermal and hydraulic transients and in general are indicative of deficiencies in the operation of the plant. At the same time, unplanned shutdowns of reactors have considerable economical implications for electrical utilities.

Since reactor scrams create a fertile environment for operator error and equipment malfunctions, systematic collection and periodic review of scram records will provide Member countries with a clue to evaluating the safety and reliability of plant operations. By updating the information on a yearly basis, the evolution of scram frequencies can be monitored from various viewpoints, such as type of scram, scram signal, scram context, root cause, initiating system, etc. The scram frequency will thus serve as a performance indicator of the plant, and the information stored in the data base will help regulatory bodies and electrical utilities in promoting their scram reduction programmes.

At the NEA Symposium on Reducing Reactor Scram Frequency held in Tokyo from 14th to 18th April 1986, it was recommended that the collection of statistical data on reactor scrams be continued and updated on a regular basis. PWG 1 delegates discussed this recommendation at their fifth meeting held from 22nd to 24th September 1986. The Committee endorsed the PWG 1 proposal regarding the systematic collection of statistical data on reactor scrams on an annual basis. Following this initiative, efforts have been made to compile the statistical data on reactor scram of 1986.

The next report on data of 1987 will be published during 1989.



QUESTIONNAIRE

1. Objective

Since reactor scrams create a fertile environment for operator error and equipment malfunctions, systematic collection and periodic review of scram records will provide Member countries with a clue to evaluating the safety and reliability of plant operations. By updating the information on a yearly basis, the evolution of scram frequencies can be monitored from various viewpoints, such as type of scram, scram signal, scram context, root cause, initiating system, etc. The scram frequency will thus serve as a performance indicator of the plant, and the information stored in the data base will help regulatory bodies and electrical utilities in promoting their scram reduction programmes.

2. Definition of a Reactor Scram to be Considered

- (1) A reactor scram is defined as a manual or automatic actuation of the reactor protection system (RPS) resulting in the most rapid possible insertion of the control rods.
- (2) Actuation of the reactor protection system which does not result in any rod motion (e.g. while the reactor is defuelled) is not to be regarded as a reactor scram.
- (3) Pre-planned reactor scrams such as plant shutdowns for periodic inspection or refuelling are not to be considered in the statistics.
- (4) Only the reactor scrams after the first grid connection are to be included in the statistics.
- (5) The statistics should only include the reactor scrams taking place while the reactor is critical and the turbine is on-line**. Therefore, the reactor scrams while the reactor is sub-critical or the turbine is off-line are not to be considered.

3. Plant Types to be Covered

This initiative is intended to cover all types of thermal reactors with more than 100 MWe of net electrical power.

4. Information to be Collected

Once a year Member countries will be invited to contribute the following information for those plants in operation according to the form attached as Tables 1 to 5. Distinction should be made between plant types (e.g. PWR, BWR, GCR, AGR, PHWR, etc.). Breakdowns by specific plant design (e.g. number of loops, power rating, plant vendors etc.) and operating utility are also desirable whenever possible.

(1) Evolution of Reactor Scram Frequency (Table 1)

The scram frequencies during the last three years are to be tabulated for respective calendar years. They should be stated in terms of the number of scrams per reactor* and per 1000 hours in which the reactor is critical and the turbine is on line.

* The number of reactors in operation at the end of the calendar year should be used in calculating the number of scrams per reactor.

** "Generator on the grid" can be regarded as having the same meaning as "turbine on line".

(2) Main Signals Resulting in a Reactor Scram (Table 2)

The scram frequencies should be classified in the following categories according to the types of main signals which caused a reactor scram; they should be stated in a percentage of the total scram frequency in the plant concerned.

- (a) Turbine trip.
- (b) Other secondary-side signals (not applicable for BWRs).
- (c) Primary-side signals (including those from the reactor itself).
- (d) Manual scrams.
- (e) Other signals (i.e. earthquakes, under-voltage of emergency buses, etc.).

(3) Initiating System (Table 3)

The scram frequencies should be sorted according to the following categories of the plant system in which the root cause of the scram occurred; they should be stated in a percentage of the total scram frequency in the plant concerned.

- (a) Condensate/Feedwater System -- (i.e. condensate and feedwater pumps, piping, valves; flow, temperature, pressures, and tank-level instruments; flow control equipment).
- (b) Turbine System -- (i.e. turbine piping and valves, electro-hydraulic control (EHC) system, turbine components such as bearings, blades, etc.).
- (c) Reactor Coolant System -- (i.e. reactor coolant pumps; recirculating pumps; flow/temperature/pressure/level or other related instruments).
- (d) Electrical Systems -- (i.e. transformers, DC power supplies, emergency power supplies and buses, 125-VAC instrument buses).
- (e) Reactor Control and Protection System -- (i.e. controls; in-core/ex-core detectors; control rod drive assemblies, etc. various input channels monitoring plant processes, signal processing and logic circuitry, etc. Does not include reactor trip breakers).
- (f) Main Steam System -- (i.e. steam piping; valves; flow, temperature and pressure instruments; moisture separator/reheaters (MSR); steam drains and relief valves).
- (g) Generator -- (i.e. cooling systems; instruments; controls and major components such as excitor, rotor, stator, bearings, etc.).
- (h) Others

N.B. Certain scrams can be counted under different items wherever applicable, in which case the total percentage exceeds 100 per cent.

* The number of reactors in operation at the end of the calendar year should be used in calculating the number of scrams per reactor.

(4) Main Causes (Table 4)

The scram frequencies should be classified according to the following categories. They should be stated as a percentage of the total scram frequency in the plant concerned:

- a) due to component failure;
- b) due to human error;
- c) involving both component failure and human error
- d) due to procedural deficiency
- e) other cause.

N.B. Certain scrams can be counted under different categories wherever applicable, in which case the total percentage exceeds 100 per cent.

(5) Operational Modes (Table 5)

The scram frequencies should be classified in the following categories according to the plant operational modes when the reactor scrams occurred:

- a) during rated power operation
- b) during increase to or reduction from rated power operation
- c) during surveillance test or periodic inspection
- d) other operational modes (i.e. trouble shooting, calibration, maintenance, etc.).

N.B. Certain scrams can be counted under different categories wherever applicable, in which case the total percentage exceeds 100 per cent.

(6) Operational Records (Table 6)

In order to help interpret the differences in scram frequencies, the following information should be provided for individual plants considered:

- (a) Total number of hours in which the reactor is critical and the turbine is on line during the calendar year;
- (b) Date of first reactor criticality.

5. Data Base

The information contributed in response to the questionnaire will be stored on a computer file at the NEA Data Bank at Saclay near Paris. By request through the NEA-IRS Co-ordinators the contents of the data base will be made available to Member countries in the form of a magnetic tape or through an on-line telephone link, bearing in mind that the information is to be used for official purposes only.

6. Publication

The information collected will be compiled as a restricted report once a year by the NEA and distributed to Member countries. It is preferable that the results of the review of general trends in scram frequencies be included in the report. PWG 1 should discuss such a report before it is published for wider distribution.

T A B L E S

TABLE 2: MAIN SIGNALS RESULTING IN REACTOR SCRAMS (1986)

(in percentage)

Country	Plant Type	Turbine Trip	Other Secondary-Side Signals	Primary-side Signals	Manual Scram	Other Signals
Belgium	PWR total Doel Tihange					
Canada	PHWR total Pickering A Pickering B Bruce A Bruce B Gentilly 2 Pt. Lepreau					
Finland	PWR BWR					
France	PWR total 900 MWe 1300 MWe GCR					
F.R. of Germany	PWR BWR					
Italy	PWR BWR GCR					

Japan	PWR BWR GCR HMLWR					
Netherlands	PWR					
Spain	PWR total Jose Cabrera Others BWR total S.M. Garona Others GCR					
Sweden	PWR BWR					
Switzerland	PWR BWR					
United Kingdom	GCR total CEGB SSEB BNFL AGR total CEGB SSEB					
United States	PWR total W. C-E B & W BWR total GE AC GCR					

* The number of reactors in operation at the end of the calendar year should be indicated.

Japan	PWR BWR GCR HNLWR																			
Netherlands	PWR																			
Spain	PWR total Jose Cabrera Others BWR total S.M. Garona Others GCR																			
Sweden	PWR BWR																			
Switzerland	PWR BWR																			
United Kingdom	GCR total CEGB SSEB BNFL AGR total CEGB SSEB																			
United States	PWR total W. C-E B & W BWR total GE AC GCR																			

* The number of reactors in operation at the end of the calendar year should be indicated.

TABLE 4: MAIN CAUSES (1986)

(in percentage)

<u>Country</u>	<u>Plant Type</u>	<u>Component Failures</u>	<u>Human Error</u>	<u>Both Component Failure and Human Error</u>	<u>Procedural Deficiency</u>	<u>Other Cause</u>
Belgium	PWR total Doel Tihange					
Canada	PHWR total Pickering A Pickering B Bruce A Bruce B Gentilly 2 Pt. Lepreau					
Finland	PWR BWR					
France	PWR total 900 MWe 1300 MWe GCR					
F.R. of Germany	PWR BWR					
Italy	PWR BWR GCR					

Japan	PWR BWR GCR HMLWR					
Netherlands	PWR					
Spain	PWR total Jose Cabrera Others BWR total S.M. Garona Others GCR					
Sweden	PWR BWR					
Switzerland	PWR BWR					
United Kingdom	GCR total CEGB SSEB BNFL AGR total CEGB SSEB					
United States	PWR total W. C-E B & W BWR total GE AC GCR					

* The number of reactors in operation at the end of the calendar year should be indicated.

TABLE 5: OPERATIONAL MODES (1986)

(in percentage)

<u>Country</u>	<u>Plant Type</u>	<u>Rated Power Operation</u>	<u>Increase to or Reduction from Rated Power Operation</u>	<u>Surveillance Test or Periodic Inspection</u>	<u>Other Operational Modes</u>
Belgium	PWR total Doel Tihange				
Canada	PHWR total Pickering A Pickering B Bruce A Bruce B Gentilly 2 Pt. Lepreau				
England	PWR BWR				
France	PWR total 900 MWe 1300 MWe GCR				
F.R. of Germany	PWR BWR				
Italy	PWR BWR GCR				

Japan	PWR BWR GCR HWR				
Netherlands	PWR				
Spain	PWR total Jose Cabrera Others BWR total S.M. Garona Others GCR				
Sweden	PWR BWR				
Switzerland	PWR BWR				
United Kingdom	GCR total CEGB SSEB BNFL AGR total CEGB SSEB				
United States	PWR total W. C-E B & W BWR total GE AC GCR				

* The number of reactors in operation at the end of the calendar year should be indicated.

TABLE 6: OPERATIONAL RECORDS (1986)

COUNTRY NAME:

<u>Plant Type</u>	<u>Plant Name</u>	<u>Critical and Turbine on-line Hours (h) during the Year</u>	<u>Date of First Reactor Criticality</u>
PWR			
	Total		
BWR			
	Total		
GCR			
	Total		
AGR			
	Total		
PHWR			
	Total		
TOTAL			

STATISTICAL DATA ON REACTOR SCRAM

MAIN SIGNALS RESULTING IN REACTOR SCRAMS (1986)

SSTT : Turbine Trip SSOS : Other Secondary-side Signals
 SSPS : Primary-side Signals SSMS : Manual Scram
 SSOT : Other Signals

	SSTT	SSOS	SSPS	SSMS	SSOT
Belgium PWR total	11.0	51.0	32.0	5.0	0.0
Doel	20.0	40.0	40.0	0.0	0.0
Tihange	5.0	59.0	27.0	9.0	0.0
Canada PHWR total	7.4	3.7	48.2	3.7	37.0
Pickering A	0.0	0.0	0.0	0.0	0.0
Pickering B	10.0	0.0	30.0	0.0	60.0
Bruce A	0.0	0.0	83.0	0.0	17.0
Bruce B	12.5	0.0	50.0	12.5	25.0
Gentilly 2	0.0	100.0	0.0	0.0	0.0
Pt. Lepreau	0.0	0.0	50.0	0.0	50.0
Finland PWR	0.0	0.0	0.0	0.0	0.0
BWR	0.0	=	0.0	0.0	0.0
France PWR total	36.0	-	-	0.0	-
900 MWe	30.0	-	-	0.0	-
1300 MWe	30.0	-	-	0.0	-
GCR	-	-	-	-	-
FRG PWR	-	-	-	-	-
BWR	-	-	-	-	-
Italy PWR	0.0	0.0	57.0	28.0	15.0
BWR	0.0	25.0	50.0	25.0	0.0
GCR	0.0	0.0	0.0	0.0	0.0
Japan PWR	100.0	0.0	0.0	0.0	0.0
BWR	50.0	=	50.0	0.0	0.0
GCR	0.0	0.0	100.0	0.0	0.0
HWLWR	0.0	0.0	0.0	0.0	0.0
Nether. PWR	0.0	100.0	0.0	0.0	0.0
Spain PWR total	38.5	23.1	34.6	3.9	0.0
Jose Cabrera	0.0	0.0	100.0	0.0	0.0
Others	40.0	24.0	32.0	4.0	0.0
BWR total	35.0	=	45.0	0.0	20.0
S.M. Garona	20.0	=	40.0	0.0	40.0
Others	50.0	=	50.0	0.0	0.0
GCR	0.0	0.0	40.0	10.0	50.0
Sweden PWR	9.0	45.0	37.0	0.0	9.0
BWR	17.0	13.0	58.0	4.0	8.0
Switz. PWR	100.0	0.0	0.0	0.0	0.0
BWR	0.0	=	100.0	0.0	0.0
UK GCR total	-	-	-	-	-
CEGB	-	-	-	-	-
SSEB	-	-	-	-	-
BNFL	-	-	-	-	-
AGR total	-	-	-	-	-
CEGB	-	-	-	-	-
SSEB	-	-	-	-	-
USA PWR total	-	-	-	-	-
W.	22.8	33.5	19.2	10.8	13.8
C-E	18.6	20.0	42.9	11.4	7.1
B & W	53.3	6.7	33.3	6.7	0.0
BWR total	29.0	=	53.5	7.0	10.5
GE	-	-	-	-	-
AC	-	-	-	-	-
GCR	-	-	-	-	-

MAIN CAUSES (1986)

SMCF : Component Failures SMHE : Human Error
 SMBT : Both Component Failure and Human Error
 SMPD : Procedural Deficiency SMOT : Other Cause

		SMCF	SMHE	SMBT	SMPD	SMOT
Belgium	PWR total	51.0	32.0	5.0	0.0	8.0
	Doel	60.0	20.0	0.0	0.0	0.0
	Tihange	45.0	41.0	13.0	0.0	14.0
Canada	PHWR total	55.6	7.4	0.0	14.8	22.2
	Pickering A	0.0	0.0	0.0	0.0	0.0
	Pickering B	50.0	10.0	0.0	10.0	30.0
	Bruce A	83.3	0.0	0.0	16.7	0.0
	Bruce B	62.5	12.5	0.0	12.5	12.5
	Gentilly 2	0.0	0.0	0.0	0.0	100.0
	Pt. Lepreau	0.0	0.0	0.0	50.0	50.0
Finland	PWR	0.0	0.0	0.0	0.0	0.0
	BWR	0.0	0.0	0.0	0.0	0.0
France	PWR total	61.0	39.0	-	-	-
	900 MWe	62.0	38.0	-	-	-
	1300 MWe	58.0	42.0	-	-	-
	GCR	-	-	-	-	-
FRG	PWR	-	-	-	-	-
	BWR	-	-	-	-	-
Italy	PWR	57.0	15.0	28.0	0.0	0.0
	BWR	75.0	25.0	0.0	0.0	0.0
	GCR	0.0	0.0	0.0	0.0	0.0
Japan	PWR	50.0	50.0	0.0	0.0	0.0
	BWR	50.0	50.0	0.0	0.0	0.0
	GCR	100.0	0.0	0.0	0.0	0.0
	HWLWR	0.0	0.0	0.0	0.0	0.0
Nether.	PWR	100.0	0.0	0.0	0.0	0.0
Spain	PWR total	65.4	3.9	0.0	0.0	30.8
	Jose Cabrera	0.0	0.0	0.0	0.0	100.0
	Others	68.0	4.0	0.0	0.0	28.0
	BWR total	77.5	0.0	10.0	0.0	12.5
	S.M. Garona	80.0	0.0	20.0	0.0	0.0
	Others	75.0	0.0	0.0	0.0	25.0
	GCR	50.0	0.0	10.0	0.0	40.0
Sweden	PWR	73.0	9.0	9.0	0.0	9.0
	BWR	50.0	13.0	21.0	12.0	4.0
Switz.	PWR	0.0	100.0	0.0	0.0	0.0
	BWR	0.0	100.0	0.0	0.0	0.0
UK	GCR total	-	-	-	-	-
	CEGB	-	-	-	-	-
	SSEB	-	-	-	-	-
	BNFL	-	-	-	-	-
	AGR total	-	-	-	-	-
	CEGB	-	-	-	-	-
	SSEB	-	-	-	-	-
USA	PWR total	-	-	-	-	-
	W.	57.5	28.7	=	6.0	7.8
	C-E	70.0	18.5	=	5.7	5.7
	B & W	73.3	13.3	=	6.7	6.7
	BWR total	67.4	20.9	=	8.1	3.5
	GE	-	-	-	-	-
	AC	-	-	-	-	-
	GCR	-	-	-	-	-

OPERATIONAL MODES (1986)

SORP : Rated Power Operation

SOIR : Increase to or Reduction from Rated Power Operation

SOSP : Surveillance Test or Periodic Inspection

SOOT : Other Operational Modes

		SORP	SOIR	SOSP	SOOT
Belgium	PWR total	41.0	19.0	41.0	0.0
	Doel	40.0	13.0	47.0	0.0
	Tihange	41.0	23.0	36.0	0.0
Canada	PHWR total	100.0	0.0	0.0	0.0
	Pickering A	0.0	0.0	0.0	0.0
	Pickering B	100.0	0.0	0.0	0.0
	Bruce A	100.0	0.0	0.0	0.0
	Bruce B	100.0	0.0	0.0	0.0
	Gentilly 2	100.0	0.0	0.0	0.0
	Pt. Lepreau	100.0	0.0	0.0	0.0
Finland	PWR	0.0	0.0	0.0	0.0
	BWR	0.0	0.0	0.0	0.0
France	PWR total	-	-	18.0	-
	900 MWe	-	-	19.0	-
	1300 MWe	-	-	11.0	-
	GCR	-	-	-	-
FRG	PWR	-	-	-	-
	BWR	-	-	-	-
Italy	PWR	43.0	43.0	14.0	0.0
	BWR	75.0	0.0	25.0	0.0
	GCR	0.0	0.0	0.0	0.0
Japan	PWR	0.0	100.0	100.0	0.0
	BWR	0.0	100.0	50.0	0.0
	GCR	0.0	100.0	100.0	0.0
	HWLWR	0.0	0.0	0.0	0.0
Nether.	PWR	0.0	100.0	0.0	0.0
Spain	PWR total	69.2	26.9	3.9	0.0
	Jose Cabrera	100.0	0.0	0.0	0.0
	Others	68.0	28.0	4.0	0.0
	BWR total	70.0	0.0	30.0	0.0
	S.M. Garona	40.0	0.0	60.0	0.0
	Others	100.0	0.0	0.0	0.0
	GCR	70.5	21.6	4.7	3.2
Sweden	PWR	45.0	55.0	36.0	0.0
	BWR	38.0	62.0	13.0	0.0
Switz.	PWR	0.0	100.0	0.0	0.0
	BWR	100.0	0.0	0.0	0.0
UK	GCR total	-	-	-	-
	CEGB	-	-	-	-
	SSEB	-	-	-	-
	BNFL	-	-	-	-
	AGR total	-	-	-	-
	CEGB	-	-	-	-
	SSEB	-	-	-	-
USA	PWR total	-	-	-	-
	W.	41.9	17.4	21.0	19.7
	C-E	55.7	12.9	20.0	11.4
	B & W	46.7	20.0	13.3	20.0
	BWR total	41.9	5.9	30.2	22.1
	GE	-	-	-	-
	AC	-	-	-	-
	GCR	-	-	-	-

OPERATIONAL RECORDS (1986)

***** OPERATIONAL RECORDS (1986) *****

----- COUNTRY NAME: Belgium

TYPE	PLANT NAME	OPHOUR	OPDATE

PWR			
	DOEL-1	6971	740716
	DOEL-2	5913	750804
	DOEL-3	8009	820614
	DOEL-4	7972	850331
	TIHANGE-1	5384	750221
	TIHANGE-2	7508	821005
	TIHANGE-3	7732	850614
	Sub Total	49489	
BWR			
GCR			
AGR			
PHWR			
	TOTAL	49489	

***** OPERATIONAL RECORDS (1986) *****
----- COUNTRY NAME: Finland

TYPE	PLANT NAME	OPHOUR	OPDATE
PWR			
	LOVIISA-1	8093	770121
	LOVIISA-2	7273	801017
	Sub Total	15366	
BWR			
	TVO-1	8008	780721
	TVO-2	8437	791013
	Sub Total	16445	
GCR			
AGR			
PHWR			
	TOTAL	31811	

***** OPERATIONAL RECORDS (1986) *****
----- COUNTRY NAME: Italy

TYPE	PLANT NAME	OPHOUR	OPDATE
PWR BWR	CAORSO		
		6647	771231
		Sub Total	6647
GCR	LATINA		
		7663	621200
		Sub Total	7663
AGR PHWR			
		TOTAL	14310

***** OPERATIONAL RECORDS (1986) *****

----- COUNTRY NAME: Japan

TYPE PLANT NAME OPHOUR OUPDATE

PWR
GENKAI-1 5425 750128
GENKAI-2 8760 800521
IKATA-1 7044 770129
IKATA-2 8760 810731
MIHAMA-1 8482 700729
MIHAMA-2 7100 720410
MIHAMA-3 8760 760128
OHI-1 4664 771202
OHI-2 8760 780914
SENDAI-1 7224 830825
SENDAI-2 7112 850318
TAKAHAMA-1 6507 740314
TAKAHAMA-2 5183 741220
TAKAHAMA-3 8215 840417
TAKAHAMA-4 7073 841011

Sub Total 109069

BWR
FUKUSHIMA I-1 5836 701001
FUKUSHIMA I-2 7478 730510
FUKUSHIMA I-3 5621 740906
FUKUSHIMA I-4 5733 780128
FUKUSHIMA I-5 5622 770826
FUKUSHIMA I-6 7390 790309
FUKUSHIMA II-1 7404 810617
FUKUSHIMA II-2 6727 830426
FUKUSHIMA II-3 6559 841018
HAMAOKA-1 5804 740620
HAMAOKA-2 6145 780328
KASHIWAZAKI-1 6463 841212
ONAGAWA-1 6871 831018
SHIMANE-1 4903 730601
TOKAI-2 5508 780118
TSURUGA-1 6863 691003

Sub Total 100927

GCR
TOKAI-1 6826 650504

Sub Total 6826

AGR
PHWR

TOTAL 216822

***** OPERATIONAL RECORDS (1986) *****

----- COUNTRY NAME: Netherlands

TYPE	PLANT NAME	OPHOUR	OPDATE
PWR	BORSSELE	8066	730000
	Sub Total	8066	
BWR			
GCR			
AGR			
PHWR			
	TOTAL	8066	

***** OPERATIONAL RECORDS (1986) *****

----- COUNTRY NAME: Spain

TYPE	PLANT NAME	OPHOUR	OPDATE
PWR			
	ALMARAZ-1	6417	810405
	ALMARAZ-2	7098	830919
	ASCO-1	6208	830617
	ASCO-2	6639	850911
	Sub Total	26362	
BWR			
	COFRENTES	7490	840822
	SANTA MARIA DE GARONA	8174	701105
	Sub Total	15664	
GCR			
AGR			
PHWR			
	TOTAL	42026	

***** OPERATIONAL RECORDS (1986) *****

----- COUNTRY NAME: Sweden

TYRE	PLANT NAME	OPHOUR	OPDATE
PWR			
	RINGHALS-2	6720	740800
	RINGHALS-3	7210	800900
	RINGHALS-4	6940	820600
	Sub Total	20870	
BWR			
	BARSEBAECK-1	8040	750500
	BARSEBAECK-2	7630	770300
	FORSMARK-1	8380	800600
	FORSMARK-2	8380	810100
	FORSMARK-3	8180	850300
	OSKARSHAMN-1	7630	710800
	OSKARSHAMN-2	7890	741000
	OSKARSHAMN-3	8250	850300
	RINGHALS-1	7360	741000
	Sub Total	71740	
GCR			
AGR			
PHWR			
	TOTAL	92610	

***** OPERATIONAL RECORDS (1986) *****
----- COUNTRY NAME: Switzerland

TYPE	PLANT NAME	OPHOUR	OPDATE
PWR			
	BEZNAU-1	7403	690000
	BEZNAU-2	7983	710000
	GOESGEN	7386	790000
	Sub Total	22772	
BWR			
	LEIBSTADT	7670	840000
	MUEHLEBERG	6645	710000
	Sub Total	14315	
GCR			
AGR			
PHWR			
	TOTAL	37087	

***** OPERATIONAL RECORDS (1986) *****

----- COUNTRY NAME: USA

TYPE	PLANT NAME	OPHOUR	OPDATE
PWR	BEAVER VALLEY-1	6244	760510
	BYRON-1	7821	850202
	CALLAWAY-1	7308	841002
	CALVERT CLIFFS-1	6906	741007
	CALVERT CLIFFS-2	8442	761130
	CATAWBA-1	5425	850107
	CATAWBA-2	2678	860805
	CRYSTAL RIVER-3	3691	770114
	DIABLO CANYON-1	5967	840429
	DIABLO CANYON-2	7296	850819
	DONALD COOK-1	7536	750118
	DONALD COOK-2	5561	780310
	FARLEY-1	7276	770809
	FARLEY-2	7550	810505
	FORT CALHOUN-1	8485	730806
	H.B. ROBINSON-2	7119	700920
	HADDAM NECK	5061	670724
	INDIAN POINT-2	5102	730522
	INDIAN POINT-3	6582	760406
	KEWAUNEE	7584	740307
	MAINE YANKEE	7791	721023
	MCGUIRE-1	5022	810808
	MCGUIRE-2	5770	830508
	MILLSTONE-2	6600	751017
	MILLSTONE-3	6201	860123
	NORTH ANNA-1	7560	780405
	NORTH ANNA-2	7301	800612
	OCONEE-1	5949	730419
	OCONEE-2	7254	731111
	OCONEE-3	7835	740905
	PALISADES	1491	710524
	PALO VERDE-1	5498	850525
	PALO VERDE-2	3803	860418
	POINT BEACH-1	7905	701102
	POINT BEACH-2	7263	720530
	PRAIRIE ISLAND-1	7898	731201
	PRAIRIE ISLAND-2	7972	741217
	SALEM-1	7097	761211
	SALEM-2	5629	800808
	SAN ONOFRE-1	2975	670614
	SAN ONOFRE-2	5480	820726
	SAN ONOFRE-3	7422	830829
	ST. LUCIE-1	8424	760422
	ST. LUCIE-2	7327	830602
	SURRY-1	6233	720701
	SURRY-2	6171	730307
	THREE MILE ISLAND-1	6269	740605
	TROJAN	7064	751215
	TURKEY POINT-3	6988	721020
	TURKEY POINT-4	3048	730611
	WATERFORD-3	7012	850304
	WOLF CREEK	6524	850522

ZION-1	5491	730619
ZION-2	7784	731224

Sub Total 346685

BWR

BRUNSWICK-1	8318	761008
BRUNSWICK-2	4233	750320
COOPER	6570	740221
DRESDEN-2	7110	700107
DRESDEN-3	2766	710131
DUANE ARNOLD-1	7348	740323
ENRICO FERMI-2	1403	850621
FITZPATRICK	8076	741117
GRAND GULF-1	5625	820818
HATCH-1	5521	740912
HATCH-2	6452	780704
HOPE CREEK-1	2670	860628
LASALLE-1	2396	820621
LASALLE-2	6614	840310
LIMERICK-1	7146	841222
MILLSTONE-1	8277	701026
MONTICELLO	6985	701210
NINE MILE POINT-1	5824	690905
PEACH BOTTOM-2	7273	730916
PEACH BOTTOM-3	5919	740807
PERRY-1	1430	860606
QUAD CITIES-1	6151	711018
QUAD CITIES-2	5728	720426
RIVER BEND-1	5309	851031
SHOREHAM	1300	850215
SUSQUEHANNA-1	6196	820910
SUSQUEHANNA-2	5947	840508
VERMONT YANKEE	4360	720324

Sub Total 152947

GCR
AGR
PHWR

TOTAL 499632

