

# **VVER-1000 Coolant Transient Benchmark**

## **PHASE 1 (V1000CT-1) Vol. I: Main Coolant Pump (MCP) switching On – Final Specifications**

*Boyan Ivanov and Kostadin Ivanov*  
Nuclear Engineering Program, USA

*Pavlin Groudev and Malinka Pavlova*  
INRNE, Academy of Sciences, Bulgaria

*Vasil Hadjiev*  
Nuclear Power Plant Kozloduy, Bulgaria

US Department of Energy

## **ORGANISATION FOR ECONOMIC CO-OPERATION AND DEVELOPMENT**

Pursuant to Article 1 of the Convention signed in Paris on 14th December 1960, and which came into force on 30th September 1961, the Organisation for Economic Co-operation and Development (OECD) shall promote policies designed:

- to achieve the highest sustainable economic growth and employment and a rising standard of living in Member countries, while maintaining financial stability, and thus to contribute to the development of the world economy;
- to contribute to sound economic expansion in Member as well as non-member countries in the process of economic development; and
- to contribute to the expansion of world trade on a multilateral, non-discriminatory basis in accordance with international obligations.

The original Member countries of the OECD are Austria, Belgium, Canada, Denmark, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, the Netherlands, Norway, Portugal, Spain, Sweden, Switzerland, Turkey, the United Kingdom and the United States. The following countries became Members subsequently through accession at the dates indicated hereafter: Japan (28th April 1964), Finland (28th January 1969), Australia (7th June 1971), New Zealand (29th May 1973), Mexico (18th May 1994), the Czech Republic (21st December 1995), Hungary (7th May 1996), Poland (22nd November 1996), Korea (12th December 1996) and the Slovak Republic (14 December 2000). The Commission of the European Communities takes part in the work of the OECD (Article 13 of the OECD Convention).

## **NUCLEAR ENERGY AGENCY**

The OECD Nuclear Energy Agency (NEA) was established on 1st February 1958 under the name of the OEEC European Nuclear Energy Agency. It received its present designation on 20th April 1972, when Japan became its first non-European full Member. NEA membership today consists of 28 OECD Member countries: Australia, Austria, Belgium, Canada, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Japan, Luxembourg, Mexico, the Netherlands, Norway, Portugal, Republic of Korea, Slovak Republic, Spain, Sweden, Switzerland, Turkey, the United Kingdom and the United States. The Commission of the European Communities also takes part in the work of the Agency.

The mission of the NEA is:

- to assist its Member countries in maintaining and further developing, through international co-operation, the scientific, technological and legal bases required for a safe, environmentally friendly and economical use of nuclear energy for peaceful purposes, as well as
- to provide authoritative assessments and to forge common understandings on key issues, as input to government decisions on nuclear energy policy and to broader OECD policy analyses in areas such as energy and sustainable development.

Specific areas of competence of the NEA include safety and regulation of nuclear activities, radioactive waste management, radiological protection, nuclear science, economic and technical analyses of the nuclear fuel cycle, nuclear law and liability, and public information. The NEA Data Bank provides nuclear data and computer program services for participating countries.

In these and related tasks, the NEA works in close collaboration with the International Atomic Energy Agency in Vienna, with which it has a Co-operation Agreement, as well as with other international organisations in the nuclear field.

### **© OECD 2002**

Permission to reproduce a portion of this work for non-commercial purposes or classroom use should be obtained through the Centre français d'exploitation du droit de copie (CCF), 20, rue des Grands-Augustins, 75006 Paris, France, Tel. (33-1) 44 07 47 70, Fax (33-1) 46 34 67 19, for every country except the United States. In the United States permission should be obtained through the Copyright Clearance Center, Customer Service, (508)750-8400, 222 Rosewood Drive, Danvers, MA 01923, USA, or CCC Online: <http://www.copyright.com/>. All other applications for permission to reproduce or translate all or part of this book should be made to OECD Publications, 2, rue André-Pascal, 75775 Paris Cedex 16, France.

## **FOREWORD**

The OECD Nuclear Energy Agency (OECD/NEA) has completed under US NRC sponsorship a PWR Main Steam Line Break (MSLB) Benchmark involving thermal-hydraulic/neutron kinetics codes. Recently, another OECD-NRC coupled code benchmark was initiated for a BWR turbine trip (TT) transient. During the course of defining and co-ordinating the OECD-NRC PWR MSLB and BWR TT benchmarks a systematic approach has been established to validate best-estimate coupled codes. This approach employs a multi-level methodology that not only allows for a consistent and comprehensive validation process but also contributes to determine additional requirements and to prepare a basis for licensing application of the coupled calculations for a specific reactor type, i.e. establishing safety expertise in analysing reactivity transients. Professional communities have been established during the course of these benchmark activities that led to in-depth discussions of the different aspects required for assessing neutron kinetics modelling relative to a given reactor, and finally on how to implement best-estimate methodologies for transient analysis using coupled codes. The above examples demonstrate the benefit of establishing such international coupled standard problems for each type of reactor.

In the framework of the United States Department of Energy (DOE) International Nuclear Safety Program (INSP), a project was started in 2001 with an overall objective to assess computer codes used in the safety analysis of VVER power plants, specifically for their use in analysing reactivity transients in a VVER-1000 reactor. As a result, a coupled benchmark problem based on data from the Bulgarian Kozloduy Nuclear Power Plant (NPP) has been developed for the purpose of assessing neutron kinetics modelling for a VVER-1000 reactor. This problem is being analysed using both point kinetics and three-dimensional kinetics models. Based on the experience accumulated in safety analyses of western-type reactors (see the examples given above for PWR and BWR international standard benchmark problems), it was proposed that Phase 1 of the VVER-1000 benchmark problem be extended to an international standard problem.

During the Starter International VVER-1000 Benchmark Meeting, which took place on 30 May 2002 in Dresden, Germany, this benchmark was proposed and accepted by the participants. It will be labelled as VVER-1000 Coolant Transient Benchmark (V1000CT) and consist of two phases. Phase 1 (V1000CT-1), led by Pennsylvania State University (PSU), is a main coolant pump (MCP) switching on transient when the three other MCPs are in operation. Phase 2 (V1000CT-2), led by the French *Commissariat à l'énergie atomique* (CEA), includes calculation of coolant mixing experiments and a main steam line break (MSLB) analysis. Both PSU and the CEA are working in co-operation with the Bulgarian Institute for Nuclear Research and Nuclear Energy (INRNE). The sponsors of the benchmark are the OECD/NEA, US DOE, CEA and IRSN. The Kozloduy Nuclear Power Plant (KNPP) provides technical support and the Atomic Energy Research (AER) Working Group D participates in the benchmark activities.

This report provides the specifications for the international, coupled VVER-1000 Coolant Transient (V1000CT-1) benchmark problem. The specification report has been prepared jointly by PSU and INRNE in co-operation with leading specialists from KNPP. The work is sponsored by the

US DOE, the OECD/NEA, and the Nuclear Engineering Program at PSU, and is being performed with the assistance of Argonne National Laboratory (ANL).

The reference MCP switching on problem chosen for simulation in a VVER-1000 is an experiment that was conducted by Bulgarian and Russian engineers during the plant-commissioning phase at the KNPP Unit 6 as part of the start-up tests. The test was carried out due to its importance for the safety of the VVER-1000, model 320 reactor at the NPP. This event is characterised by a rapid increase in coolant flow through the core resulting in a coolant temperature decrease, which is spatially dependent. All necessary information to model and analyse the transient with best-estimate system thermal-hydraulic codes using both point kinetics and three-dimensional kinetics models is provided in the report. A KNPP Unit 6 RELAP5 thermal-hydraulic skeleton input deck, as well as the KNPP 6 RELAP5 four-loop model nodalisation diagram are also provided in Appendix A. They represent part of the source information that provides the plant data. They are derived from the baseline VVER-1000 RELAP5 input deck shown in Appendix D, developed and validated by INRNE for KNPP Unit 6. This baseline input deck is considered part of the data specification.

The specification covers the three exercises of Phase 1 and the required output information is specified for each exercise. In addition, a CD-ROM is also being prepared with the transient boundary conditions, decay heat values as a function of time, and cross-section libraries.

In June 2001 the NEA Nuclear Science Committee (NSC) approved and endorsed the coupled Kozloduy benchmark problem to become an international standard problem for validation of the best-estimate safety codes for VVER applications. The collaboration with the AER group addressing VVER coupling benchmarks concerning this benchmark has provided valuable feedback on these specifications. In June 2002 the NSC approved and endorsed the extension of the benchmark to two phases, as described above.

#### *Acknowledgements*

This report is dedicated to the students of Penn State University, who form part of the next generation of nuclear engineers.

The authors would like to thank Dr. J. Roglans-Ribas, Dr. T. Taiwo, Dr. P. Pizzica and J. Ahrens from the Argonne National Laboratory (ANL), whose support and encouragement in establishing and carrying out this benchmark are invaluable.

This report is the sum of many efforts, the participants, the funding agencies and their staff – the US Department of Energy and the OECD Nuclear Energy Agency. Special appreciation goes to the report reviewers: N. Todorova from PSU, R. Gencheva from INRNE, P. Demerdjiev from KNPP, J.W. Ahrens from ANL-INSC, J.E. Cahalan from ANL, J.E. Fisher from the Idaho National Engineering and Environmental Laboratory (INEEL), and T.A. Taiwo from ANL. Their comments and suggestions were very valuable and significantly improved the quality of this report.

The authors wish to express their sincere appreciation for the outstanding support offered by the KNPP personnel in providing the plant data and discussing the transient characteristics.

Particularly noteworthy have been the efforts of J. Roglans-Ribas, P. Pizzica, M. Petri and J. Ahrens from ANL. With their help, funding has been secured, enabling this project to proceed. We also thank them for their excellent technical advice and assistance.

The authors would like to thank Dr. János Gadó, Director of the Hungarian Central Research Institute for Physics (KFKI), Prof. J. Aragones from *Universidad Politécnica de Madrid* (UPM), both members of the NEA Nuclear Science Committee and Prof. F. D'Auria of the University of Pisa (UP), member of the NEA Committee on the Safety of Nuclear Installations, whose support and encouragement in establishing and carrying out this benchmark are invaluable.

The authors wish to express their sincere appreciation for the outstanding support offered by Dr. Enrico Sartori, who provided efficient administration, organisation and valuable technical recommendations.

Finally, we are grateful to Hélène Déry for having devoted her competence and skills to the preparation of this report for publication.



## TABLE OF CONTENTS

<b>FOREWORD .....</b>	3
<b>LIST OF ABBREVIATIONS .....</b>	11
<b>Chapter 1. INTRODUCTION .....</b>	13
1.1 Background.....	13
1.2 Definition of three benchmark exercises .....	14
<b>Chapter 2. CORE AND NEUTRONIC DATA .....</b>	15
2.1 General.....	15
2.2 Core geometry and fuel assembly (FA) geometry.....	15
2.3 Neutron modelling.....	16
2.4 Two-dimensional assembly types and three-dimensional composition maps .....	16
2.5 Cross-section library .....	16
<b>Chapter 3. THERMAL-HYDRAULIC DATA .....</b>	27
3.1 Component specifications for the full thermal-hydraulic system model .....	27
3.2 Definition of the core thermal-hydraulic boundary conditions model.....	30
3.3 Thermal-physical and heat-transfer specifications .....	31
<b>Chapter 4. NEUTRONIC/THERMAL-HYDRAULIC COUPLING .....</b>	63
<b>Chapter 5. VVER-1000 MCP SWITCHING ON PROBLEM .....</b>	65
5.1 Description of MCP switching on scenario .....	65
5.2 Initial steady-state conditions .....	66
5.3 Point kinetics model inputs.....	67
5.4 Transient calculations .....	67
<b>Chapter 6. OUTPUT REQUESTED .....</b>	75
6.1 Initial steady-state results .....	75
6.2 Transient results.....	76
6.3 Output format.....	77
<b>REFERENCES .....</b>	83
<b>Appendices</b>	
<b>A. RELAP5 nodalisation schemes and skeleton input deck .....</b>	85
<b>B. Sample cross-section table.....</b>	103
<b>C. MCP test plant data.....</b>	107

**List of tables**

Table 2.2.1.	FA geometry data .....	18
Table 2.3.1.	Decay constant and fractions of delayed neutrons .....	18
Table 2.3.2.	Heavy-element decay heat constants.....	18
Table 2.3.3.	Operational history .....	19
Table 2.4.1.	Definition of assembly types .....	19
Table 2.4.2.	Composition numbers in axial layers for each assembly type.....	20
Table 2.5.1.	Range of variables .....	21
Table 2.5.2.	Key to macroscopic cross-section tables .....	21
Table 2.5.3.	Macroscopic cross-section table's structure .....	22
Table 3.1.1.1.	Reactor vessel design data.....	32
Table 3.1.1.2.	Reactor vessel volume data .....	32
Table 3.1.1.3.	Description of vessel plates .....	33
Table 3.1.1.4.	Description of control rod guide tubes above the core .....	33
Table 3.1.1.5.	Description of reactor cover .....	34
Table 3.1.1.6.	Description of core barrel.....	34
Table 3.1.1.7.	Description of basket.....	34
Table 3.1.2.1.	Reactor coolant system nominal steady-state parameters .....	35
Table 3.1.2.2.	Primary system component elevations .....	35
Table 3.1.2.3.	Reactor coolant system piping design data .....	35
Table 3.1.2.4.	Flow areas .....	35
Table 3.1.2.5.	Reactor coolant system volume data .....	36
Table 3.1.2.6.	Pressurizer description .....	36
Table 3.1.2.7.	Reactor coolant system flow data .....	36
Table 3.1.2.8.	Safety valve data .....	37
Table 3.1.2.9.	Main coolant pump description .....	37
Table 3.1.3.1.	Steam generator design data.....	37
Table 3.1.3.2.	Steam generator nominal characteristics .....	38
Table 3.1.3.3.	Steam generator geometry description .....	38
Table 3.1.3.4.	Tube bundle data .....	39
Table 3.1.3.5.	SG secondary side data .....	40
Table 3.3.1.	Properties of fuel .....	40
Table 3.3.2.	Properties of cladding .....	41
Table 3.3.3.	Properties of fuel rod gap .....	41
Table 3.3.4.	Properties of steel 15ХНМФА .....	41
Table 3.3.5.	Properties of steel 08X18H10T .....	41
Table 3.3.6.	Properties of steel 12X18H10T .....	42
Table 3.3.7.	Properties of steel 10ГН2МФА .....	42
Table 5.2.1.	Initial conditions for KNPP unit 6 at 883.5 MWt .....	69
Table 5.2.2.	Definition of steady-states.....	69
Table 5.3.1.	Summary of point kinetics analysis input values .....	70
Table 5.4.1.	KNPP analysis assumptions .....	70
Table 5.4.2.	MCP#3 rotor speed boundary conditions .....	70
Table 5.4.3.	Feedwater flow boundary conditions .....	71
Table 5.4.4.	Steam generators pressure boundary conditions .....	72
Table 5.4.5.	Pressurizer heaters logic .....	73
Table 6.1.	Steady state conditions .....	78
Table 6.2.	Sequence of events .....	79

Table 6.3.	Sequence of events for extreme scenario of Exercise 3 .....	79
Table C.1.	Water level in the pressuriser during the transient .....	109
Table C.2.	Water level in SG #1 during the transient .....	110
Table C.3.	Water level in SG #2 during the transient .....	111
Table C.4.	Water level in SG #3 during the transient .....	112
Table C.5.	Water level in SG #4 during the transient .....	113
Table C.6.	Cold leg #1 coolant temperature during the transient .....	114
Table C.7.	Cold leg #2 coolant temperature during the transient .....	115
Table C.8.	Cold leg #3 coolant temperature during the transient .....	116
Table C.9.	Cold leg #4 coolant temperature during the transient .....	117
Table C.10.	Hot leg #1 coolant temperature during the transient .....	118
Table C.11.	Hot leg #2 coolant temperature during the transient .....	119
Table C.12.	Hot leg #3 coolant temperature during the transient .....	120
Table C.13.	Hot leg #4 coolant temperature during the transient .....	121
Table C.14.	Pressure above the core .....	122
Table C.15.	Reactor pressure drop .....	123
Table C.16.	MCP #1 pressure drop .....	124
Table C.17.	MCP #2 pressure drop .....	125
Table C.18.	MCP #3 pressure drop .....	126
Table C.19.	MCP #4 pressure drop .....	127

## List of figures

Figure 2.2.1.	Cross-section of the reactor core .....	23
Figure 2.2.2.	Arrangement of control rods .....	24
Figure 2.4.1.	Two-dimensional assembly type map .....	25
Figure 2.4.2.	Profiled fuel assembly .....	26
Figure 3.1.1.1.	Reactor .....	43
Figure 3.1.1.2.	Reactor vessel .....	44
Figure 3.1.1.3.	Core barrel .....	45
Figure 3.1.1.4.	Reactor cover .....	46
Figure 3.1.1.5.	Core basket .....	47
Figure 3.1.1.6.	Reactor shielding tubes block .....	48
Figure 3.1.1.7.	Shielding tube .....	49
Figure 3.1.1.8.	Fuel assembly .....	50
Figure 3.1.1.9.	Control rod cluster .....	51
Figure 3.1.2.1.	Primary circuit loops – layout .....	52
Figure 3.1.2.2.	Primary circuit layout .....	53
Figure 3.1.2.3.	Primary circuit layout .....	54
Figure 3.1.2.4.	Main equipment layout .....	55
Figure 3.1.2.5.	Main coolant pump .....	56
Figure 3.1.2.6.	Pressuriser .....	57
Figure 3.1.2.7.	Pressuriser cross-section .....	58
Figure 3.1.3.1.	Steam generator .....	59
Figure 3.1.3.2.	Steam generator .....	60
Figure 3.2.1.	Transient core boundary conditions mapping scheme for the second exercise .....	61
Figure 5.3.1.	Initial HP radial power distribution .....	73
Figure 5.3.2.	Initial HP core average axial relative power distribution .....	73
Figure 6.3.1.	Form for axial power distribution .....	81
Figure 6.3.2.	Form for radial power distribution .....	81

Figure A.1.	VVER-1000 Unit 6 reactor and pressuriser RELAP5 four loops model.....	87
Figure A.2.	VVER-1000 Unit 6 steam generator RELAP5 four loops model .....	88
Figure A.3.	Four – quadrant MCP head characteristics.....	101
Figure A.4.	Four – quadrant MCP torque characteristics .....	102
Figure C.1.	Water level in the pressuriser during the transient .....	109
Figure C.2.	Water level in SG #1 during the transient .....	110
Figure C.3.	Water level in SG #2 during the transient .....	111
Figure C.4.	Water level in SG #3 during the transient .....	112
Figure C.5.	Water level in SG #4 during the transient .....	113
Figure C.6.	Cold leg #1 coolant temperature during the transient .....	114
Figure C.7.	Cold leg #2 coolant temperature during the transient .....	115
Figure C.8.	Cold leg #3 coolant temperature during the transient .....	116
Figure C.9.	Cold leg #4 coolant temperature during the transient .....	117
Figure C.10.	Hot leg #1 coolant temperature during the transient .....	118
Figure C.11.	Hot leg #2 coolant temperature during the transient .....	119
Figure C.12.	Hot leg #3 coolant temperature during the transient .....	120
Figure C.13.	Hot leg #4 coolant temperature during the transient .....	121
Figure C.14.	Pressure above the core .....	122
Figure C.15.	Reactor pressure drop.....	123
Figure C.16.	MCP #1 pressure drop.....	124
Figure C.17.	MCP #2 pressure drop.....	125
Figure C.18.	MCP #3 pressure drop.....	126
Figure C.19.	MCP #4 pressure drop.....	127

## LIST OF ABBREVIATIONS

ADF	Assembly Discontinuity Factor
ANS	American Nuclear Society
APSR	Axial Power Shaping Rods
BOC	Beginning of Cycle
BWR	Boiling Water Reactor
CA	Control Assembly
DOE	Department of Energy
DTC	Doppler Temperature Coefficient
EFPD	Effective Full Power Days
EFW	Emergency Feed Water
EHTC	Electro Hydraulic Turbine Controller
FA	Fuel Assembly
FWP	Feed Water Pump
HP	Hot Power
HZP	Hot Zero Power
ID	Hot Zero Power
INRNE	Institute for Nuclear Research and Nuclear Energy
INSP	International Nuclear Safety Program
KNPP	Kozloduy Nuclear Power Plant
LOCA	Lost of Coolant Accident
LWR	Light Water Reactor
MCP	Main Coolant Pump
MSH	Main Steam Header
MSLB	Main Steam Line Break
MTC	Moderator Temperature Coefficient
NEA	Nuclear Energy Agency
NFMS	Neutron Flux Monitoring System (in-core reactor control system)
ANS	American Nuclear Society
NP	Normalised Power
NRC	Nuclear Regulatory Commission
OD	Outside Diameter
OECD	Organisation for Economic Co-operation and Development
PRV	Pressuriser Relief Valve
PSU	Pennsylvania State University
PWR	Pressuriser Water Reactor
RC	Reactor Coolant
RCS	Reactor Coolant System
RPLC	Reactor Power Limitation Controller
RPC	Reactor Power Controller
SG	Steam Generator
TG	Turbo Generator
TT	Turbine Trip
UES	Universal Electronic System
WP-1	Warning Protection



## *Chapter 1*

### **INTRODUCTION**

Incorporation of full three-dimensional (3-D) models of the reactor core into system transient codes allows for a “best-estimate” calculation of interactions between the core behaviour and plant dynamics. Recent progress in computer technology has made the development of coupled system thermal-hydraulic (T-H) and neutron kinetics code systems feasible. Considerable efforts have been made in various countries and organisations in this direction. To verify the capability of the coupled codes to analyse complex transients with coupled core-plant interactions and to fully test thermal-hydraulic coupling, appropriate Light Water Reactor (LWR) transient benchmarks need to be developed on a higher “best-estimate” level. The previous sets of transient benchmark problems addressed separately system transients (designed mainly for thermal-hydraulic (T-H) system codes with point kinetics models) and core transients (designed for T-H core boundary conditions models coupled with three-dimensional (3-D) neutron kinetics models). The Nuclear Energy Agency (NEA) of the Organisation for Economic Co-operation and Development (OECD) has recently completed under the US Nuclear Regulatory Commission (NRC) sponsorship a PWR Main Steam Line (MSLB) Benchmark [1] for evaluating coupled T-H system and neutron kinetics codes. A benchmark team from the Pennsylvania State University (PSU) has been responsible for developing the benchmark specification, assisting the participants and co-ordinating the benchmark activities. The benchmark was well accepted by the international community. A similar benchmark for codes used in analysis of a BWR plant transient has been recently defined. The Turbine Trip (TT) transients in a BWR are pressurisation events in which the coupling between core phenomena and system dynamics plays an important role. In addition the available real plant experimental data makes the benchmark problem very valuable. The NEA, OECD and US NRC have approved the BWR TT benchmark for the purpose of validating advanced system best-estimate analysis codes. This specification is a further continuation of the above activities and it defines a coupled code benchmark problem for validation of thermal-hydraulics system codes for application to Soviet-designed VVER-1000 reactors based on actual plant data.

#### **1.1 Background**

The United States Department of Energy (US DOE), under the auspices of the INSP, provides assistance to the nuclear industry in Central and Eastern Europe and the countries of the Former Soviet Union to help foster and further develop the safety analysis capabilities at individual nuclear power plants and their technical support organisations, to the extent that it supports safety operation.

Most transients in a VVER reactor can be properly analysed with a system thermal-hydraulics code like RELAP5, with simplified neutron kinetics models (point kinetics). A few specific transients require more advanced, three-dimensional (3-D) modelling for neutron kinetics for a proper description. A coupled thermal-hydraulics/3-D neutron kinetics code would be the right tool for such tasks.

The proposed benchmark problem [2] will be analysed with RELAP5/MOD3.2 [3] and the results will be compared with those obtained with coupled codes with 3-D kinetics such as RELAP5-3D [4] and TRAC-PF1/NEM [5].

The reference problem chosen for simulation is a Main Coolant Pump (MCP) switching on when the other three main coolant pumps are in operation, which is a real transient of an operating VVER-1000 power plant. This event is characterised by rapid increase in the flow through the core resulting in a coolant temperature decrease, which is spatially dependent. This leads to insertion of spatially distributed positive reactivity due to the modelled feedback mechanisms and non-symmetric power distribution. Simulation of the transient requires evaluation of core response from a multi-dimensional perspective (coupled three-dimensional (3-D) neutronics/core thermal-hydraulics) supplemented by a one-dimensional (1-D) simulation of the remainder of the reactor coolant system. The purpose of this benchmark is three-fold:

- To verify the capability of system codes to analyse complex transients with coupled core-plant interactions.
- To fully test the 3-D neutronics/thermal-hydraulic coupling.
- To evaluate discrepancies between predictions of coupled codes in best-estimate transient simulations.

## 1.2 Definition of three benchmark exercises

In addition to being based on a well-defined problem, with reference design and data from the Kozloduy Nuclear Power Plant Unit 6 (KNPP) [6], the benchmark includes a complete set of input data, and consists of three exercises. These exercises are discussed below.

### 1.2.1 *Exercise 1 – Point kinetics plant simulation*

The purpose of this exercise is to test the primary and secondary system model responses. Provided are compatible point kinetics model inputs, which preserve axial and radial power distribution, and scram reactivity obtained using a 3-D code neutronics model and a complete system description.

### 1.2.2 *Exercise 2 – Coupled 3-D neutronics/core T-H response evaluation*

The purpose of this exercise is to model the core and the vessel only. Inlet and outlet core transient boundary conditions are provided.

### 1.2.3 *Exercise 3 – Best-estimate coupled code plant transient modeling*

This exercise combines elements of the first two exercises in this benchmark and is an analysis of the transient in its entirety.

## *Chapter 2*

### **CORE AND NEUTRONIC DATA**

#### **2.1 General**

The reference design for the VVER-1000 is derived from the reactor geometry and operational data of the Kozloduy NPP Unit 6 [6, 9]. The data provided in the following paragraphs, appendices, and in the pertinent tables and figures, completely defines the VVER-1000 benchmark exercise. A KNPP Unit 6 RELAP5 thermal-hydraulic skeleton input deck, as well as the KNPP 6 RELAP5 four-loop model nodalization diagram are given in Appendix A. They represent part of the source information that provides the plant data. They are derived from the baseline VVER-1000 RELAP5 input deck, developed and validated by INRNE for KNPP Unit 6. The baseline VVER-1000 RELAP5 input deck is shown in Appendix D. The Engineering Handbook that supports this baseline deck and nodalization diagram has been already reviewed and approved by DOE [7]. The VVER-1000 MCP Switching on transient scenario, described in Section 5.1, is specified.

#### **2.2 Core geometry and fuel assembly (FA) geometry**

The radial geometry of the reactor core is shown in Figure 2.2.1. Radially, the core is divided into hexagonal cells with a pitch 23.6 cm, each corresponding to one fuel assembly (FA), plus a radial reflector (shaded area) of the same size. There are a total of 211 assemblies, 163 FA and 48 reflector assemblies. Axially, the reactor core is divided into 10 layers with a height (starting from the bottom) of 35.5 cm, adding up to a total active core height of 355 cm. Both upper and lower axial reflectors have a thickness of 23.6 cm. The axial nodalisation scheme accounts for material changes in the fuel design and for the exposure and moderator temperature (spectral history) variations. Zero flux boundary conditions are specified on outer reflector surface for both radial and axial reflectors.

The mesh used for the calculation is up to the participant, and should be chosen according to the numerical capabilities of the code. For example axially the reactor core can be also modelled with 20 layers with a height of 17.75 cm. Output should, however, give volume-averaged results on the specified mesh in the format described in Chapter 6.

Fuel assemblies with different  $^{235}\text{U}$  enrichments are present in the core. This is the first cycle for NPP Kozloduy Unit 6 and all assemblies are fresh. The radial distributions of the enrichment can be found in Section 2.4; the geometric data for the FA is given in Table 2.2.1.

The available gap width is 0.08 mm (distance between pellet surface and inside clad wall). For the neutronic problem, each of the FAs is considered to be homogeneous.

The radial arrangement of the control assemblies (CA) is shown in Figure 2.2.2. The sixty-one CAs, grouped into ten groups, are full-length control rods except group #5, which consists of part-

length control rods. The part-length control rods have neutron absorber only in its lower half and they are used to damp the Xe-oscillations. The full-length control rods contain a strong neutron absorber over a length that spans most of the active core region. In addition to the radial arrangement, the position of control rod insertion in units of cm is given from the bottom of the lower reflector. The total CA length, which coincides with the absorber length, is 371 cm. No tip of control rods is defined. The position of the lower CA absorber edge from the bottom of the lower reflector is 23.6 cm for a completely inserted CA, and 378.6 cm for a completely withdrawn CA. The definition completely withdrawn means withdrawn from the active core, i.e. out of the core.

### 2.3 Neutron modelling

Two neutron energy groups and six decay groups for delayed neutrons are modelled. The energy release per fission for the two prompt neutron groups is  $0.3213 \times 10^{-10}$  and  $0.3206 \times 10^{-10}$  W-s/fission, and this energy release is considered to be independent of time and space. Table 2.3.1 shows the time constants and fractions of delayed neutrons.

It is recommended that ANS-79 be used as a decay heat standard model. In total 71 decay-heat groups are used: 69 groups are used for the three isotopes  $^{235}\text{U}$ ,  $^{239}\text{Pu}$  and  $^{238}\text{U}$  with the decay-heat constants defined in the 1979 ANS standard; plus, the heavy-element decay heat groups for  $^{239}\text{U}$  and  $^{239}\text{Np}$  are used with constants given in Table 2.3.2. It is recommended that the participants also use the operational history provided in Table 2.3.3. For participants who are not capable of using the ANS-79 decay heat standard, a file of the decay heat evolution throughout the transient for both scenario versions is provided on CD-ROM under the directory **Decay-Heat**. These predictions are obtained using the Pennsylvania State University (PSU) coupled code TRAC-PF1/NEM [5]. The effective decay heat energy fraction of the total thermal power (the relative contribution in the steady state) is equal to 0.07143.

### 2.4 Two-dimensional assembly types and three-dimensional composition maps

Twenty-nine assembly types are contained within the core geometry. There are 283 unrodded and 110 rodded compositions. The corresponding sets of cross-sections are provided. Each composition is defined by material properties (due to changes in the fuel design) and burn-up. The burn-up dependence is a three-component vector variables: exposure (MWd/kgU), spectral history ( $T_{\text{mod}}$ ) and control rod (CR) history. The definition of assembly types is shown in Table 2.4.1. The radial distribution of these assembly types within the reactor geometry is shown in Figure 2.4.1. The 2-D assembly type map is shown in a one-sixth-core symmetry sector together with the assembly exposure values at the 30.7 EFPD in cycle depletion. The axial locations of compositions for each assembly are shown in Table 2.4.2.

### 2.5 Cross-section library

A complete set of diffusion coefficients and macroscopic cross-sections for scattering, absorption, and fission as a function of the moderator density and fuel temperature is defined for each composition. The assembly discontinuity factors (ADFs) are taken into consideration implicitly by incorporating them into the cross-sections (i.e. by dividing the cross sections with ADFs for each energy group) in order to minimise the size of the cross-section tables. The group inverse neutron velocities are also provided for each composition. All the data in the cross-section library was obtained using the HELIOS code [19]. Dependence of the cross-sections on the above variables is specified

through a two-dimensional table look-up. Each composition is assigned to a cross-section set containing separate tables for the diffusion coefficients and cross-sections, with each point in the table representing a possible core state. The expected range of the transient is covered by the selection of an adequate range for the independent variables shown in Table 2.5.1. A linear interpolation scheme is used to obtain the appropriate total cross-sections from the tabulated ones based on the reactor conditions being modelled. Table 2.5.2 shows the definition of a cross-section table associated with a composition. Table 2.5.3 shows the macroscopic cross-section table structure for one cross-section set. All cross-section sets are assembled into a cross-section library. The cross-sections are provided in separate libraries for rodded (**nemtabr**) (numerical nodes with a CA) and unrodded compositions (**nemtab**). The format of each library is as follows:

- The first line of data is used to show the number of data points used for the independent thermal-hydraulic (T-H) parameters. These parameters include fuel temperature, moderator density, boron concentration and moderator temperature.
- Each cross-section set is in the order shown in Table 2.5.3. Each table is in the format described in Table 2.5.2. More detailed information on this format is presented in Appendix B. First, the values of the independent thermal-hydraulic parameters (fuel temperature and moderator density) used to specify that particular set of cross-sections are listed, followed by the values of the cross-sections. Finally, the group inverse neutron velocities complete the data for a given cross-section set.
- The dependence on fuel temperature in the reflector cross-section tables is also modelled. This is because the reflector cross-sections are generated by performing lattice physics transport calculations, including the next fuel region. In order to simplify the reflector feedback modelling the following assumptions are made for this benchmark: an average fuel temperature value equal to 600 K is used for the radial reflector cross-section modelling in both the initial steady-state and transient simulations, and the average coolant density for the radial reflector is equal to the inlet coolant density. For the axial reflector regions the following assumptions are made: for the bottom – the fuel temperature is equal to the inlet coolant temperature (per T-H channel or cell) and the coolant density is equal to the inlet coolant density (again per channel); for the top – the fuel temperature is equal to the outlet coolant temperature (per channel) and the coolant density is equal to the outlet coolant density (per channel).

All cross-section data, along with a program for linear interpolation, are supplied on CD-ROM under the directory **XS-Lib** in the format described above.

**Table 2.2.1. FA geometry data**

Parameter	Value
Pellet diameter, mm	7.56
Central void diameter, mm	1.40
Clad diameter (outside), mm	9.10
Clad wall thickness, mm	0.69
Fuel rod total length, mm	3837
Fuel rod active length (cold state), mm	3530
Fuel rod active length (hot state), mm	3550
Fuel rod pitch, mm	12.75
Fuel rod grid	Triangular
Number of guide tubes	18
Guide tube diameter (outside), mm	12.60
Guide tube diameter (inside), mm	11.00
Number of fuel pins	312
Number of water rods/assembly	1
Water rod diameter (outside), mm	11.20
Water rod diameter (inside), mm	9.60
FA wrench size, mm	234
FA pitch, mm	236

**Table 2.3.1. Decay constant and fractions of delayed neutrons**

Group	Decay constant ( $s^{-1}$ )	Relative fraction of delayed neutrons in %
1	0.0125	0.0209
2	0.0305	0.1493
3	0.0111	0.1368
4	0.3050	0.2866
5	1.1300	0.0984
6	3.0000	0.0348

Total fraction of delayed neutrons: 0.7268%.

**Table 2.3.2. Heavy-element decay heat constants**

Group no. (isotope)	Decay constant ( $s^{-1}$ )	Available energy from a single atom (MeV)
70 ( $^{239}\text{U}$ )	$4.91 \times 10^{-4}$	0.474
71 ( $^{239}\text{Np}$ )	$3.41 \times 10^{-6}$	0.419

**Table 2.3.3. Operational history**

No.	Time, EFPD	Thermal power, MW	No.	Time, EFPD	Thermal power, MW
1	2.00	750	7	12.85	240
2	2.55	840	8	19.90	1 500
3	3.25	90	9	20.47	1 710
4	6.49	1 230	10	25.50	2 160
5	6.94	1 350	11	26.70	1 800
6	12.37	1 470	12	30.30	2 160

**Table 2.4.1. Definition of assembly types**

Assembly type	Enrichment, w/o	Exposure, MWd/kgU
1	2.0	1.219
2	2.0	1.283
3	2.0	1.311
4	3.0	1.553
5	2.0	1.360
6	2.0	1.409
7	3.3 <sup>1</sup>	1.391
8	3.0	1.603
9	2.0	1.271
10	2.0	1.286
11	3.0	1.676
12	3.0	1.578
13	3.3	0.909
14	2.0	1.271
15	2.0	1.213
16	2.0	1.271
17	2.0	1.246
18	3.3	1.065
19	2.0	1.286
20	2.0	1.271
21	3.0	1.489
22	3.3	1.053
23	3.0	1.676
24	2.0	1.246
25	3.3	1.053
26	3.0	1.578
27	3.3	1.065
28	3.3	0.909
29	Radial reflector	

1. Profiled fuel assembly – see Figure 2.4.2.

**Table 2.4.2. Composition numbers in axial layers for each assembly type**

Bottom

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29
<b>1</b>	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	281	
<b>2</b>	1	11	21	31	41	51	61	71	81	91	101	111	121	131	141	151	161	171	181	191	201	211	221	231	241	251	261	271	282
<b>3</b>	2	12	22	32	42	52	62	72	82	92	102	112	122	132	142	152	162	172	182	192	202	212	222	232	242	252	262	272	282
<b>4</b>	3	13	23	33	43	53	63	73	83	93	103	113	123	133	143	153	163	173	183	193	203	213	223	233	243	253	263	273	282
<b>5</b>	4	14	24	34	44	54	64	74	84	94	104	114	124	134	144	154	164	174	184	194	204	214	224	234	244	254	264	274	282
<b>6</b>	5	15	25	35	45	55	65	75	85	95	105	115	125	135	145	155	165	175	185	195	205	215	225	235	245	255	265	275	282
<b>7</b>	6	16	26	36	46	56	66	76	86	96	106	116	126	136	146	156	166	176	186	196	206	216	226	236	246	256	266	276	282
<b>8</b>	7	17	27	37	47	57	67	77	87	97	107	117	127	137	147	157	167	177	187	197	207	217	227	237	247	257	267	277	282
<b>9</b>	8	18	28	38	48	58	68	78	88	98	108	118	128	138	148	158	168	178	188	198	208	218	228	238	248	258	268	278	282
<b>10</b>	9	19	29	39	49	59	69	79	89	99	109	119	129	139	149	159	169	179	189	199	209	219	229	239	249	259	269	279	282
<b>11</b>	10	20	30	40	50	60	70	80	90	100	110	120	130	140	150	160	170	180	190	200	210	220	230	240	250	260	270	280	282
<b>12</b>	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	283	

Top

**Table 2.5.1. Range of variables**

T Fuel (°K)	Rho M. (kg/m <sup>3</sup> )
540.00	786.84
760.00	786.84
855.00	786.84
1 000.00	786.84
1 500.00	786.84
540.00	761.78
760.00	761.78
855.00	761.78
1 000.00	761.78
1 500.00	761.78
540.00	712.50
760.00	712.50
855.00	712.50
1 000.00	712.50
1 500.00	712.50
540.00	661.68
760.00	661.68
855.00	661.68
1 000.00	661.68
1 500.00	661.68

**Table 2.5.2. Key to macroscopic cross-section tables**

T <sub>f1</sub>	T <sub>f2</sub>	T <sub>f3</sub>	T <sub>f4</sub>	T <sub>f5</sub>
ρ <sub>m1</sub>	ρ <sub>m2</sub>	ρ <sub>m3</sub>	ρ <sub>m4</sub>	Σ <sub>1</sub>
Σ <sub>2</sub>	...			
	...	Σ <sub>19</sub>	Σ <sub>20</sub>	

Where:

– T<sub>f</sub> is the Doppler (fuel) temperature (°K)

– ρ<sub>m</sub> is the moderator density (kg/m<sup>3</sup>)

Macroscopic cross-sections are in units of cm<sup>-1</sup>

**Table 2.5.3. Macroscopic cross-section table's structure**

```
*****
NEM – Cross-section table input.

T fuel      Rho mod.          Boron ppm.        T Mod.
5           4                  0                 0

*****
***** Cross-section set #
#
*****
Group no. 1.

*****
***** Diffusion coefficient table.

*****
***** Absorption cross-section table.

*****
***** Fission cross-section table.

*****
***** Nu-fission cross-section table.

*****
***** Scattering from group 1 to 2 cross-section table.

*****
*****
Group no. 2.

*****
***** Diffusion coefficient table.

*****
***** Absorption cross-section table.


*****
***** Fission cross-section table.

*****
***** Nu-fission cross-section table.


*****
***** Xenon absorption cross-section table.

*****
*****
Inv. neutron velocities.
```

**Figure 2.2.1. Cross-section of the reactor core**




**Figure 2.2.2. Arrangement of control rods**




Bank	No rods	Purpose
I	6	Safety
II	6	Safety
III	6	Safety
IV	6	Safety
V	4	Path-length
VI	9	Safety
VII	6	Safety
VIII	6	Safety
IX	6	Safety
X	6	Regulating

**Figure 2.4.1. Two-dimensional assembly type map**




1 – Type of fuel assembly


2 – Burnup MWd/kgU




Fuel assembly with enrichment 2.0%




Profiled fuel assembly with enrichment 3.3%



Fuel assembly with enrichment 3.0%




Reflector Assembly



Fuel assembly with enrichment 3.3%

**Figure 2.4.2. Profiled fuel assembly**



## *Chapter 3*

### **THERMAL-HYDRAULIC DATA**

A KNPP Unit 6 RELAP5 skeleton thermal-hydraulic (T-H) input deck, as well as the KNPP Unit 6 four-loop model nodalisation diagrams [7], are provided in Appendix A. The baseline VVER-1000 RELAP5 input deck is shown in Appendix D.

#### **3.1 Component specifications for the full thermal-hydraulic system model**

##### **3.1.1 Reactor vessel**

The following tables provide all of the necessary data about the KNPP Unit 6 Reactor Vessel. The KNPP Unit 6 RELAP5 thermal-hydraulic skeleton input deck (given in Appendix A) represents part of the source information that provides the plant data. It is derived from the baseline VVER-1000 RELAP5 input deck, developed and validated by INRNE for KNPP Unit 6. The Engineering Handbook that supports this baseline deck has been already reviewed and approved by DOE [7]. Table 3.1.1.1 contains all of the design data, and Table 3.1.1.2 contains the volume data. The volumes given in tables are the actual physical volumetric data. Figures 3.1.1.3 through 3.1.1.7 provide more specific details about all of the components in the pressure vessel.

The reactor pressure vessel is the pressure boundary of the reactor core and high-pressure coolant. The detailed geometry of the reactor pressure vessel is presented on Figures 3.1.1.1 and 3.1.1.2.

The lower part of the core barrel consists of an elliptical flow distributor plate with perforations passing through the inner vessel. The perforations are circular holes 40 mm in diameter and 1 344 holes are present (Figure 3.1.1.3.). The curvature of the reactor shaft elliptic bottom is greater than the curvature of the reactor vessel elliptic bottom. This configuration allows for a significant amount of flow area to be present even during the most severe loss of coolant accident (LOCA) and high vessel temperatures. Thus, this increase in area was a way to try and guarantee that a significant part of the flow path will be available so that coolant will be able to reach the active section of the core during severe conditions. Once the coolant passes through the perforation of the inner vessel, the flow reaches the lower plenum, which is adjacent to the fuel support columns.

The fuel support columns are also perforated to allow the coolant to enter into the fuel assemblies themselves. The fuel support columns are welded to the inner vessel and welded together at the top such that no flow passes around the fuel support columns. The upper part of support columns has a hexagonal shape with a central circular opening for the bottom of the fuel assemblies. There are 163 fuel support columns since there is a one to one correspondence between the fuel assemblies and the support columns. The fuel support columns have an outside diameter 194 mm with a metal thickness of 12 mm. The perforations in the support column are ellipsoidal slits about 30 mm long

(major axe) and 3 mm wide (minor axe). Each column along the height has 12 rows of slits. Every two adjacent rows are shifted in a chess layout. The distance between two adjacent slits in a row is 60 mm, thus every four adjacent slits form a rhomboid 30 mm wide. Primary coolant flows through the slits, upward through the supporting columns and into the fuel assemblies. The perforations act as an orifice to distribute the flow. Another function of the slots is to prevent debris from entering the active fuel region and completely blocking off an assembly. Supporting columns also ensure that an even stress is applied to the elliptic bottom of the inner vessel while providing the support for the fuel.

The core barrel rests on a support ledge recessed in the upper part of the reactor pressure vessel immediately below the level where the upper head is bolted on. Outside of the upper part of the core barrel is the supporting ring. The core barrel is secured in place by the reactor pressure vessel head. The top of the core barrel has an “o” ring around its circumference. When the head is bolted on, the “o” rings are elastically compressed between the head and the supporting ring of the core barrel to ensure a complete seal. The core barrel is shown on Figure 3.1.1.3.

### **3.1.2 Reactor coolant system**

This section provides participants with the data for the reactor coolant system (RCS). Table 3.1.2.1 summarises the basic RCS parameters, such as pressure drop. Table 3.1.2.2 provides the elevations for the primary system components, while Table 3.1.2.3 provides all of the data on the system piping [6]. Tables 3.1.2.4 and 3.1.2.5 contain the flow areas and volume data for the system, respectively. Table 3.1.2.6 gives the pressuriser description, and Tables 3.1.2.7 through 3.1.2.9 list the system flow data, all of the safety valve data and MCP performance data respectively. Figures 3.1.2.1 through 3.1.2.7 provide specific details about the RCS arrangement, the hot and cold leg pipes, the surge line, the pressuriser, and the main coolant pump.

Primary heat transport system transfers the heat produced in the reactor through four parallel loops to horizontal steam generators. The layout and elevations of the primary circuit are presented on Figures 3.1.2.1 through 3.1.2.4.

The hot leg nozzle for each loop of VVER-1000/V320 is located on the reactor pressure vessel directly above the cold leg nozzle for each corresponding primary loop. The distance between the centres of the hot and cold leg is 1 800 mm. The hot leg pipe runs directly to the nearest steam generator header and has only one elbow of 90 degrees. This configuration was selected to provide the shortest path to the steam generator and to reduce the hydraulic losses at the same time.

The Kozloduy VVER-1000 reactor uses standard Russian built main coolant pumps (MCP). There are four units, which are of the type GCN 195M series. MCP is shown on Figure 3.1.2.5. These pumps are run by electrical motors 6kV AC. The GCN-195M pumps are vertical, single stage, and centrifugal. More information about the MCP can be found in Appendix A. The nominal flow of the MCP at 50 Hz is  $5.889 \text{ m}^3/\text{s}$ . For the normal operation of the MCPs the following supporting systems are required:

- Oil lubrication system.
- Intermediate circuit water system.
- Sealing water system.

- Service water system.
- Independent cooling circuit.

In case of loss of service water or intermediate circuit water the operation of MCPs is available up to 3 min. In case of loss of sealing water – up to 2 h. In case of primary saturation or containment overpressure protection signals 15 s after the closure of the isolation valves the MCPs are stopped by self-protection on low oil pressure. The pump coast down time in case of loss of power supply for 1 out of 4 MCP is 55 s, and for 4 out of 4 MCP – 210 s.

The pressuriser is shown on Figures 3.1.2.6 and 3.1.2.7. The interface between the water and the steam in the pressuriser reduces the risk from water hammer and provides a compressible steam (gas) space, which is used to set the absolute pressure of the reactor vessel. The bottom of the volume is connected to one of the hot legs by the surge line while the top of the pressuriser has sprays with piping connected to a cold leg and the make-up system. This configuration for the spray injection inherently allows the high pressure in the cold leg to inject into the pressuriser, but other systems are available to inject water to condense and reduce the steam in the system. The pressuriser has four groups of heaters, which have the following power: group #1 – 360 kW; group #2 – 180 kW; group #3 – 720 kW and group #4 – 1 260 kW.

Coolant inventory in primary side is regulated by Make-up and Let-down systems. The Make-up system delivers coolant to the cold legs of primary loops #1, 2, 3 and 4. The nominal flow rate to the four loops is 8.19 kg/s at a pressuriser water level 8.77 m, the maximum flow rate to the four loops is 22.136 kg/s. The Let-down system is connected to the cold legs of primary loops #2 and 3. The nominal flow rate is 8.19 kg/s at Pressuriser water level 8.77 m, the maximum flow rate is 22.136 kg/s.

### ***3.1.3 Steam generator***

This section contains information about the horizontal U-tube natural circulation type steam generator (Figures 3.1.3.1 and 3.1.3.2). Table 3.1.3.1 gives the design data, Table 3.1.3.2 gives nominal characteristics, and Table 3.1.3.3 provides the geometry description.

The main components of the system are:

- Steam generator (SG) vessel.
- Heat transfer tubes and primary coolant heads.
- Seedwater nozzle facility.
- Emergency feedwater nozzle facility.
- A perforated plate.
- Moisture separator.

Tube bundle configuration is provided in Tables 3.1.3.4. and 3.1.3.5.

### *3.1.3.1. Feedwater system*

Feedwater flows into the steam generator through a pipe Ø426x24 mm, then through 16 collectors of 80 mm inside diameter which couple to the distribution pipes. Each of these distribution pipes has 38 perforated pipes. Some are at the upper steam tubing elevation while another portion is over the perforated sheet in order to balance the non-uniform steam generation. This is achieved by partial condensation of the voids in high steam areas.

## **3.2 Definition of the core thermal-hydraulic boundary conditions model**

The full KNPP Unit 6 thermal-hydraulic (T-H) model can be converted to a core T-H boundary condition model by defining an inlet condition at the vessel bottom and an outlet condition at the vessel top. The boundary conditions (BC) for this model are provided on the CD-ROM under the directory **3D-BC**. The BC are calculated using the TRAC-PF1/NEM best-estimate core plant system code. Radial distributions are provided for 18 T-H cells (from 1 to 18) as shown in Figure 3.2.1. These 18 T-H cells are coupled to the neutronic core model in the radial plane as shown in Figure 3.2.1. This mapping scheme follows the spatial mesh overlays developed for the KNPP Unit 6 TRAC-PF1/NEM model.

The KNPP Unit 6 TRAC-PF1 model is a 3-D vessel model in cylindrical geometry. A majority of the existing coupled codes model the core thermal-hydraulically using parallel channel models, which leads to difficulties in the interpretation of the mass flow BC generated with TRAC-PF1/NEM. In order to avoid this source of modelling uncertainty, BC have been generated where mass flows are corrected for direct use as input data in the multi-channel core models. A geometrical interpolation method is used to process the TRAC-PF1/NEM BC in order to obtain inlet conditions for each assembly. The detailed mapping scheme (see Figure 3.2.1) shows how the provided 18 BC values are distributed per assembly.

There are several files of data, available on the CD-ROM, which are used for definition of the core T-H boundary condition model (Exercise #2). This data is taken from the best-estimate core plant system code calculations performed with the PSU version of TRAC-PF1/NEM:

### A. File TEMP.BC

The transient inlet radial distribution of liquid temperatures from 0 s to 129 s during the transient. The values are extracted from the TRAC vessel axial layer #3 which is mapped to the bottom reflector of the core neutronics model. For each time interval the first number is the time, followed by 18 numbers corresponding to the liquid temperatures (°K) in the 18 azimuthal sectors that make up the core region.

### B. File MASS\_FLOW.BC

The same as above for the inlet radial distribution of axial mass flows (kg/s).

### C. File Press\_Inlet.BC

The same as above for the inlet radial distribution of pressure (Pa).

#### D. File Press\_Outlet.BC

The same as above for the outlet radial distribution of pressure (Pa). The values in the file Press\_Outlet.BC are extracted from the TRAC vessel axial layer #14, which is mapped to the top reflector.

The average pressure drop between the third and fourteenth layers (i.e. across the core) at time=0 s is about 0.106 MPa. In the TRAC nodalisation the lower plenum is represented with the first, second and third layers. The upper plenum is represented with the fourteenth and eighteenth layers.

In addition a file, Cold Temp.BC, is provided. The file contains cold leg temperatures for the four loops as a function of time.

### 3.3 Thermal-physical and heat-transfer specifications

The Doppler temperature,  $T_f$ , is found from the fuel temperature at the fuel rod centre  $T_{f,c}$  and the fuel rod surface  $T_{f,s}$  via the relation:

$$T_f = (1 - \alpha)T_{f,c} + \alpha T_{f,s}$$

where  $\alpha=0.7$ .

The UO<sub>2</sub> density is 10.6 g/cm<sup>3</sup> (95% of the theoretical density) at a temperature of 293.15°K. The pellet dishing amounts to 1.956%. The cladding material is Zr+1% Nb with a density of 6.55 g/cm<sup>3</sup>.

Participants should use Tables 3.3.1 through 3.3.3 for the heat conductivity  $\lambda$  (W/m°K) and specific heat capacity  $c_p$  (J/kg°K) of fuel, cladding and gap. The pressure of He in fuel rod gas gap is 2.0±0.25 MPa at the BOL.

In Tables 3.3.4 through 3.3.7 are shown the properties of different steel types.

Expansion effects of fuel and cladding will not be considered in this benchmark.

The heat transfer coefficient between cladding and moderator has to be calculated using code specific correlations.

**Table 3.1.1.1. Reactor vessel design data**

<b>Item</b>	<b>Data</b>
Average coolant temperature (°K)	576.15
Overall height of reactor vessel (m)	10.897
Total volume of the vessel (m <sup>3</sup> )	110
Inlet nozzle ID (mm)	850
Outlet nozzle ID (mm)	850
Coolant operating temperature – inlet (°K)	560.15
Coolant operating temperature – outlet (°K)	592.05
Reactor coolant flow (kg/s)	17 611
Height of active fuel region (mm)	3 550
Outer diameter of reactor pressure vessel D <sub>1</sub> (mm)	4 535
Inner diameter of reactor pressure vessel D <sub>2</sub> (mm)	4 136
Outer diameter of reactor shaft D <sub>3</sub> (mm)	3 620
Height of elliptical bottom, (mm)	967
Wall thickness of elliptical bottom, (mm)	237 <sup>+0 -22</sup>
Wall thickness of cylindrical part, (mm)	192
Inside coating of elliptical bottom, (mm)	7.0 <sup>+2 -1</sup>
Inside coating of cylindrical part, (mm)	7.0
Total height (inside) of vessel and reactor cover, (mm)	12 433
Elevation above inside bottom of reactor vessel, (mm)	
• inlet nozzles axis	6 973
• outlet nozzles axis	8 773
• bottom of heated part of core	1 823

**Table 3.1.1.2. Reactor vessel volume data**

<b>Description</b>	<b>Value</b>
Lower plenum (m <sup>3</sup> )	16.0
Core (m <sup>3</sup> )	14.8
Down comer (m <sup>3</sup> )	18.0
Upper plenum (m <sup>3</sup> )	61.2

**Table 3.1.1.3. Description of vessel plates**

<b>Item</b>	<b>Data</b>
Lower core support plate	
• thickness, (mm)	100
• elevation from bottom of reactor vessel to top of plate, (mm)	1 633
Upper core support plate	
• elevation from bottom of reactor vessel, (mm)	6 103
• thickness, (mm)	265
Perforation of upper core support plate	
• holes for fuel assemblies top head	163
• holes for coolant	186 x $\phi$ 122 mm
• holes for in-core measurements	72 x $\phi$ 108 mm 12 x $\phi$ 92 mm
Plate at the top of the block of control rod guide tubes (CRGT)	
• elevation from bottom of reactor vessel, (mm)	9 925
• thickness, (mm)	200
Perforation of plate at the top of CRGT	
• holes for control rod guide tubes	61 x $\phi$ 185 mm
• holes for in-core measurements	72 x $\phi$ 115 mm
• holes for coolant	42 x $\phi$ 100 mm 90 x $\phi$ 90 mm
• holes for temperature measurements on the periphery	30 x $\phi$ 22 mm
Plate between cylindrical and elliptical part of upper head	
• elevation from bottom of reactor vessel, (mm)	10 660
• thickness, (mm)	90
• diameter of plate, (mm)	3 240
• OD of annulus, (mm)	3 280
• gap, (mm)	20
Perforation of plate	
• for tubes penetration	61 x $\phi$ 63 mm
• holes for coolant	36 x $\phi$ 200 mm 6 x $\phi$ 145 mm

**Table 3.1.1.4. Description of control rod guide tubes above the core**

<b>Parameter</b>	<b>Value</b>
Number of tubes	61
Shape	cylindrical
OD, (mm)	180
ID, (mm)	166
Total length between the plates, (mm)	3 557

**Table 3.1.1.5. Description of reactor cover**

Parameter	Value
Reactor cover heights, (mm)	
• total (incl. wall)	2 062
• upper elliptical part	1 085
• to the end of nozzle for control rods	2 710
Reactor cover inside diameter, (mm)	3 396
Reactor cover outside diameter, (mm)	4 580
Reactor cover inside coating of elliptical part, (mm)	9
Perforation of elliptical head:	
• CRGT nozzles:	61
– nozzles for penetration of temperature measurements	14
– nozzles for penetration of neutron flux measurements	16
– nozzle of air evacuation line	1

**Table 3.1.1.6. Description of core barrel**

Parameter	Value
Core barrel elliptical bottom	
• elevation from bottom of reactor vessel, (mm)	106
• thickness, (mm)	120
Perforation of core barrel elliptical bottom	
• number of holes	1 344
• diameter of holes, (mm)	40
Perforation of core barrel above the core	
• number of rows	6
• elevation of row # 3 from bottom of reactor vessel, (hot leg axis), (mm)	8 773
• distance between axes of rows, (mm)	250
• number of holes in row 3 (38 for coolant and 2 for hydro accumulators)	38 x $\phi$ 180 mm 2 x $\phi$ 300 mm
• number of holes in other rows	40 x $\phi$ 180 mm

**Table 3.1.1.7. Description of basket**

Parameter	Value
Total height, (mm)	4 070
OD, (mm)	3 485
Bottom elevation above inside bottom of reactor vessel, (mm)	1 533

**Table 3.1.2.1. Reactor coolant system nominal steady-state parameters**

<b>Parameter</b>	<b>Value</b>
Total core power output (MWt)	3 000
Reactor inlet pressure drop (MPa)	0.201
Core pressure drop (MPa)	0.142
Block of shielding tubes region pressure drop (MPa)	0.029
Reactor exit pressure drop (MPa)	0.037
Reactor without inlet/outlet nozzles pressure drop (MPa)	0.392

**Table 3.1.2.2. Primary system component elevations**

<b>Component</b>	<b>Elevation (m)</b>
Reactor outlet piping	▽25.70
Reactor inlet piping	▽23.90
Reactor vessel lower head	▽16.69
Pressuriser lower head	▽22.03

**Table 3.1.2.3. Reactor coolant system piping design data**

<b>Parameter</b>	<b>Value</b>
Reactor inlet piping	Pipe, ID (mm)
	Minimum thickness (mm)
	Coolant volume (hot-system total) (m <sup>3</sup> )
Reactor outlet piping	850
	140
	60.28
Pressuriser surge piping	850
	140
	22.96
Pressuriser surge piping	Pipe size (m)
	Pipe ID (m)
	Pipe OD (m)
	Coolant volume, hot (m <sup>3</sup> )

**Table 3.1.2.4. Flow areas**

<b>Component</b>	<b>Location</b>	<b>Flow area (m<sup>2</sup>)</b>
Hot leg		0.567
Cold leg		0.567
Steam generator	RC inlet nozzle	0.546
Reactor vessel	RC outlet nozzle	2.268 (4 loops)

**Table 3.1.2.5. Reactor coolant system volume data**

Description	Value
Pressuriser (at 8.77 m nominal water level)	
Water volume (m <sup>3</sup> )	55.00
Steam volume (m <sup>3</sup> )	24.00
Cold leg – each (m <sup>3</sup> )	15.07
Hot leg – each (m <sup>3</sup> )	5.74
Reactor coolant pumps (m <sup>3</sup> )	3.00
Surge line (m <sup>3</sup> )	1.69

**Table 3.1.2.6. Pressuriser description**

Description	Value
Nominal pressure (kgf/cm <sup>2</sup> )	160
Internal diameter (m)	3
Outer diameter (m)	3.3
Full height (m)	12.7
Heater elevation (m)	0.257
Liquid volume change in case of level deviation of 0.1m (m <sup>3</sup> )	0.707
Spray line length (m)	38
Spray line OD (mm)	219
Spray line ID (mm)	181
Pressuriser bottom elevation (m)	22.03
Single relief valve steam flow (kg/s)	50
Constant flow through relief valves (l/hr)	50
Time for open/close the pressurise relief valves (PRV) (s)	1
PRV line ID (mm)	200

**Table 3.1.2.7. Reactor coolant system flow data**

Description	Value
Total reactor flow (kg/s)	17 611
Average flow path lengths (m)	
Hot leg	10.12
Cold leg	26.60
Steam generator	11.10
Reactor coolant pumps	
Actual pump capacity	
4 pumps in operation (m <sup>3</sup> /s/pump)	5.889
3 pumps in operation (m <sup>3</sup> /s/pump)	6.764
2 pumps in operation (m <sup>3</sup> /s/pump)	7.333
1 pumps in operation (m <sup>3</sup> /s/pump)	7.500

**Table 3.1.2.8. Safety valve data**

Description	Value
Pressuriser safety valves (3 valves)	
Pressure set point (MPa)	17.7
	18.6
	18.6
Capacity (kg/sec) total	50.0

**Table 3.1.2.9. Main coolant pump description**

Description	Value
Coolant volume, (m <sup>3</sup> )	3.0
Nominal flow at 50 Hz, (m <sup>3</sup> /s)	5.9
Nominal flow at 49 Hz, (m <sup>3</sup> /s)	5.555
Nominal speed of the rotor, (Rad/s)	104.2
Rated torque, (NM)	47 500

**Table 3.1.3.1. Steam generator design data**

Item	Data per steam generator
Steam conditions at full load, outlet nozzles	
Steam flow (kg/s)	437.0
Steam temperature (°C)	278.5
Steam pressure (MPa)	6.28±0.2
Feedwater temperature (°C)	220±5 (with PVN)
Reactor coolant side	
Operating pressure (MPa)	15.7±0.3
Operating temperature (°K)	
Outlet	559.15±2.0
Inlet	593.15±3.5
Coolant volume – hot (m <sup>3</sup> )	20.5 – primary side volume

**Table 3.1.3.2. Steam generator nominal characteristics**

Description	Value
Pressure drop between steam collector and turbo-generator (Pa)	$1 \times 10^5$
Pressure drop between SG and steam collector (Pa)	$2 \times 10^5$
Feedwater temperature with HP pre-heaters on ( $^{\circ}$ K)	$493.15 \pm 5$
Feedwater temperature with HP pre-heaters off ( $^{\circ}$ K)	$437.15 \pm 4$
Thermal power (MW)	750 <sup>+33</sup>
Steam load (MPa)	437.22 <sup>+2.843</sup>
Live steam pressure (MPa)	$6.28 \pm 0.2$
Live steam temperature ( $^{\circ}$ K)	551.65
SG primary side pressure drop (MPa)	0.133
SG secondary side pressure drop (MPa)	0.1
Steam quality at steam generator outlet (%)	<0.2
Nominal secondary side level (m)	2.55

**Table 3.1.3.3. Steam generator geometry description**

Description	Value
Steam lines volume from SG to the steam collector ( $m^3$ )	100
Steam lines volume from the steam collector to the turbo-generator ( $m^3$ )	62
Upper level of the tubing (m)	2.19
Length of a cylindrical part of the SG (m)	11.34
SG ID (m)	4
SG OD (m)	4.29
Upper level of perforated plate (m)	2.45
Number of primary side heads	2
Volume of one SG head ( $m^3$ )	2.4
Total height of a head (m)	4
Primary side volume ( $m^3$ )	20.5
Number of heat transfer tubes	11 000
Average length of the tubes (m)	11.1
Heat transfer tube OD (mm)	16
Heat transfer tube ID (mm)	13
Total cross-section area of heat transfer tubes ( $m^2$ )	1.46
Total heat transfer area (secondary side) ( $m^2$ )	6 115
Relative elevation of FW nozzle (m)	2.72
Equivalent hydraulic diameter (secondary side) (mm)	17.4
Distance between axes of rows (mm)	19
Distance between tubes axes in a row (mm)	23

**Table 3.1.3.4. Tube bundle data**

No. of row	Tubes of row	Axis height	No. of tubes total	No. of row	Tubes in row	Axis height	No. of tubes total	No. of row	Tubes of row	Axis height	No. of tubes total
1	16	119	16	41	102	879	2 920	81	118	1 639	7 548
2	26	138	42	42	102	898	3 024	82	120	1 658	7 668
3	32	157	74	43	104	917	3 128	83	118	1 677	7 786
4	40	176	114	44	106	936	3 234	84	120	1 696	7 906
5	44	195	158	45	106	955	3 340	85	118	1 715	8 024
6	50	214	208	46	108	974	3 448	86	120	1 734	8 144
7	54	233	262	47	108	993	3 556	87	118	1 753	8 262
8	58	252	320	48	110	1 012	3 666	88	120	1 772	8 382
9	60	271	380	49	110	1 031	3 776	89	118	1 791	8 500
10	60	290	440	50	112	1 050	3 888	90	120	1 810	8 620
11	60	309	500	51	112	1 069	4 000	91	118	1 829	8 738
12	60	328	560	52	114	1 088	4 114	92	120	1 848	8 858
13	60	347	620	53	114	1 107	4 228	93	118	1 867	8 976
14	60	366	680	54	116	1 126	4 344	94	120	1 886	9 096
15	60	385	740	55	116	1 145	4 460	95	118	1 905	9 214
16	60	404	800	56	118	1 164	4 582	96	120	1 924	9 334
17	60	423	860	57	116	1 183	4 794	97	118	1 943	9 452
18	60	442	920	58	118	1 202	4 812	98	120	1 962	9 572
19	60	461	980	59	118	1 221	4 930	99	118	1 981	9 690
20	60	480	1 040	60	120	1 240	5 050	100	120	2 000	9 810
21	60	499	1 100	61	118	1 259	5 168	101	118	2 019	9 928
22	60	518	1 160	62	120	1 278	5 288	102	120	2 038	10 048
23	76	537	1 236	63	118	1 292	5 406	103	118	2 057	10 166
24	84	556	1 320	64	120	1 316	5 526	104	120	2 076	10 286
25	84	575	1 404	65	118	1 335	5 644	105	118	2 095	10 404
26	86	594	1 490	66	120	1 354	5 764	106	120	2 114	10 524
27	86	613	1 576	67	118	1 373	5 882	107	118	2 133	10 642
28	90	632	1 666	68	120	1 392	6 002	108	120	2 152	10 762
29	90	651	1 756	69	118	1 411	6 120	109	118	2 171	10 880
30	92	670	1 848	70	120	1 430	6 240	110	120	2 190	11 000
31	92	689	1 940	71	118	1 449	6 358				
32	94	708	2 034	72	120	1 468	6 478				
33	94	727	2 128	73	118	1 487	6 596				
34	96	746	2 224	74	120	1 506	6 716				
35	96	765	2 320	75	118	1 525	6 834				
36	98	784	2 418	76	120	1 544	6 954				
37	98	803	2 516	77	118	1 563	7 072				
38	100	822	2 616	78	120	1 582	7 192				
39	100	841	2 716	79	118	1 601	7 310				
40	102	860	2 818	80	120	1 620	7 430				

**Table 3.1.3.5. SG secondary side data**

Elevation, m	HT area, m <sup>2</sup>	Sec. vol, m <sup>3</sup>
0.0	0.00	0.53
0.2	10.23	2.18
0.4	446.00	5.90
0.6	877.00	10.76
0.8	1 385.00	15.80
1.0	1 673.00	18.50
1.2	2 627.00	28.00
1.4	3 342.50	34.40
1.6	4 057.50	42.00
1.8	4 772.50	47.80
2.0	5 487.50	55.16
2.19	6 115.00	62.80
2.50	6 115.00	77.63
2.60	6 115.00	82.50
3.00	6 115.00	100.50
3.50	6 115.00	119.90
4.00	6 115.00	127.00

**Table 3.3.1. Properties of fuel [11, 13, 14, 18]**

Parameter	Value						
T, °K	300	500	700	900	1 100	1 300	1 500
λ, W/m°K	8.15	6.7	5.4	4.4	3.75	3.25	2.80
c <sub>p</sub> , J/kg°K	270	287	302	310	314	319	320
ρ, kg/m <sup>3</sup>	10 400 ÷ 10 800						
c <sub>v</sub> , kJ/m <sup>3</sup> °K	2 862.0	3 042.2	3 201.2	3 286	3 328.4	3 381.4	3 392

Parameter	Value						
T, °K	1 700	1 900	2 100	2 300	2 500	2 700	2 900
λ, W/m°K	2.50	2.40	2.42	2.44	2.5	2.65	3.0
c <sub>p</sub> , J/kg°K	328	340	364	390	426	470	520
ρ, kg/m <sup>3</sup>	10 400 ÷ 10 800						
c <sub>v</sub> , kJ/m <sup>3</sup> °K	3 476.8	3 604	3 858.4	4 134	4 515.6	4 982	5 512

**Table 3.3.2. Properties of cladding [18]**

Parameter	Value								
t, °C	20	100	200	300	400	500	600	700	800
T, °K	293.15	373.15	473.15	573.15	673.15	773.15	873.15	973.15	1 073.15
λ, W/m°K	17.2	18.0	19.3	20.1	20.5	20.9	21.8	22.9	
c <sub>p</sub> , J/kg°K		280	301	322	343	368	398	448	420
c <sub>v</sub> , kJ/m <sup>3</sup> °K		1 834	1 972	2 109.1	2 246.7	2 410.4	2 606.9	2 934.4	2 751

Parameter	Value						
t, °C	900	1 000	1 100	1 200	1 300	1 400	1 500
T, °K	1 173.15	1 273.15	1 373.15	1 473.15	1 573.15	1 673.15	1 773.15
λ, W/m°K		27.8	29.0	30.1	31.2	32.3	33.4
c <sub>p</sub> , J/kg°K	380	290					
c <sub>v</sub> , kJ/m <sup>3</sup> °K	2 489	1 899.5					

**Table 3.3.3. Properties of fuel rod gap [11, 14, 15]**

Parameter	Value						
T, °K	273.15	373.15	473.15	573.15	673.15	873.15	1 073.15
λ, W/(m °K)	0.145	0.181	0.214	0.246	0.279	0.334	0.387
c <sub>p</sub> , J/(kg °K)				5 193.0			
ρ, kg/m <sup>3</sup>	3.50	2.59	2.04	1.69	1.44	1.11	0.90
c <sub>v</sub> *10 <sup>-3</sup> , J/(m <sup>3</sup> °K)	18.176	13.450	10.594	8.776	7.478	5.764	4.674

**Table 3.3.4. Properties of steel 15XHMΦA [18]**

Properties	Value			
t, °C	100	200	300	400
T, °K	373	473	573	673
λ	26.4	27.0	29.0	30.0
c <sub>p</sub>	495	520	545	575
ρ		7 860 (at 20°C)		
c <sub>v</sub>	3 890.7	4 087.2	4 283.7	4 519.5

**Table 3.3.5. Properties of steel 08X18H10T [12, 16, 17]**

T, °K	λ[W/m°K]	c <sub>p</sub> , J/(kg°K)	ρ, kg/m <sup>3</sup>	c <sub>v</sub> *10 <sup>-3</sup> , J/(m <sup>3</sup> °K)
293.15	15.07	461	7 900	3 641.9
373.15	16.33	494	7 860	3 882.8
473.15	17.58	515	7 820	4 027.3
573.15	18.84	536	7 780	4 170.1
673.15	21.35	548	7 740	4 241.5


**Table 3.3.6. Properties of steel 12Х18Н10Т [12, 13]**

T, °K	$\lambda$ [W/m°K]	$c_p$ , J/(kg°K)	$\rho$ , kg/m <sup>3</sup>	$c_v \cdot 10^{-3}$ , J/(m <sup>3</sup> °K)
293.15	15.0	462	7 900	3 649.8
373.15	16.0	496	7 860	3 898.6
473.15	18.0	517	7 820	4 042.9
573.15	19.0	538	7 780	4 185.6
673.15	21.0	550	7 740	4 257.0
773.15	23.0	563	7 690	4 329.5
873.15	25.0	575	7 650	4 398.8


**Table 3.3.7. Properties of steel 10ГН2МФА [18]**

T, °K	$\lambda$ [W/m°K]	$\rho$ , kg/m <sup>3</sup>	$c_v \cdot 10^{-3}$ , J/(m <sup>3</sup> °K)
293.15	32.70	7 860	3 594.8
373.15	35.16		3 880.0
473.15	38.28		4 236.6
573.15	41.40		4 593.1
623.15	42.96	7 778	4 771.4
673.15	44.52		4 949.7
773.15	47.64		5 306.2
873.15	50.76		5 662.8


**Figure 3.1.1.1. Reactor**




### **Figure 3.1.1.2. Reactor vessel**



**Figure 3.1.1.3. Core barrel**




**Figure 3.1.1.4. Reactor cover**




1. Truncated ellipsoid
2. Cover flange
3. Anti-corrosion cladding
4. Circle sector
5. Control rod drive flange (or TC-, or NIS flange)
6. Gaz – removal nozzle flange

**Figure 3.1.1.5. Core basket**



**Figure 3.1.1.6. Reactor shielding tubes block**




on Figure 3.1.1.7.

- |                            |                         |
|----------------------------|-------------------------|
| 1. Upper plate             | 9. NIS assembly channel |
| 2. Templates assembly tube | 10. Tight frames        |
| 3. Support ring            | 11. Plates              |
| 4. Cotter                  | 12. Upper plate         |
| 5. Middle plate            | 13. ICIS tubes          |
| 6. Perforated frame        | 14. TC bundle           |
| 7. Shielding tube          | 15. NIS bundle          |
| 8. Lower support plate     |                         |


**Figure 3.1.1.7. Shielding tube**

A – A from Figure 3.1.1.6.




1. Shielding tube
2. Sealing tube for sensors
3. Metal guide structure
4. Lower support plate

**Figure 3.1.1.8. Fuel assembly**




1. Cotter
2. Head
3. Guide channel
4. Spacer grid
5. Fuel rod
6. Lower plate
7. Bottom
8. Fixing bolt


**Figure 3.1.1.9. Control rod cluster**




**Figure 3.1.2.1. Primary circuit loops – layout**




**Figure 3.1.2.2. Primary circuit layout 1**




**Figure 3.1.2.3. Primary circuit layout 2**



**Figure 3.1.2.4. Main equipment layout**




**Figure 3.1.2.5. Main coolant pump**




1. Pump body
2. Radiation protection ring
3. Console
4. Lower shroud
5. Torsion shaft
6. Motor
7. Balance wheel
8. Upper shroud
9. Console
10. Moving support

**Figure 3.1.2.6. Pressuriser**




**Figure 3.1.2.7. Pressuriser cross-section**



- 9


  1. Block of tube electroheaters
  2. Expansion vessel
  3. Expansion vessel
  4. Steam outlet to pressuriser relief valve
  5. Leakage output nozzle
  6. Vent
  7. Thermocouple casing
  8. Cold coolant inlet
  9. Vessel
  10. Thermocouple casing

**Figure 3.1.3.1. Steam generator**




- |                              |                                   |
|------------------------------|-----------------------------------|
| 1. Vessel                    | 7. Gas removal nozzle             |
| 2. Drainage nozzle           | 8. Emergency feedwater spray unit |
| 3. Blow down nozzle          | 9. Steam nozzle                   |
| 4. Heat-exchange tubes       | 10. Steam header                  |
| 5. Separation units          | 11. Emergency feedwater nozzle    |
| 6. Main feedwater spray unit | 12. Access airlock                |

**Figure 3.1.3.2. Steam generator cross-section**



- |  |                                |
|--|--------------------------------|
| 1. Steam header                        | 7. MCC nozzles                 |
| 2. Secondary circuit (SC) header cover | 8. Heat exchange tubes         |
| 3. Nuts                                | 9. Steam pressure equalization |
| 4. Primary circuit (PC) header cover   | 10. Feedwater nozzle           |
| 5. SC header                           | 11. Separation units           |
| 6. PC header                           | 12. Steam nozzle               |

**Figure 3.2.1. Transient core boundary conditions mapping scheme for the second exercise**





## *Chapter 4*

### **NEUTRONIC/THERMAL-HYDRAULIC COUPLING**

The feedback, or coupling, between neutronics and thermal-hydraulics (T-H) can be characterised by choosing user supplied mapping schemes (spatial mesh overlays) in the radial and axial core planes.

Some of the inlet perturbations (inlet disturbances of both temperature and flow rate) are specified as a fraction of the position across the core inlet. This requires either three-dimensional (3-D) modelling of the vessel or some type of a multi-channel model.

For the purposes of this benchmark (Exercises 2 and 3), it is recommended that an assembly flow area of 256 cm<sup>2</sup> be used in the core T-H multi-channel models.



## *Chapter 5*

### **VVER-1000 MCP SWITCHING ON PROBLEM**

#### **5.1 Description of MCP switching on scenario**

During the plant-commissioning phase at the Kozloduy NPP – Unit #6 a number of experiments were performed. One of them is the investigation of the behaviour of the nuclear power reactor parameters in case of switching on one main coolant pump (MCP) when the other three main coolant pumps are in operation [2]. This investigation was performed jointly by the Bulgarian and Russian specialists on the stage when the reactor power was at 75% of the nominal level. The purpose of the experiment was the complete testing of reliability of all power plant equipment, testing the reliability of the main regulators (Power Reactor Controller, Electro-hydraulic Turbine Controller and the regulator of the level in the steam generator) and defining the jump of the neutron reactor power in case of switching on of one main coolant pump.

Before the experiment the reactor power level was reduced from 75% (2250 MW) to approximately 21% by consecutive switching off of MCP#2 and MCP#3. A few hours before the experiment MCP #2 was switched on, and the power was stabilised at 30% following the Technical specification requirements. According to the Technical specification for safety operation of the Units 5 and 6, switching on one main coolant pump in operation is performed when the reactor power is at 30% of the nominal level.

The Reactor Power Controller (RPC) is a part of the Unit Power Control System and operates in co-ordination with the Reactor Power Limitation Controller (RPLC) and the Electro-hydraulic Turbine Controller (EHTC). The controller stabilises the reactor power or makes it to follow the turbine power. The RPC does not set any setpoint specification devices and stores the current values of neutron power or main steam header pressure as a setpoint at the time of switching on. In order to reset a setpoint, switching off and then switching on to the appropriate mode is needed. The controller usually uses the control rod group #10 to operate. In this particular transient the control rod group #10 is not changing its position during the transient.

RPLC is used to constrain the maximum thermal and neutron power to setpoints automatically chosen depending on the operational status of certain plant components such as MCP, Feed Water Pump (FWP), Steam Generator (SG), and Turbo Generator (TG). RPLC inserts the control rod group #10 with normal operation speed of 2 cm/sec. Control signal is the neutron flux, measured by the neutron flux monitoring system (NFMS). This signal is corrected once in every 50 seconds using the thermal power evaluated on the basis of the average temperature rise in the operating loops.

When RPLC is in operation, RPC is automatically disconnected and WP-1 (warning protection) signals are not used.

Depending on the initiating event, the reactor power is lowered to and then kept at specified setpoints by RPLC as follows:

- 1) 1 out of 4 MCPs trip; to 67% N<sub>n</sub>.
- 2) 2 out of 4 diametrically placed MCPs trip; to 50% N<sub>n</sub>.
- 3) 2 out of 4 (neighbouring) MCPs trip; to 40% N<sub>n</sub>.

During the experiment of switching on the MCP #3 the system and equipment of the Unit 6 performed according to design requirements for the corresponding level of the reactor power. Registrations of the parameters when there is a transient event are recorded by the design equipment, which includes the universal electronic system (UES), and NFMS (in-core reactor control system).

The initial power level is about 29.45% of the nominal with control rod group #10 inserted into the core at about 36% of the reactor core height. Control rod group #10 is not changing its position during the transient. Analysis of the initial 3-D relative power distribution showed that this insertion introduced axial neutronics asymmetry in the core. At the beginning of the transient there is also a thermal-hydraulic asymmetry coming from the colder water introduced in ¼ of the core when MCP #3 is switched on. This causes a spatial asymmetry in the reactivity feedback, which has been propagated through the transient and combined with insertion of positive reactivity.

Different code predictions will be compared and evaluated in regard to time and value of a power peak after the switching on MCP #3.

## 5.2 Initial steady-state conditions

The reactor is at the beginning of cycle (BOC) with average core exposure of 30.7 EFPD and boron concentration 5.95 g/kgH<sub>2</sub>O. At the beginning of the experiment there are three pumps in operation – 1<sup>st</sup>, 2<sup>nd</sup> and 4<sup>th</sup> main coolant pumps and the reactor power is at 29.45% of nominal power level according to the equipment that controls neutron flux. MCP #1, #2 and #4 are working under stable conditions and MCP #3 is out of operation. Initial conditions are given in Table 5.2.1. The inlet temperature in the reactor core is about 555.00°K. The temperature differences between the hot and cold legs for the loop with working MCP vary between 8.3-11.5°K while the same temperature difference for the loop #3 with the MCP out of operation is -3.6°K. The total mass flow through the core is about 13 611 kg/s with an average flow of 5 000 kg/s through each of the working loops and negative (reverse) flow of -1 544 kg/s in loop #3. There is a core axial non-symmetry as it can be seen from the value of the axial offset of the core power distribution at the initial state – 28.5%. The Electro-hydraulic Regulative System supports the pressure in the main steam collector when the Turbine Generator works at 164.0±10 MW. All regulators are in automatic regime. Definition of the initial steady state is given in Table 5.2.2. The above described initial conditions of the transient are referred as Hot Power (HP) conditions. Additional Hot Zero Power (HZP) state is defined for initialization of the 3-D core neutronics model for the second exercise. The HZP conditions are defined as follows: the power level is 0.1% of the nominal power; the fuel temperature is 552.15°K and the moderator density is 767.1 kg/m<sup>3</sup>.

### **5.3 Point kinetics model inputs**

Point kinetics model inputs, which preserve axial and radial core power distributions obtained with 3-D neutronics model, must be specified in order to make both simulations compatible. The following parameters for the point kinetics model and the 3-D neutronic transient core model should be consistent:

- Control rod group #10 worth.
- Radial power distribution.
- Axial power distribution.
- Moderator temperature coefficient.
- Doppler temperature coefficient.
- Other kinetics parameters.

All other initial and boundary conditions also have to be identical between the two cases. A summary of the point kinetics analysis input values can be found in Table 5.3.1. HP radial and axial relative power distributions (based on 10 equal nodes of 35.5 cm axial height) are shown in Figures 5.3.1 and 5.3.2, respectively.

### **5.4 Transient calculations**

The key assumptions for performing the point and 3-D kinetics MCP transient analyses are summarised in Table 5.4.1.

The transient test scenario is as follows:

- 1) At reactor power 29.45%  $N_{\text{nom}}$  MCP#3 is switched on.
- 2) After switching on of MCP#3 the reactor power gradually increases to 29.8%  $N_{\text{nom}}$ .
- 3) Pressuriser water level decreases from 744 cm to 728 cm.
- 4) Water level in the steam generator #3 decreases by 9 cm.
- 5) EHTC is supporting the pressure in MSH at level  $6.0 \pm 0.05$  MPa when the TG power is  $164.0 \pm 10$  MW.
- 6) The flow rate in loop #3 reverses back to normal at the 13<sup>th</sup> second of the switching on of MCP#3. The timing is consistent with reactivity increase, as observed through the reactor power setpoints.

During the transient as a result of the switching on of MCP #3 there is an increased mass flow through the core. The cooling of the core is improved and re-distributed while the thermal core power level increase slightly (the total power increase during the transient is between 29.45% and 29.8% of

nominal level). The non-symmetric cooling of the reactor core results in non-symmetric reactivity feedback and subsequently non-symmetric radial power distribution.

At the end of the transient the temperature difference between hot and cold legs of loops #1, #2, and #4 slightly decreases:

- For loop #1 – from 11.5°K to 8.8°K.
- For loop #2 – from 8.3°K to 8.4°K.
- For loop #4 – from 10.9°K to 8.9°K.
- For loop #3 – from -3.6°K to 8.2°K.

The most noticeable change is in the temperature difference for loop #3. This results in a dynamically changing spatial distribution of reactivity feedback during the transient and subsequently in a dynamically changing spatial power distribution. MCP test plant data is shown in Appendix C.

Since the objective of this benchmark is not to examine pump model of different codes, boundary conditions of MCP #3 rotor speed are provided in Table 5.4.2.

Transient boundary conditions for feedwater flow and secondary side pressure for each stem generator are provided in Tables 5.4.3 and 5.4.4 respectively. Feedwater temperature during the transient is 437.0°K.

The logic of the pressuriser heaters during the transient is given in Table 5.4.5.

The neutronics and thermal-hydraulic information presented in Chapter 3, suffices for performing Exercises 1, 2, and 3. In addition, an extreme version of Exercise 3 is defined as follows.

The control rod of group #10 located in the sector of the core cooled by MCP 3 is ejected after switching on of the MCP 3. The ejection of the rod begins at 13<sup>th</sup> second of the transient and the velocity of ejection is 17.75 m/sec. The scram is activated upon reaching the high neutron flux setpoint, which is 40% of the nominal value. The scram delay is 0.3 sec. After that all control rod groups except group #5 fall down simultaneously from their initial position. Control rod group #5 does not operate during the scram and fall down with a delay of 4 seconds. The velocity of control rod insertion during the scram is 1.04 m/s. Everything else should remain the same as for Exercise 3.

This extreme scenario will develop very peaked spatial power distribution and nonlinear asymmetric feedback effects. It is designed to test and compare better the predictions of coupled 3-D kinetics/thermal-hydraulic codes.

**Table 5.2.1. Initial conditions for KNPP unit 6 at 883.5 MWt**

<b>Parameter</b>	<b>Value</b>
Core power, MWt	883.50
Primary side pressure, MPa	15.60
RCS first cold leg temperature, °K	555.55
RCS second cold leg temperature, °K	554.55
RCS third cold leg temperature, °K	554.35
RCS fourth cold leg temperature, °K	555.25
RCS first hot leg temperature, °K	567.05
RCS second hot leg temperature, °K	562.85
RCS third hot leg temperature, °K	550.75
RCS fourth hot leg temperature, °K	566.15
Core flow rate, kg/s	13 611
First loop flow rate, kg/s	5 031
Second loop flow rate, kg/s	5 069
Third loop flow rate, kg/s	-1 544
Fourth loop flow rate, kg/s	5 075
Pressuriser level, m	7.44
Water level in SG1, m	2.30
Water level in SG2, m	2.41
Water level in SG3, m	2.49
Water level in SG4, m	2.43
Secondary side pressure, MPa	5.937

**Table 5.2.2. Definition of steady-states**

<b>Number</b>	<b>T-H conditions</b>	<b>Control rod positions</b>
0	HZP	Groups 1-3 ARO <sup>1</sup> Group 4 – 57.3% wd (227 cm) Group 5 ARO Groups 6-10 ARI <sup>2</sup>
1	HP	Groups 1-9 ARO Group 10 – 36% wd

1. ARO – all rods out.

2. ARI – all rods inserted.

**Table 5.3.1. Summary of point kinetics analysis input values**

Parameter	Value
HP MTC, %/ $^{\circ}$ K	-3.1000E-03
HP DTC, %/ $^{\circ}$ K	-1.6610E-03
HP delayed neutron fraction ( $\beta_{\text{eff}}$ )	0.7268E-02
HP prompt neutron lifetime	0.2670E-04
Control rod group #10 worth, %dk/k	0.91
Ejected rod worth, %dk/k	0.15
Tripped rod worth, %dk/k	7.85
Control rod group #5 worth, %dk/k	0.20

**Table 5.4.1. KNPP analysis assumptions**

Parameter	Value
Thermal power loop #1, MWt	278
Thermal power loop #2, MWt	231
Thermal power loop #3, MWt	34
Thermal power loop #4, MWt	280

**Table 5.4.2. MCP#3 rotor speed boundary conditions**

Time, s	MCP#3 Rotor speed, rad/s
0	0
0.5	9.4732
1	19.9464
1.5	31.4196
2	41.8928
4	61.3660
6	73.8392
8	83.3124
10	90.7856
11	94.3567
14	102.3032
15	104.1964
17	104.1964
18-129	104.1964

**Table 5.4.3. Feedwater flow boundary conditions**

Time, s	SG1 FW flow, kg/s	SG2 FW flow, kg/s	SG3 FW flow, kg/s	SG4 FW flow, kg/s
0	155.624	170.7111	13.61540	155.362
4	155.407	158.3780	14.05300	155.239
8	153.289	141.7140	14.22340	154.096
12	164.448	225.1120	4.27314	160.604
16	167.115	204.9680	14.94800	163.023
20	169.039	178.8350	15.78160	164.004
24	168.173	162.8140	19.67410	163.498
28	164.576	150.4810	26.39720	161.854
32	161.860	139.1290	30.98240	160.053
36	158.205	128.5570	49.25790	157.671
40	154.204	125.5240	71.71070	155.385
44	149.555	124.7210	87.59740	153.143
48	145.487	123.5100	98.76420	149.429
52	142.210	124.3690	106.57600	146.329
56	139.657	125.3380	111.81300	143.729
60	137.894	124.5630	115.07000	141.335
64	136.221	123.8120	117.47900	139.125
68	134.795	124.4220	119.37100	137.255
72	133.601	124.6930	120.83300	135.691
76	132.590	124.7900	121.96300	134.357
80	131.723	125.0700	122.81400	133.197
84	130.954	125.0810	123.43000	132.184
88	130.284	125.0770	123.95300	131.321
92	129.699	125.2440	124.31100	130.572
96	129.212	125.3440	124.66200	129.925
100	128.786	125.4090	124.91800	129.371
104	128.419	125.4830	125.12200	128.898
108	128.102	125.5100	125.26800	128.506
112	127.833	125.6180	125.39700	128.163
116	127.617	125.7100	125.48600	127.868
120	127.420	125.7320	125.58100	127.614
124	127.253	125.7510	125.69900	127.411
128	127.111	125.8410	125.77100	127.236
129	127.087	125.8550	125.77600	127.187


**Table 5.4.4. Steam generators pressure boundary conditions**

Time, s	SG1 pressure, Pa	SG2 pressure, Pa	SG3 pressure, Pa	SG4 pressure, Pa
0	6.09141e+06	6.09231e+06	6.05465e+06	6.09254e+06
4	6.09005e+06	6.09068e+06	6.04962e+06	6.09124e+06
8	6.09277e+06	6.09410e+06	6.06253e+06	6.09375e+06
12	6.09989e+06	6.09878e+06	6.09698e+06	6.09993e+06
16	6.08386e+06	6.08218e+06	6.08846e+06	6.08383e+06
20	6.06502e+06	6.06322e+06	6.07210e+06	6.06525e+06
24	6.06749e+06	6.06662e+06	6.07461e+06	6.06771e+06
28	6.07324e+06	6.07323e+06	6.08046e+06	6.07365e+06
32	6.07338e+06	6.07426e+06	6.08057e+06	6.07403e+06
36	6.07351e+06	6.07498e+06	6.08052e+06	6.07419e+06
40	6.07401e+06	6.07565e+06	6.08056e+06	6.07466e+06
44	6.07375e+06	6.07530e+06	6.07930e+06	6.07432e+06
48	6.07364e+06	6.07509e+06	6.07802e+06	6.07417e+06
52	6.07388e+06	6.07516e+06	6.07732e+06	6.07440e+06
56	6.07445e+06	6.07555e+06	6.07716e+06	6.07497e+06
60	6.07482e+06	6.07586e+06	6.07703e+06	6.07537e+06
64	6.07492e+06	6.07591e+06	6.07676e+06	6.07550e+06
68	6.07492e+06	6.07582e+06	6.07649e+06	6.07552e+06
72	6.07495e+06	6.07577e+06	6.07632e+06	6.07557e+06
76	6.07503e+06	6.0758e0+06	6.07626e+06	6.07568e+06
80	6.07513e+06	6.07584e+06	6.07623e+06	6.07579e+06
84	6.07521e+06	6.07588e+06	6.07622e+06	6.07588e+06
88	6.07528e+06	6.07591e+06	6.07621e+06	6.07596e+06
92	6.07533e+06	6.07592e+06	6.07620e+06	6.07602e+06
96	6.07537e+06	6.07594e+06	6.07619e+06	6.07607e+06
100	6.07541e+06	6.07595e+06	6.07618e+06	6.07612e+06
104	6.07544e+06	6.07596e+06	6.07618e+06	6.07616e+06
108	6.07547e+06	6.07597e+06	6.07619e+06	6.07620e+06
112	6.07550e+06	6.07598e+06	6.07620e+06	6.07623e+06
116	6.07553e+06	6.07599e+06	6.07620e+06	6.07626e+06
120	6.07555e+06	6.07600e+06	6.07621e+06	6.07629e+06
124	6.07557e+06	6.07601e+06	6.07621e+06	6.07631e+06
128	6.07559e+06	6.07602e+06	6.07622e+06	6.07633e+06
129	6.07559e+06	6.07602e+06	6.07622e+06	6.07633e+06


**Table 5.4.5. Pressuriser heaters logic**

Heaters group number	Condition	State
1	P<15.60 MPa	On
2	P<15.60 MPa	On
3	P<15.30 MPa	On
4	P<15.30 MPa	On
1	P>15.78 MPa	Off
2	P>15.60 MPa	Off
3	P>15.50 MPa	Off
4	P>15.50 MPa	Off

**Figure 5.3.1. Initial HP radial power distribution**



**Figure 5.3.2. Initial HP core average axial relative power distribution**





## *Chapter 6*

### **OUTPUT REQUESTED**

- The analysis results will be presented in a benchmark analysis report, which will be made available in both hard copy and electronic form.
- Results should be presented on paper *and* diskette (format details are given in Section 6.3).
- All data should be in SI units (kg, m, sec.).
- For time histories, data should be at 0.1-second intervals.
- Graphical comparison of calculated results and test data should be performed.

#### **6.1 Initial steady-state results**

The parameters given in Table 6.1 will be compared for **Exercise 1**.

The following results will be compared for **Exercise 2**:

- For the initial HZP state (state 1), the following parameters will be compared:  $K_{eff}$ , 2-D normalised power (NP) distribution; core averaged axial power distribution; the power peaking factors  $F_{xy}$ ,  $F_z$  and axial offset; scram rod worth (SRW), ejected rod worth (ERW), and control rod group #10 worth (CRW).
- For the initial HP steady-state (state 2), the same information as for the HZP state plus: 2-D maps for inlet coolant temperature, inlet flow rate and outlet coolant temperature, coolant density, mass flow rate and Doppler temperature. The spatial distributions should follow the format of the radial and axial power distributions.

The following results will be compared for the initial HP steady state for **Exercise 3**:

- $K_{eff}$ .
- Radial power distribution – 2-D assembly NP distribution – axially averaged radial power distribution for 163 radial nodes (full core) normalised to core average power (relative radial power distribution).
- Axial power distribution – core average axial shape – radially averaged axial power distribution for 10 axial nodes (each 35.5 cm in length), normalised to core average power (relative axial power distribution).

- Power peaking factors –  $F_{xy}$ ,  $F_z$ , and axial offset.
- Primary system pressure, temperatures and mass flow rates – core inlet and outlet pressure values; core average axial temperature and axial velocity distributions; core inlet radial coolant temperature and flow rate distributions; core outlet radial coolant temperature distributions. The spatial distributions should follow the format of the radial and axial power distributions respectively.

## 6.2 Transient results

### *Exercise 1*

- Sequence of events.
- Transient core average results (time histories): total core power; fission power; RCS pressure – core average, loop 3 (loop 3 is associated with the start up of MCP #3); core average coolant temperature; hot and cold leg coolant temperatures in all four loops (last cell before/after vessel); coolant heat-up temperature in all four loops; pressuriser water level; SG water levels; secondary side pressure; primary side flow rates; reactivity edits; and core average fuel temperature.

### *Exercise 2*

- Snapshots at time of maximum power after switching on MCP #3, and at 129 seconds – the same data as for the HP steady-state except the total and fission power levels will be compared instead of  $K_{eff}$ .
- Time histories (core volume averaged without the reflector region): total power, fission power; coolant density; and Doppler temperature. In addition, the maximum nodal Doppler temperature vs. time will be compared.

### *Exercise 3*

The following results will be compared for both scenarios of Exercise 3 – basic and extreme.

- Sequence of events.
- Transient average results (time histories): RCS pressure – core average, loop 3 (loop 3 is associated with the start up of MCP #3); core average coolant temperature; hot and cold leg coolant temperatures in all four loops (last cell before/after vessel); coolant heat-up temperature in all four loops; pressuriser water level; SG water levels; secondary side pressure; primary side flow rates; and reactivity edits.
- Time histories (core volume averaged without the reflector region): total power; fission power; coolant density; and Doppler temperature. In addition, the maximum nodal Doppler temperature vs. time will be compared.

- Snapshots at time of maximum power after switching on MCP #3 for both basic and extreme scenarios (states 3 and 4), and snapshots at 129 seconds (end of transient) for both scenarios (states 5 and 6) – the same data as for the HP steady-state except the total and fission power levels will be compared instead of  $K_{eff}$ .

### 6.3 Output format

Contents should be typed as close as possible to sample format.

### *Remarks*

- Time histories consist of data pairs (time, value), one per line, starting at 0 seconds, up to 129 seconds. Please provide the units on the first line of each time history.
  - A plot of time histories would be appreciated for a first comparison of the transient results.
  - The plots of calculated results and test results should be compared on the same graph.
  - Radial and axial profiles should be given according to the form shown in Figures 6.3.1 and 6.3.2.
  - Please do not use tabs in the data files.
  - Start each line in column one and end each line with a carriage return <CR>.

### *Output sample*

- A. VVER-1000 Kozloduy NPP BENCHMARK  
KNPPB at Hot Full Power  
RESULTS FROM CODE "XXXXXXX"  
EXERCISE 1: Point kinetics
  - B. STEADY STATE RESULTS
    - B1)  $K_{eff} = 1.0000$
    - B2) Radial power distribution (full core) – start each line in column one, leave a blank space in between each number, and use a total of six spaces per number):

- B3) Axial power distribution – place all data starting in column one, leave a blank in between each number, and use a total of six spaces per number:

0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999

- B4) Scram rod worth: 1.000% dk/k

- Ejected rod worth: 1.000% dk/k.
- Control rod group #10 worth: 1.000% dk/k.

- B5) Calculated steady state conditions compared to those in the test.

Steady state calculation should be compared to the steady state test parameters according to Table 6.1.

**Table 6.1. Steady state conditions. Measured plant parameters and uncertainty measurement ranges**

Parameter	Test	Accuracy	Result	Deviation, %
Core power, MWt	883.50	±60 MW		
Primary side pressure, MPa	15.6	±0.3 MPa		
RCS first cold leg temperature, °K	555.55	±2.0 K		
RCS second cold leg temperature, °K	554.55	±2.0 K		
RCS third cold leg temperature, °K	554.35	±2.0 K		
RCS fourth cold leg temperature, °K	555.25	±2.0 K		
RCS first hot leg temperature, °K	567.05	±2.0 K		
RCS second hot leg temperature, °K	562.85	±2.0 K		
RCS third hot leg temperature, °K	550.75	±2.0 K		
RCS fourth hot leg temperature, °K	566.15	±2.0 K		
Core flow rate, kg/s	13 611	±800.0 kg/s		
First loop flow rate, kg/s	5 031	±200.0 kg/s		
Second loop flow rate, kg/s	5 069	±200.0 kg/s		
Third loop flow rate, kg/s	-1 544	±200.0 kg/s		
Fourth loop flow rate, kg/s	5 075	±200.0 kg/s		
Pressuriser level, m	7.44	±0.15 m		
Water level in SG1, m	2.30	±0.075 m		
Water level in SG2, m	2.41	±0.075 m		
Water level in SG3, m	2.49	±0.075 m		
Water level in SG4, m	2.43	±0.075 m		
Secondary side pressure, MPa	5.937	±0.2 MPa		
Pressure difference in the reactor		±0.02 MPa		
Pressure difference in MCP		±0.02 MPa		

### C. SEQUENCE OF EVENTS

Transient calculation should be compared to the sequence of events given in Table 6.2.

**Table 6.2. Sequence of events**

Event description	Experiment, s	Calculation, s
MCP #3 switched on	0	
Minimum pressure above the core	12	
MCP #3 pressure drop stabilises	12	
Reactor pressure drop stabilises	16	
Primary side pressure stabilises	$\approx 25$	
Pressuriser water level stabilises	$\approx 60$	
Hot leg #3 temperature stabilises	60	
Transient ends	129	

Extreme scenario transient calculations should be compared to the sequence of events given in Table 6.3.

**Table 6.3. Sequence of events for extreme scenario of Exercise 3**

Event description	Specification, s	Calculation, s
MCP #3 switched on		
Rod of group 10 is ejected		
High neutron flux setpoint reached		
Maximum power after ejection		
Start of scram		
Transient ends		

### D. TRANSIENT CORE AVERAGED RESULTS (TIME HISTORIES)

For each of the results in Section D, the first column of numbers should be the time covering a time interval of 0-129 seconds, with data taken every 0.1 second. The second column should include the data at that time, with a space between the first and second columns.

D1) Fission power (W):

0.0000 9.9999E+99  
99.999 9.9999E+99

D2) Coolant (liquid) temperature (core average, hot and cold leg) (K):

0.0000 9.9999E+99  
99.999 9.9999E+99

D3) Pressure (core average, loop 3, and loops 1,2,4) (Pa):

0.0000 9.9999E+99  
99.999 9.9999E+99

#### D4) Reactivity edits (dk/k):

Total core reactivity and reactivity components (contributions from changes in moderator density, fuel temperature and neutron flux distribution – optional):

0.0000 9.999E+99  
99.999 9.999E+99

D8) Core average fuel temperature (K):

0.0000 9.999E+99  
99.999 9.999E+99

## E. SNAPSHOTS

- At time of maximum power before switching on MCP #3.
  - At time of maximum power after switching on MCP #3.
  - At time of maximum power after rod ejection.
  - At the end of the transient (129 seconds).

### E1) Fission power:


9.9999E+99

E2) Radial power distribution (full core) – start each line in column one, leave a blank space in between each number, and use a total of six spaces per number):


- E3) Axial power distribution – place all data starting in column one, leave a blank in between each number, and use a total of six spaces per number:

0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999 0.9999

**Figure 6.3.1. Form for axial power distribution**



**Figure 6.3.2. Form for radial power distribution**





## REFERENCES

- [1] Ivanov, K. *et al*, “PWR MSLB benchmark. Volume 1: Final Specifications”, NEA/NSC/DOC (99) 8, April 1999.
- [2] Ivanov, K., P. Groudev, R. Gencheva and B. Ivanov, “Letter-report on Kozloduy NPP transient”, US DOE, September 2000.
- [3] RELAP 5/MOD3.2 Code manual, INEEL.
- [4] RELAP-3D Code manual, Volume 1, INEEL.
- [5] Ivanov, K., *et al*, “Features and performance of a coupled three dimensional thermal-hydraulics/kinetics code TRAC-PF1/NEM PWR analysis code”, *Ann. Nucl. Energy*, **26**, 1407 (1999).
- [6] Database for VVER1000, “Safety analysis capability improvement of KNPP (SACI of KNPP) in the field of thermal hydraulic analysis”, BOA 278065-A-R4, INRNE-BAS, Sofia.
- [7] Engineering handbook, “Safety analysis capability improvement of KNPP (SACI of KNPP) in the field of thermal hydraulic analysis”, BOA 278065-A-R4, INRNE-BAS, Sofia.
- [8] Model validation for units 5&6, “Safety analysis capability improvement of the Kozloduy NPP in the field of thermal hydraulic analysis”, BOA 278065-A-R4.
- [9] B0401.04.00.000 VVER assemblies - Catalogue discription for 2 years fuel campaign.
- [10] Guideline for performing code validation within the DOE International Nuclear Safety Center (INSC), US/Russian International Nuclear Safety Center, ANL, Chicago and Moscow, September 23, 1997.
- [11] Исходные Данные для Кода, “Течь-М-4”, УДК 681.3: 621.039.586 8624606.00256-018101. ОКБ “Гидропресс”, 1995. (Available only in Russian.)
- [12] Марочник Сталь и Сплавов под Редакцией Сорокина В.Г., Москва, Машиностроение, 1989. (Available only in Russian.)
- [13] Чиркин В.С. Теплофизические Свойства Материалов Ядерной Энергетики, Москва, Атомиздат, 1968. (Available only in Russian.)
- [14] Запорожская АЭС Блок 5, Проект, Техническое Обоснование Безопасности Сооружения и Эксплуатации АЭС, Атомэнергопроект, Москва, 1991. (Available only in Russian.)


- [15] Справочник по Теплогидравлическим Расчетам (ядрные реакторы, теплоприемники, парогенераторы), Кириллов П.Л., Юрьев Ю.С., Бобков В.П., Москва, 1984. (Available only in Russian.)
- [16] Характеристики Сталь, Сварных Соединений, Сварных и Наплавочных Материалов для Корпуса и Крышки Реактора ВВЭР – 1000. Отчет ВНИИАЭС №85-031 /60200/I Москва, 1982. (Available only in Russian.)
- [17] Разработка Алгоритмов и Программ Расчета Деформации и Элементах Оборудования 1–го контура. Отчет ВНИИАЭС УДК 539.4.62Г, Москва, 1987. (Available only in Russian.)
- [18] Database for the Kozloduy NSSS for accident analysis of WWER-1000 model 320 nuclear plants, TC/RER/020, Reproduced by the IAEA, Vienna, Austria, 1994.
- [19] “HELIOS Methods”, StudsvikScandpower, 2000.

*Appendix A*


**RELAP5 NODALISATION SCHEMES  
AND SKELETON INPUT DECK**



**Figure A.1. VVER-1000 Unit 6 reactor and pressuriser RELAP5 four loops model**



**Figure A.2. VVER-1000 Unit 6 steam generator RELAP5 four loops model**



## SKELETON INPUT DECK

### **REACTOR**

Number of Volume	I.D/O.D. m	Elevation, m -bottom -top	Height, m	Flow area, m <sup>2</sup>	Hydraulic diameter, m	Volume, m <sup>3</sup>	Note
107	3.62/3.986	23.475 24.325	0.85	0.5466	0.366	0.4646	Upper part of downcomer.
108-01	3.62/3.986	23.03 23.475	0.445	0.5466	0.366	0.2432	Downcomer. Note: 208, 308, 408 are identical.
108-02	3.62/3.986	22.28 23.03	0.75	0.5466	0.366	0.41	
108-03	3.61/4.136	21.8388 22.28	0.44125	0.8	0.526	0.353	
108-04	3.61/4.136	21.39755 21.8388	0.44125	0.8	0.526	0.353	
108-05	3.61/4.136	20.9563 21.39755	0.44125	0.8	0.526	0.353	
108-06	3.61/4.136	20.51505 20.9563 20.0738	0.44125	0.8	0.526	0.353	
108-07	3.61/4.136	20.51505 19.6326 20.0738	0.44125	0.8	0.526	0.353	
108-08	3.61/4.136	19.1913 19.6326	0.44125	0.8	0.526	0.353	
108-09	3.61/4.136	18.7501 19.1913	0.44125	0.8	0.526	0.353	
108-10	3.61/4.136	18.4601 18.7501	0.44125	0.8	0.526	0.353	
108-11	3.61/4.136	17.894 18.4601	0.29	0.8	0.526	0.2328	
108-12	3.61/4.136		0.566	0.8	0.526	0.4528	
108-13	3.61/4.136	16.9301 17.8971	0.967	0.8	0.526	0.7736	Note: 208-13, 308-13, 408-13 are identical.
116	3.63/3.986	24.75 25.7	0.95	0.5324	0.21667	0.5058	Appendix of the downcomer. Note: 216, 316, 416 are identical.
830	3.47	17.894 18.46	0.566	9.4569	3.47	5.3526	Lower plenum- cylindrical part of core basket.
829		16.927 17.894	0.967			3.5757	lower plenum – lower part.
843-01		18.46 18.75	0.29	4.4498		1.2905	Reactor core.
843-02		18.75 18.75	0.44125	3.8165		1.68404	Note: The sub-volumes are with identical geometry.
843-03 - 843-09		19.19125	0.44125	3.8165		1.68404	
843-10		22.28 23.03	0.75	7.5192		5.6394	
845-01		18.46 18.75	0.29	0.4181		0.1212491	Note: The sub-volumes are with identical geometry.
845-02		18.75 19.19125	0.44125	0.3586		0.15823	
845-03 - 845-09			0.44125	0.3586		0.15823	
845-10		22.28 23.03	0.75	0.77238		0.57929	
842-01		18.46 18.75	0.29	0.14604		0.04235	Core bypass.
842-02		18.75 19.19125	0.44125	0.1253		0.05529	Note: The sub-volumes are with identical geometry.
842-03 - 842-09			0.44125	0.1253		0.05529	
842-10		22.28 23.03	0.75	0.11883		0.08912	
850		23.03 23.475	0.445	8.2916		3.68976	Mixing volume.
855-01		23.475 24.325	0.85	8.2916		7.04786	Down part of upper volume.
855-02		24.325 25.275	0.95	8.2916		7.87702	
860		25.275 26.125	0.85	11.8180		10.04532	Upper volume.
870		26.125 28.125	2.00	8.66612		17.332242	Upper part of upper volume.
880		28.125 29.36	1.235			8.9	Upper volume below reactor heat.

## **STEAM GENERATORS**

### **Steam generator primary side**

<b>Number of volume</b>	<b>Length/(height), m</b>	<b>Flow area, m<sup>2</sup></b>	<b>Volume, m<sup>3</sup></b>	<b>Note</b>
120	10.95	0.33395	3.658	SG#1 tubes. Note: Volumes 220, 320, 420 for SG #2, #3 and #4 tubes are identical.
121	11.09	0.636317	7.025	SG#1 tubes. Note: Volumes 221, 321, 421 for SG #2, #3 and #4 tubes are identical.
122	11.09	0.4898	5.432	SG#1 tubes. Note: Volumes 222, 322, 422 for SG #2, #3 and #4 tubes are identical.
110	0.8	0.546	0.4368	Hot collector. The Volumes 111, 112 are identical.
141-03	0.67 top elev. 27.91 bottom 27.24	0.546	0.3658	Inlet of SG #1 hot collector.
115	1.875 top elev. 32.185 bottom 30.31	0.386	0.7238	Upper part of SG#1 hot collector .
130	0.8 top elev. 28.71 bottom 27.91	0.546	0.4368	SG #1 cold collector. The Volumes 230, 330 and 430 are identical.
131	0.8 top elev. 29.51 bottom 28.71	0.546	0.4368	SG #1 cold collector. The Volumes 231, 331 and 431 are identical.
132	0.8 top elev. 30.31 bottom 29.51	0.546	0.4368	SG #1 cold collector. The Volumes 232, 332 and 432 are identical.
135	1.875 top elev. 32.185 bottom 30.31	0.386	0.7238	Upper part of SG #1 cold collector The Volumes 235, 335 and 435 are identical.
210	0.8	0.546	0.4368	SG#2 hot collector. The Volumes 211, 212 are identical.
241-03	0.67 top elev. 27.91 bottom 27.24	0.546	0.3658	Inlet of SG#2 hot collector.
215	1.875	0.386	0.7238	SG#2 hot collector.
310	0.8	0.546	0.4368	SG#3 hot collector. The Volumes 311, 312 are identical.
341-03	0.67 top elev. 27.91 bottom 27.24	0.546	0.3658	Inlet of SG#3 hot collector.
315	1.875	0.386	0.7238	SG#3 hot collector.
410	0.8	0.546	0.4368	SG#4 hot collector. Volumes 411, 412 are identical.
441-03	0.67 top elev. 27.91 bottom 27.24	0.546	0.3658	Inlet of SG#4 hot collector.
415	1.875	0.386	0.7238	SG#4 hot collector.

Note: Data for Volumes 110-115 (hot collectors) and Volumes 130-135 (cold collectors) are analogues.  
SG#2, 3 and 4 cold and hot collectors are analogues.

### **Steam generator secondary side – modelled corresponding to the SG – primary side**

<b>Number of volume</b>	<b>Height, m</b>	<b>Volume, m<sup>3</sup></b>	<b>Note</b>
100	0.80	11.80	
101	0.80	22.60	
102	0.80	22.05	
103	0.30	14.15	
104	0.80	32.90	
105	0.50	7.10	
150	0.80	4.00	
151	0.80	3.60	
152	0.80	8.80	

Note: The total volume is 127 m<sup>3</sup>. Steam generators # 2, 3 and 4 volumes are analogous.

## **PRIMARY LOOPS**

### *Hot leg*

Number of volume	Length, m	Flow area, m <sup>2</sup>	Volume, m <sup>3</sup>	Elevation (axis elevation), m	Note
146	1.64	0.5675	0.9307	25.70	Outlet of reactor vessel. Volumes 246, 346 and 446 are identical.
140	5.87	0.5675	3.331225	25.70	Volumes 240, 340 and 440 are identical.
141-01	1.714	0.5675	0.9727	25.70	Hot leg of loop#1. Volumes 241-01, 341-01 and 441-01 are identical.
141-02	1.54	0.5675	0.87395	25.70 bottom 27.24 top	Hot leg of loop#1.
141-03	0.67	0.546	0.3658	27.24 bottom 27.91 top	Volumes 241-02, 341-02 and 441-03 are identical. Inlet of SG#1 hot collector. Volumes 241-03, 341-03 and 441-03 are identical.

Note: Date the volume of hot loops #2, 3 and 4 volumes are analogues.

### *Cold leg*

Number of volume	Height, m	Flow area, m <sup>2</sup>	Volume, m <sup>3</sup>	Elevation • bottom • top	Note
142-01	0.67	0.546	0.36582	27.24 27.91	Volume 142 – Pipe, outlet of cold collector.
142-02	3.34	0.567	1.89378	23.90 27.24	Volumes 242, 342 and 442 are identical.
142-03	3.26	0.567	1.848	20.64 23.90	
142-04	1.9467	0.567	1.103779	20.64 – axis	
142-05	1.9467	0.567	1.103779	20.64 – axis	
142-06	1.9467	0.567	1.103779	20.64 – axis	
142-07	3.26	0.567	1.84842	23.90 27.91	
145-01	2.308	0.5675	1.3097	23.90	
145-02	2.308	0.5675	1.3097	23.90	
145-03	2.308	0.5675	1.3097	23.90	Volume 145 is a pipe after MCP.
145-04	2.308	0.5675	1.3097	23.90	Volumes 245, 345 and 445 are identical.
145-05	2.308	0.5675	1.3097	23.90	

Note: Date the volume of cold loops #2, 3 and 4 volumes are analogues.

## **MAIN COOLANT PUMP GCN – 195 M**

Pump components in the model are volumes 144, 244, 344 and 444.

### **Input data for pump – component 144, having 1 volume and 2 junctions**

Volume no.	Flow area, (m <sup>2</sup> )	Flow length, (m)	Volume, (m <sup>3</sup> )	Horizontal angle, (deg)	Vertical angle, (deg)	Elevation changes, (m)
144 010 000	0.500000	6.000000	3.000000	0.000000	0.000000	0.000000

Junction no.	Initial liquid flow	Initial vapour flow
144 010 000	4 405.00	4 405.00
144 020 000	4 405.00	4 405.00

### Edit of pump index & option indicators

Single phase table set index	0
2 phase head & torque multiplier table index	0
2 phase difference table set index	0
Pump motor torque table index	-1
Time dependent pump speed table index	0
Pump reverse indicator	0

### Edit of pump fixed data parameters

Parameter	Value
Rated pump speed	104.199 (rad/sec)
Pump speed ratio (initial/rated)	1.00000
Rated pump flow	5.88889 (m <sup>3</sup> /sec)
Rated pump head	82.9000 (m)
Rated pump torque	47500.0 (n-m)
Pump moment of inertia	7600.00 (kg-m <sup>2</sup> )
Pump rated density	0.00000 (kg/m <sup>3</sup> )
Pump rated motor torque	0.00000 (n-m)
Pump frictional torque coefficient #3	0.00000 (n-m)
Pump frictional torque coefficient #1	400.000 (n-m)
Pump frictional torque coefficient #2	0.00000 (n-m)
Pump frictional torque coefficient #4	0.00000 (n-m)

### Pump stop parameter values input

Parameter	Value
Pump stop time	0.00000 (sec)
Pump maximum forward speed	0.00000 (rad/sec)
Pump maximum reverse speed	0.00000 (rad/sec)

Rundown characteristics for 4 pumps at p = 15.4 MPa and T = 300°C are presented below

$\tau$ , sec	Q, m <sup>3</sup> /h	P, kgf/cm <sup>2</sup>	N, Rad/sec
0	20 000	6.5	104.196
0.5	19 450	6.15	103.46
1.0	18 900	5.8	98.44
1.5	18 450	5.5	96.03
2.0	16 000	5.3	93.72
2.5	17 750	5.0	91.42
3.0	17 150	4.8	89.33
3.5	16 750	4.6	87.23
4.0	16 350	4.35	85.14
5.0	15 650	4.0	81.68
7.0	14 400	3.4	74.98

<b><math>\tau</math>, sec</b>	<b><math>Q</math>, <math>m^3/h</math></b>	<b><math>P</math>, <math>kgf/cm^2</math></b>	<b><math>N</math>, Rad/sec</b>
10	12 850	2.70	67.02
15	10 900	2.00	56.76
20	9 400	1.45	45.87
25	8 400	1.15	43.77
30	7 500	1.00	39.06
50	5 160	0.45	26.91
90	3 200	0.15	15.71
135	1 820	0.05	9.42
180	1 100	0.02	5.76
210	720	0.01	3.98
232	0	0	0

### **Homologous curves (see Figure A3 and Figure A4)**

The differences shown in tables are for the eight curve types used for determining pump head.

#### **Edit for pump single phase table input**

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For head curve no. 1	0.000000	1.56000
	0.179000	1.47000
	0.304000	1.42000
	0.431000	1.39000
	0.582000	1.35000
	0.860000	1.18000
	0.966000	1.08000
	1.000000	1.00000
For head curve no. 2	0.000000	-1.40000
	0.161000	-1.10000
	0.247000	-0.93000
	0.315000	-0.78000
	0.424000	-0.54000
	0.500000	-0.35000
	0.556000	-0.21000
	0.610000	-8.00000E-02
	0.673000	0.10000
	0.736000	0.26000
	0.815000	0.45000
	0.904000	0.73000
	1.000000	1.00000
For head curve no. 3	-1.000000	4.00000
	-0.823000	2.30000
	-0.770000	2.13000
	-0.720000	2.13000
	-0.571000	2.07000
	-0.450000	1.92000
	-0.120000	1.70000
	0.000000	1.56000
For head curve no. 4	-1.000000	4.00000
	-0.767000	2.94000
	-0.500000	2.50000
	0.000000	1.76000

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For head curve no. 5	0.000000	0.00000
	7.700000E-02	8.00000E-02
	0.110000	0.11000
	0.150000	0.15000
	0.208000	0.21000
	0.250000	0.25000
	0.286000	0.29000
	0.333000	0.33000
	0.381000	0.38000
	0.730000	0.73000
	0.800000	0.80000
	1.000000	1.00000
For head curve no. 6	0.000000	1.76000
	4.100000E-02	1.70000
	0.211100	1.53000
	0.324000	1.41000
	0.380400	1.34000
	0.473000	1.25000
	0.611000	1.11000
	0.865200	1.01000
	1.000000	1.00000
For head curve no. 7	-1.000000	-2.78000
	-0.913000	-2.54000
	-0.839000	-2.33000
	-0.659000	-1.83000
	-0.570000	-1.58000
	-0.526000	-1.46000
	-0.475000	-1.32000
	-0.410000	-1.14000
	-0.327000	-0.91000
	-0.210000	-0.58000
	-0.119000	-0.33000
	-6.000000E-02	-0.17000
	0.000000	0.00000
For head curve no. 8	-1.000000	-2.78000
	-0.881000	-2.62000
	-0.730000	-2.41000
	-0.453000	-2.03000
	-0.368000	-1.91000
	0.000000	-1.40000

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For torque curve no. 1	0.000000	0.800000
	8.400000E-02	0.800000
	0.294000	0.820000
	0.406000	0.830000
	0.575000	0.880000
	0.920000	0.980000
	1.000000	1.000000

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For torque curve no. 2	0.000000	-0.810000
	0.111000	-0.590000
	0.185000	-0.440000
	0.240000	-0.330000
	0.308000	-0.200000
	0.340000	-0.140000
	0.378000	-6.000000E-02
	0.418000	3.000000E-02
	0.483000	0.170000
	0.530000	0.230000
	0.574000	0.300000
	0.633000	0.390000
	0.694000	0.500000
	0.790000	0.630000
	0.970000	0.950000
	1.000000	1.000000
For torque curve no. 3	-1.000000	2.460000
	-0.969000	2.340000
	-0.930000	2.190000
	-0.796000	1.680000
	-0.615000	1.370000
	-0.476000	1.090000
	-0.359000	0.980000
	-0.307000	0.930000
	-8.800000E-02	0.810000
	0.000000	0.800000
For torque curve no. 4	-1.000000	2.460000
	-0.950000	2.400000
	-0.860000	2.280000
	-0.702000	2.120000
	-0.440000	1.860000
	0.000000	1.500000
For torque curve no. 5	0.000000	-1.300000
	9.100000E-02	-1.100000
	0.194000	-0.880000
	0.313000	-0.700000
	0.465000	-0.380000
	0.754000	0.190000
	0.876000	0.430000
	1.000000	0.670000
For torque curve no. 6	0.000000	1.500000
	6.700000E-02	1.450000
	0.113000	1.410000
	0.239000	1.330000
	0.565000	1.060000
	0.681000	0.960000
	0.956000	0.710000
	1.000000	0.670000
For torque curve no. 7	-1.000000	-3.970000
	0.000000	-1.300000

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For torque curve no. 8	-1.000000	-3.970000
	-0.833000	-3.440000
	-0.600000	-2.700000
	-0.333000	-1.860000
	-0.186000	-1.400000
	-7.500000E-02	-1.050000
	0.000000	-0.810000

Edit for pump head multiplier table input	0.000000	0.000000
	7.000000E-02	0.000000
	8.000000E-02	0.740000
	0.165000	1.000000
	0.900000	1.000000
	1.000000	0.000000
Edit for pump torque multiplier table input	0.000000	0.000000
	1.000000	0.000000

### Edit for pump two-phase table set input

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For head curve no. 1	0.000000	0.000000
	0.100000	0.830000
	0.200000	1.090000
	0.500000	1.020000
	0.700000	1.010000
	0.900000	0.940000
	1.000000	1.000000
For head curve no. 2	0.000000	0.000000
	0.100000	-4.000000E-02
	0.200000	0.000000
	0.300000	0.100000
	0.400000	0.210000
	0.800000	0.670000
	0.900000	0.800000
	1.000000	1.000000
For head curve no. 3	-1.000000	-1.160000
	-0.900000	-1.240000
	-0.800000	-1.770000
	-0.700000	-2.360000
	-0.600000	-2.790000
	-0.500000	-2.910000
	-0.400000	-2.670000
	-0.250000	-1.690000
	-0.100000	-0.500000
	0.000000	0.000000
For head curve no. 4	-1.000000	-1.160000
	-0.900000	-0.780000
	-0.800000	-0.500000
	-0.700000	-0.310000
	-0.600000	-0.170000
	-0.500000	-8.000000E-02

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For head curve no. 4 (cont'd)	-0.350000	0.000000
	-0.200000	5.000000E-02
	-0.100000	8.000000E-02
	0.000000	0.110000
For head curve no. 5	0.000000	0.000000
	0.200000	-0.340000
	0.400000	-0.650000
	0.600000	-0.950000
	0.800000	-1.190000
	1.000000	-1.470000
For head curve no. 6	0.000000	0.110000
	0.100000	0.130000
	0.250000	0.150000
	0.400000	0.130000
	0.500000	7.000000E-02
	0.600000	-4.000000E-02
	0.700000	-0.230000
	0.800000	-0.510000
	0.900000	-0.910000
	1.000000	-1.470000
For head curve no. 7	-1.000000	0.000000
	0.000000	0.000000
For head curve no. 8	-1.000000	0.000000
	0.000000	0.000000

<b>Curve no.</b>	<b>Indep. variable</b>	<b>Depend. variable</b>
For torque curve no. 1	0.00000	0.00000
	1.00000	0.00000
For torque curve no. 2	0.00000	0.00000
	1.00000	0.00000
For torque curve no. 3	-1.00000	0.00000
	0.00000	0.00000
For torque curve no. 4	-1.00000	0.00000
	0.00000	0.00000
For torque curve no. 5	0.00000	0.00000
	1.00000	0.00000
For torque curve no. 6	0.00000	0.00000
	1.00000	0.00000
For torque curve no. 7	-1.00000	0.00000
	0.00000	0.00000
For torque curve no. 8	-1.00000	0.00000
	0.00000	0.00000

## PRESSURISER VESSEL

Number of volume	Height, m	Flow area, m <sup>2</sup>	Volume, m <sup>3</sup>	Hydraulic diameter, m	Elevation, m • bottom • top	Note
806	0.60	4.7714	2.8628	2.4648	22.03 22.63	Branch. Elliptical bottom of the Prz. Vessel.
307-01	2.00	7.0686	14.1372		22.63 24.63 24.63 26.67	Pipe. The cylindrical part of the vessel.
307-02	2.045	2.9757	6.0875		26.67	Prz. Heaters.
307-03	2.045	7.0686	14.4553		26.67 28.72	
307-04	2.045	7.0686	14.4553		28.72	
307-05	1.59	7.0686	11.2391		30.76 30.76 32.35	
370	1.825	7.0686	12.9002		32.35 34.175	Branch. The cylindrical part of the vessel.
377	0.60	4.7714		2.4648		Branch. Elliptical head of the vessel.

## SURGE LINE & PRESSURISER SPRAY LINE

Number of volume	Length, m	Flow area, m <sup>2</sup>	Volume, m <sup>3</sup>	Elevation, m • bottom • top	Note
805	18.00	0.094	1.692		Pipe – surge line.
805-01	5.56		0.52264	20.14 25.70	
805-02	10.55		0.9917	20.14	
805-03	1.89		0.17766	20.14 22.03	
380	38.00	0.02573	0.97774		Pipe – pressuriser spray line.
380-01	10.00		0.2573	23.90	
380-02	18.12		0.466	23.90	
380-03	9.88		0.254	23.90 33.78	

## PRESSURE LOSS COEFICIENTS

All pressure loss coefficients are based on the geometrical data of the corresponding junction. They take into account the flow area change and the change of flow direction.

- $k_f$  – forward pressure loss coefficient.
- $k_r$  – reverse pressure loss coefficient.

## Reactor pressure loss coefficients

<b>From component no. to component no.</b>	<b>k<sub>f</sub></b>	<b>k<sub>r</sub></b>
From component 147 (247, 347, 447) to component 107 (207, 327, 407)	0.5	0.2
From component 107 to component 207: cross flow junction	0.3	0.2
From component 207 to component 327: cross flow junction	0.3	0.3
From component 327 to component 407: cross flow junction	0.3	0.3
From component 407 to component 107: cross flow junction	0.3	0.3
From component 107 (207, 327, 427) to component 108-01 (208-01, 308-01, 408-01)	0.05	0.02
From component 108-13 (208-13, 308-13, 408-13) to component 829 cross flow junction is applied	1.5	1.8
From component 829 to component 830	1.95	2.2
From component 830 to component 843 (845, 842)	1.2	2.5
From component 843 (845, 842) to component 850	2.0	2.2
From component 850 to component 855	0.8	1.2
From component 860 to component 146 (246, 346, 446) cross flow junction is applied	0.5	0.8
From component 855 to component 860	0.1	0.3
From component 860 to component 870	0.1	0.1
From component 870 to component 880	0.1	0.1
From component 108-01 (up to 108-13) to component 208-01 (up to 208-13): cross flow junction	0.3	0.3
From component 208-01 (up to 208-13) to component 308-01 (up to 308-13): cross flow junction	0.3	0.3
From component 308 (up to 308-13) to component 408 (up to 408-13): cross flow junction	0.3	0.3
From component 108 (up to 108-13) to component 408 (up to 408-13): cross flow junction	0.3	0.3

## SG #1 primary side pressure loss coefficients

<b>From component no. to component no.</b>	<b>k<sub>f</sub></b>	<b>k<sub>r</sub></b>
From component 110 to 120: abrupt area change option	1.0	1.2
From component 110 to 111	0.0	0.0
From component 141-03 to 110-01	0.3	0.48
From component 111-01 to 112-01	0.0	0.0
From component 111-01 to 121-01	1.0	1.2
From component 112-01 to 115-01	0.0	0.0
From component 131-01 to 130-01	0.0	0.0
From component 120-05 to 130-01	1.0	1.2
From component 130-01 to 142-01	0.3	0.48
From component 132-01 to 131-01	0.0	0.0
From component 121-05 to 131-01	1.0	1.2
From component 135-01 to 132-01	0.0	0.0
From component 122-05 to 132-01	1.0	1.2

Note: Pressure loss coefficients for SG #2, 3 and 4 are identical to SG #11 coefficients.

## SG #1 secondary side pressure loss coefficients

<b>From component no. to component no.</b>	<b>k<sub>f</sub></b>	<b>k<sub>r</sub></b>
From component 100-01 to 101-01	0.5	0.5
From component 101-01 to 102-01	0.5	0.5
From component 151-01 to 150-01	0.0	0.0
From component 150-01 to 100-01	3.3	3.3
From component 151-01 to 101-01	1.2	1.2
From component 152-01 to 151-01	0.0	0.0
From component 103-01 to 152-01	0.5	0.5
From component 102-01 to 103-01	1.0	1.2
From component 103-01 to 104-01	0.0	0.0
From component 104-01 to 105-01	5.0	5.5
From component 109-01 to 152-01	0.0	0.0
From component 105-01 to 109-01	0.0	0.0
From component 105-01 to 106-01	3.0	3.5

Note: Pressure loss coefficients for SG #2, 3 and 4 are identical to SG #1 coefficients.

### Pressuriser pressure loss coefficients

<b>From component no. to component no.</b>	<b><math>k_f</math></b>	<b><math>k_r</math></b>
From component #441 (hot leg) to component #805 (surge line): cross flow junction	1.0	1.0
From component #805 to component 806: abrupt area change option, (junction flow area = 0.094 )	0.0	0.0
From component #806 to component #307	0.0	0.0

## MATERIAL

### *REACTOR VESSEL*

Reactor vessel	Steel 15X2HMФA
Reactor cover	Steel 15X2HMФA
Reactor core barrel	08X18H10T
Reactor core barrel elliptical bottom	SS
Reactor core support plate (lower)	08X18H10T
Reactor core support plate (down)	08X18H10T
Plate at the top of the block of control rod guide tubes	SS
Plate between cylindrical and elliptical part of upper head	SS

### *REAKTOR CORE*

Fuel rod pellet	UO <sub>2</sub>
Fuel rod cladding	Zr+1%Nb
Gas in gas gap	He
Water rod	Zr+1%Nb
Control rod guide tubes	SS

### *MAIN CIRCULATION LOOP*

Primary loops material	10ГН2МФА
Pressuriser vessel	10ГН2МФА


### *REACTOR COOLANT PUMP*

Material of the action wheel	Steel 12X18H10T
Material of the casing	Steel 12X18H10T

### *STEAM GENERATOR*

SG secondary side Vessel	10ГН2МФА
SG primary side tubing	08X18H10T

**Figure A.3. Four – quadrant MCP head characteristics**




H – Pump head

Q – Mass-flow rate

n – Rotation speed

**Figure A.4. Four – quadrant MCP torque characteristics**



*Appendix B*

**SAMPLE CROSS-SECTION TABLE**



```

* NEM-Cross Section Table Input
*
*      T Fuel          Rho Mod.        Boron ppm.      T Mod.
*      5               4                  0                 0
*
*****
*      X-Section set #      1
*
*      Group No.   1
*
*****                      Diffusion Coefficient Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .1508700E+01
.1514300E+01  .1437800E+01  .1440100E+01  .1441000E+01  .1441500E+01
.1446600E+01  .1388600E+01  .1390800E+01  .1391700E+01  .1392100E+01
.1397000E+01  .1387100E+01  .1389300E+01  .1390200E+01  .1390700E+01
.1395500E+01  .1380300E+01  .1382500E+01  .1383300E+01
*
*****                      Total Absorption X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .1079000E-01
.1103800E-01  .1074100E-01  .1089800E-01  .1095500E-01  .1098300E-01
.1123800E-01  .1087400E-01  .1103400E-01  .1109300E-01  .1112100E-01
.1138300E-01  .1087900E-01  .1104000E-01  .1109800E-01  .1112700E-01
.1138900E-01  .1089800E-01  .1105900E-01  .1111800E-01
*
*****                      Fission X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .1965171E-02
.1948015E-02  .2007931E-02  .2000111E-02  .1996925E-02  .1995221E-02
.1978074E-02  .2030571E-02  .2022701E-02  .2019584E-02  .2017878E-02
.2000667E-02  .2031764E-02  .2023930E-02  .2020737E-02  .2019030E-02
.2001854E-02  .2035185E-02  .2027312E-02  .2024119E-02
*
*****                      Nu-Fission X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .5309500E-02
.5264900E-02  .5418000E-02  .5397900E-02  .5389700E-02  .5385300E-02
.5340800E-02  .5473200E-02  .5453000E-02  .5444800E-02  .5440400E-02
.5396000E-02  .5475400E-02  .5455300E-02  .5447100E-02  .5442700E-02
.5398200E-02  .5483400E-02  .5463200E-02  .5455000E-02
*
*****                      Scattering X-Section Table
*
**** From group 1 to 2
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .1321800E-01
.1306600E-01  .1510700E-01  .1501300E-01  .1497800E-01  .1496100E-01
.1480100E-01  .1650500E-01  .1640800E-01  .1637200E-01  .1635400E-01
.1618700E-01  .1654500E-01  .1644800E-01  .1641200E-01  .1639400E-01
.1622600E-01  .1674700E-01  .1665000E-01  .1661300E-01

```

```

*
*      Group No.  2
*
*****          Diffusion Coefficient Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .4056100E+00
.4069800E+00  .3693900E+00  .3699500E+00  .3701800E+00  .3703000E+00
.3715600E+00  .3440200E+00  .3445600E+00  .3447800E+00  .3448900E+00
.3460800E+00  .3427700E+00  .3433100E+00  .3435300E+00  .3436400E+00
.3448300E+00  .3390900E+00  .3396200E+00  .3398400E+00
*
*****          Total Absorption X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .9817500E-01
.9774600E-01  .9955400E-01  .9934400E-01  .9925900E-01  .9921600E-01
.9876400E-01  .1005400E+00  .1003200E+00  .1002300E+00  .1001800E+00
.9970400E-01  .1006500E+00  .1004300E+00  .1003400E+00  .1002900E+00
.9980900E-01  .1008400E+00  .1006100E+00  .1005200E+00
*
*****          Fission X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .5128803E-01
.5106745E-01  .5171034E-01  .5160071E-01  .5155243E-01  .5153199E-01
.5130000E-01  .5196260E-01  .5184540E-01  .5179896E-01  .5177478E-01
.5152942E-01  .5200564E-01  .5188840E-01  .5184004E-01  .5181586E-01
.5156494E-01  .5206176E-01  .5194078E-01  .5189240E-01
*
*****          Nu-Fission X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .1385700E+00
.1380200E+00  .1395300E+00  .1392600E+00  .1391400E+00  .1390900E+00
.1385100E+00  .1400600E+00  .1397700E+00  .1396500E+00  .1395900E+00
.1389800E+00  .1401500E+00  .1398600E+00  .1397400E+00  .1396800E+00
.1390500E+00  .1402700E+00  .1399700E+00  .1398500E+00
*
*****          Xe X-Section Table
*
.5400000E+03  .7600000E+03  .8550000E+03  .1000000E+04  .1500000E+04
.7868400E+03  .7617800E+03  .7125000E+03  .6616800E+03  .3316200E-02
.3293900E-02  .3327400E-02  .3317700E-02  .3313600E-02  .3311500E-02
.3289200E-02  .3335000E-02  .3325100E-02  .3321000E-02  .3318800E-02
.3296200E-02  .3340400E-02  .3330500E-02  .3326300E-02  .3324200E-02
.3301400E-02  .3344100E-02  .3334100E-02  .3329900E-02
*
*****          Inv. Neutron Velocities
*
.5456850E-07  .2491910E-05
*
```

*Appendix C*


**MCP TEST PLANT DATA**



**Table C.1. Water level in the pressuriser during the transient**

Time, s	Level, m	Time, s	Level, m	Time, s	Level, m
0	7.44	44	7.34	88	7.30
4	7.44	48	7.33	92	7.30
8	7.44	52	7.32	96	7.29
12	7.41	56	7.32	100	7.29
16	7.39	60	7.31	104	7.29
20	7.39	64	7.31	108	7.28
24	7.37	68	7.31	112	7.28
28	7.36	72	7.31	116	7.29
32	7.36	76	7.32	120	7.28
36	7.36	80	7.30	124	7.28
40	7.35	84	7.30	128	7.28


**Figure C.1. Water level in the pressuriser during the transient**



**Table C.2. Water level in SG #1 during the transient**

Time, s	Level, m	Time, s	Level, m	Time, s	Level, m
0	2.30	44	2.32	88	2.37
4	2.30	48	2.33	92	2.36
8	2.30	52	2.33	96	2.36
12	2.30	56	2.35	100	2.36
16	2.29	60	2.35	104	2.36
20	2.28	64	2.36	108	2.35
24	2.28	68	2.36	112	2.35
28	2.28	72	2.36	116	2.35
32	2.29	76	2.36	120	2.35
36	2.30	80	2.36	124	2.35
40	2.30	84	2.36	128	2.35


**Figure C.2. Water level in SG #1 during the transient**



**Table C.3. Water level in SG #2 during the transient**

Time, s	Level, m	Time, s	Level, m	Time, s	Level, m
0	2.41	44	2.38	88	2.40
4	2.41	48	2.39	92	2.41
8	2.41	52	2.39	96	2.41
12	2.42	56	2.40	100	2.41
16	2.42	60	2.39	104	2.42
20	2.40	64	2.39	108	2.41
24	2.40	68	2.40	112	2.41
28	2.40	72	2.41	116	2.42
32	2.39	76	2.40	120	2.41
36	2.39	80	2.40	124	2.42
40	2.39	84	2.41	128	2.41


**Figure C.3. Water level in SG #2 during the transient**



**Table C.4. Water level in SG #3 during the transient**

Time, s	Level, m	Time, s	Level, m	Time, s	Level, m
0	2.49	44	2.49	88	2.35
4	2.49	48	2.47	92	2.35
8	2.48	52	2.45	96	2.35
12	2.48	56	2.42	100	2.36
16	2.56	60	2.40	104	2.36
20	2.57	64	2.39	108	2.36
24	2.56	68	2.36	112	2.37
28	2.56	72	2.35	116	2.37
32	2.54	76	2.34	120	2.38
36	2.53	80	2.34	124	2.38
40	2.51	84	2.35	128	2.39


**Figure C.4. Water level in SG #3 during the transient**



**Table C.5. Water level in SG #4 during the transient**

Time, s	Level, m	Time, s	Level, m	Time, s	Level, m
0	2.43	44	2.46	88	2.49
4	2.43	48	2.47	92	2.49
8	2.43	52	2.47	96	2.49
12	2.43	56	2.48	100	2.49
16	2.42	60	2.49	104	2.49
20	2.41	64	2.49	108	2.49
24	2.40	68	2.49	112	2.48
28	2.41	72	2.49	116	2.48
32	2.43	76	2.49	120	2.48
36	2.43	80	2.49	124	2.48
40	2.44	84	2.49	128	2.48


**Figure C.5. Water level in SG #4 during the transient**



**Table C.6. Cold leg #1 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	555.55	45	555.15	89	554.65
5	555.65	49	555.05	93	554.65
9	555.65	53	554.75	97	554.55
13	555.65	57	554.85	101	554.65
17	555.55	61	554.85	105	554.65
21	555.55	65	554.65	109	554.55
25	555.25	69	554.65	113	554.25
29	555.25	73	554.65	117	554.25
33	555.05	77	554.55	121	554.25
37	555.15	81	554.65	125	554.45
41	555.05	85	554.75	129	554.75


**Figure C.6. Cold leg #1 coolant temperature during the transient**



**Table C.7. Cold leg #2 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	554.55	45	554.65	89	554.35
5	554.45	49	554.75	93	554.35
9	554.35	53	554.45	97	554.35
13	554.65	57	554.65	101	554.45
17	554.75	61	554.45	105	554.35
21	554.75	65	554.55	109	554.25
25	554.65	69	554.65	113	554.35
29	554.65	73	554.45	117	554.15
33	554.75	77	554.35	121	554.25
37	554.65	81	554.55	125	554.45
41	554.75	85	554.45	129	554.25


**Figure C.7. Cold leg #2 coolant temperature during the transient**



**Table C.8. Cold leg #3 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	554.35	45	554.55	89	554.85
5	554.25	49	554.65	93	554.85
9	554.35	53	554.55	97	554.65
13	554.35	57	554.75	101	554.55
17	554.05	61	554.85	105	554.55
21	553.75	65	554.75	109	554.65
25	554.05	69	554.75	113	554.55
29	554.15	73	554.75	117	554.75
33	554.35	77	554.65	121	554.45
37	554.55	81	554.65	125	554.45
41	554.75	85	554.65	129	554.45


**Figure C.8. Cold leg #3 coolant temperature during the transient**



**Table C.9. Cold leg #4 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	555.25	45	554.65	89	554.35
5	555.25	49	554.75	93	554.35
9	555.25	53	554.55	97	554.45
13	555.25	57	554.55	101	554.25
17	555.25	61	554.45	105	554.15
21	555.15	65	554.65	109	554.25
25	555.15	69	554.55	113	554.35
29	555.05	73	554.55	117	554.25
33	554.95	77	554.45	121	554.45
37	554.95	81	554.45	125	554.55
41	554.65	85	554.65	129	554.25


**Figure C.9. Cold leg #4 coolant temperature during the transient**



**Table C.10. Hot leg #1 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	567.05	45	564.45	89	563.65
5	567.05	49	564.35	93	563.65
9	566.95	53	564.15	97	563.55
13	566.85	57	563.75	101	563.65
17	566.35	61	563.85	105	563.65
21	566.15	65	563.85	109	563.65
25	565.85	69	563.75	113	563.65
29	565.15	73	563.65	117	563.65
33	564.75	77	563.75	121	563.65
37	564.85	81	563.65	125	563.65
41	564.55	85	563.65	129	563.55


**Figure C.10. Hot leg #1 coolant temperature during the transient**



**Table C.11. Hot leg #2 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	562.85	45	563.05	89	562.75
5	562.65	49	563.05	93	562.65
9	562.85	53	562.75	97	562.65
13	563.15	57	562.65	101	562.65
17	563.45	61	562.65	105	562.45
21	563.55	65	562.55	109	562.45
25	563.45	69	562.65	113	562.65
29	563.45	73	562.65	117	562.45
33	563.35	77	562.65	121	562.55
37	563.05	81	562.65	125	562.65
41	563.05	85	562.75	129	562.65


**Figure C.11. Hot leg #2 coolant temperature during the transient**



**Table C.12. Hot leg #3 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	550.75	45	561.45	89	562.65
5	550.75	49	561.85	93	562.35
9	550.95	53	562.05	97	562.55
13	551.95	57	562.35	101	562.55
17	556.55	61	562.35	105	562.65
21	557.25	65	562.45	109	562.35
25	558.05	69	562.55	113	562.45
29	559.75	73	562.55	117	562.75
33	559.95	77	562.65	121	562.65
37	560.65	81	562.45	125	562.45
41	561.45	85	562.65	129	562.65


**Figure C.12. Hot leg #3 coolant temperature during the transient**



**Table C.13. Hot leg #4 coolant temperature during the transient**

Time, s	Temperature, K	Time, s	Temperature, K	Time, s	Temperature, K
1	566.15	45	563.15	89	563.15
5	566.15	49	563.15	93	563.15
9	566.15	53	563.15	97	563.15
13	565.15	57	563.15	101	563.15
17	565.15	61	563.15	105	563.15
21	564.15	65	563.15	109	563.15
25	564.15	69	563.15	113	563.15
29	564.15	73	563.15	117	563.15
33	563.15	77	563.15	121	563.15
37	563.15	81	563.15	125	563.15
41	563.15	85	563.15	129	563.15


**Figure C.13. Hot leg #4 coolant temperature during the transient**



**Table C.14. Pressure above the core**

Time, s	Pressure, MPa	Time, s	Pressure, MPa	Time, s	Pressure, MPa
0	15.60	44	15.53	88	15.54
4	15.60	48	15.54	92	15.54
8	15.59	52	15.54	96	15.53
12	15.53	56	15.54	100	15.54
16	15.53	60	15.54	104	15.53
20	15.53	64	15.54	108	15.53
24	15.54	68	15.54	112	15.54
28	15.54	72	15.54	116	15.53
32	15.54	76	15.53	120	15.54
36	15.54	80	15.53	124	15.54
40	15.54	84	15.54	128	15.54


**Figure C.14. Pressure above the core**



**Table C.15. Reactor pressure drop**

Time, s	Pressure, MPa	Time, s	Pressure, MPa	Time, s	Pressure, MPa
0	0.225	44	0.400	88	0.399
4	0.235	48	0.399	92	0.399
8	0.313	52	0.397	96	0.400
12	0.380	56	0.402	100	0.400
16	0.397	60	0.401	104	0.398
20	0.397	64	0.399	108	0.398
24	0.400	68	0.400	112	0.399
28	0.398	72	0.397	116	0.398
32	0.399	76	0.399	120	0.400
36	0.397	80	0.398	124	0.400
40	0.399	84	0.396	128	0.399


**Figure C.15. Reactor pressure drop**



**Table C.16. MCP #1 pressure drop**

Time, s	Pressure, MPa	Time, s	Pressure, MPa	Time, s	Pressure, MPa
0	0.492	44	0.614	88	0.613
4	0.495	48	0.614	92	0.612
8	0.533	52	0.613	96	0.612
12	0.612	56	0.610	100	0.612
16	0.614	60	0.613	104	0.611
20	0.611	64	0.612	108	0.612
24	0.611	68	0.611	112	0.611
28	0.612	72	0.611	116	0.610
32	0.615	76	0.612	120	0.610
36	0.617	80	0.615	124	0.611
40	0.614	84	0.615	128	0.610


**Figure C.16. MCP #1 pressure drop**



**Table C.17. MCP #2 pressure drop**

Time, s	Pressure, MPa	Time, s	Pressure, MPa	Time, s	Pressure, MPa
0	0.469	44	0.596	88	0.605
4	0.475	48	0.600	92	0.608
8	0.472	52	0.608	96	0.608
12	0.562	56	0.602	100	0.605
16	0.598	60	0.601	104	0.607
20	0.600	64	0.601	108	0.615
24	0.611	68	0.603	112	0.597
28	0.595	72	0.588	116	0.594
32	0.608	76	0.604	120	0.595
36	0.593	80	0.604	124	0.603
40	0.593	84	0.590	128	0.600


**Figure C.17. MCP #2 pressure drop**



**Table C.18. MCP #3 pressure drop**

Time, s	Pressure, MPa	Time, s	Pressure, MPa	Time, s	Pressure, MPa
0	0.179	44	0.632	88	0.609
4	0.244	48	0.632	92	0.609
8	0.395	52	0.607	96	0.610
12	0.608	56	0.607	100	0.610
16	0.605	60	0.606	104	0.612
20	0.605	64	0.607	108	0.609
24	0.610	68	0.607	112	0.610
28	0.608	72	0.624	116	0.607
32	0.609	76	0.613	120	0.607
36	0.609	80	0.605	124	0.611
40	0.602	84	0.607	128	0.610


**Figure C.18. MCP #3 pressure drop**



**Table C.19. MCP #4 pressure drop**

Time, s	Pressure, MPa	Time, s	Pressure, MPa	Time, s	Pressure, MPa
0	0.500	44	0.610	88	0.602
4	0.535	48	0.609	92	0.607
8	0.522	52	0.607	96	0.611
12	0.564	56	0.569	100	0.626
16	0.600	60	0.607	104	0.600
20	0.599	64	0.645	108	0.581
24	0.608	68	0.605	112	0.620
28	0.634	72	0.571	116	0.607
32	0.599	76	0.603	120	0.607
36	0.607	80	0.578	124	0.606
40	0.608	84	0.603	128	0.610

**Figure C.19. MCP #4 pressure drop**





*Appendix D*

**RELAP5 BASE INPUT**



```

*      2 0 0 1
*      relap5/mod3.2
*      October
*      INRNE
* Safety Group Manager Pavlin Groudev
* VVER - 1000, NPP Kozloduy
* 100% Power
* This problem has four loops for primary side and four loops for
* secondary side.
*=====*
=relap5/mod3 vver-1000
*crdno problem type option
*----1----2----3----4----5----6----7
100      new stdy-st * transnt
101      run
*----1----2----3----4----5----6----7
**crdno time1 time2
*----1----2----3----4----5----6----7
105      1. 3.
*----1----2----3----4----5----6----7
110      nitrogen
115      1.0
*----1----2----3----4----5----6----7
**crdno end time min dt max dt control minor ed major ed restart
*----1----2----3----4----5----6----7
201      200. 1.0-9 0.02 003 100 1000 1000
*----1----2----3----4----5----6----7
*202      1000.0 1.0-6 0.01 003 200 100000 100000
*----1----2----3----4----5----6----7
20800001 dt 0
20800002 dtcrrnt 0
*----1----2----3----4----5----6----7
*
*      * R E A C T O R   V E S S E L *      *
*----1----2----3----4----5----6----7
* 107 upper part of downcomer
*----1----2----3----4----5----6----7
1070000  udca branch
1070001 2 0
1070101 0.5466 0.850 0 0 -90.0 -0.850 4.3-5 0.366 0
1070200 110 16038077. 1248537. 2434747. 0. .00696915
1071101 145050002 107010003 0 0.5 0.7 0001001
1072101 107010002 108010001 0 0.05 0.05 0001000
1071201 10.50314 10.50314 0. * 4484.91
1072201 10.46208 11.07017 0. * 4475.34
*----1----2----3----4----5----6----7
* 207 upper part of downcomer
*----1----2----3----4----5----6----7
2070000  udca branch
2070001 2 0
2070101 0.5466 0.850 0 0 -90.0 -0.850 4.3-5 0.366 0
2070200 110 16038077. 1248683. 2434747. 0. .00696892
2071101 245050002 207010003 0 0.5 0.7 0001001
2072101 207010002 208010001 0 0.05 0.05 0001000
2071201 10.48974 10.48974 0. * 4478.88
2072201 10.46239 11.07047 0. * 4475.17
*----1----2----3----4----5----6----7
* 327 upper part of downcomer
*----1----2----3----4----5----6----7
3270000  udca branch
3270001 2 0
3270101 0.5466 0.850 0 0 -90.0 -0.850 4.3-5 0.366 0
3270200 110 16038077. 1248658. 2434747. 0. .00696892
3271101 345050002 327010003 0 0.5 0.7 0001001
3272101 327010002 308010001 0 0.05 0.05 0001000
3271201 10.48975 10.48975 0. * 4478.92
3272201 10.46232 11.0704 0. * 4475.19
*----1----2----3----4----5----6----7
* 407 upper part of downcomer
*----1----2----3----4----5----6----7
4070000  udca branch
4070001 2 0
4070101 0.5466 0.850 0 0 -90.0 -0.850 4.3-5 0.366 0
4070200 110 16038077. 1248619. 2434747. 0. .00696891
4071101 445050002 407010003 0 0.5 0.7 0001001
4072101 407010002 408010001 0 0.05 0.05 0001000
4071201 10.4721 10.4721 0. * 4471.48
4072201 10.46222 11.0703 0. * 4475.23
*----1----2----3----4----5----6----7
* 108 lower part of downcomer
*----1----2----3----4----5----6----7
1080000  ldca annulus
1080001 13
1080101 0.5466 2
1080102 0.8 13

```

1080301	0.445	1	1082011	.00696915	11			
1080302	0.75	2	1082012	.00696915	12			
1080303	0.44125	10	1082013	.00696915	13			
1080304	0.29	11	1081300	0				
1080305	0.566	12	1081301	10.4626	10.95408	0.	1 * 4475.34	
1080306	0.967	13	1081302	10.46272	10.99858	0.	2 * 4475.39	
1080601	-90.0	13	1081303	7.43488	7.88111	0.	3 * 4475.4	
1080801	4.0-5 .366	2	1081304	7.43489	7.88107	0.	4 * 4475.42	
1080802	4.0-5 .526	13	1081305	7.4349	7.88103	0.	5 * 4475.43	
1080901	0.0 0.0	12	1081306	7.4349	7.88099	0.	6 * 4475.44	
1081601	0.16287	1	1081307	7.4349	7.88095	0.	7 * 4475.46	
1081602	0.2745	2	1081308	7.4349	7.8809	0.	8 * 4475.47	
1081603	0.2321	10	1081309	7.4349	7.88085	0.	9 * 4475.48	
1081604	0.15254	11	1081310	7.43489	7.88079	0.	10 * 4475.49	
1081605	0.29772	12	1081311	7.4349	7.88076	0.	11 * 4475.51	
1081606	0.50864	13	1081312	7.4349	7.87932	0.	12 * 4475.54	
1082301	4.0-5 .366	2	1081401	0.366	1.0	2.0	1.0	2 * 1520.63
1082302	4.0-5 .526	13	1081402	0.526	1.0	2.0	1.0	12 * 1520.63
1081001	0	13	*-----1-----2-----3-----4-----5-----6-----7					
1081101	0001000	12	* 208 lower part of downcomer					
1081201	110	15998970. 1248541. 2435799. 0. 0. 1	2080000	ldca annulus				
1081202	110	16002588. 1248549. 2435702. 0. 0. 2	2080001	13				
1081203	110	16026774. 1248554. 2435051. 0. 0. 3	2080101	0.5466	2			
1081204	110	16029831. 1248558. 2434969. 0. 0. 4	2080102	0.8	13			
1081205	110	16032887. 1248562. 2434887. 0. 0. 5	2080301	0.445	1			
1081206	110	16035943. 1248565. 2434805. 0. 0. 6	2080302	0.75	2			
1081207	110	1.6039+7 1248567. 2434723. 0. 0. 7	2080303	0.44125	10			
1081208	110	16042055. 1248569. 2434641. 0. 0. 8	2080304	0.29	11			
1081209	110	16045112. 1248571. 2434558. 0. 0. 9	2080305	0.566	12			
1081210	110	16048168. 1248572. 2434476. 0. 0. 10	2080306	0.967	13			
1081211	110	16050700. 1248572. 2434408. 0. 0. 11	2080601	-90.0	13			
1081212	110	16056102. 1248573. 2434263. 0. 0. 12	2080801	4.0-5 .366	2			
1081213	110	16061401. 1248573. 2434121. 0. 0. 13	2080802	4.0-5 .526	13			
1082001	.00696915	1	2080901	0.0 0.0	12			
1082002	.00696915	2	2081601	0.16287	1			
1082003	.00696915	3	2081602	0.2745	2			
1082004	.00696915	4	2081603	0.2321	10			
1082005	.00696915	5	2081604	0.15254	11			
1082006	.00696915	6	2081605	0.29772	12			
1082007	.00696915	7	2081606	0.50864	13			
1082008	.00696915	8	2082301	4.0-5 .366	2			
1082009	.00696915	9	2082302	4.0-5 .526	13			
1082010	.00696915	10						

2081001	0		13		
2081101	0001000		12		
2081201	110	15998970.	1248686.	2435799. 0. 0. 1	
2081202	110	16002588.	1248694.	2435702. 0. 0. 2	
2081203	110	16026774.	1248699.	2435051. 0. 0. 3	
2081204	110	16029831.	1248703.	2434969. 0. 0. 4	
2081205	110	16032887.	1248707.	2434887. 0. 0. 5	
2081206	110	16035943.	1248710.	2434805. 0. 0. 6	
2081207	110	1.6039+7	1248712.	2434723. 0. 0. 7	
2081208	110	16042055.	1248714.	2434641. 0. 0. 8	
2081209	110	16045112.	1248716.	2434558. 0. 0. 9	
2081210	110	16048168.	1248716.	2434476. 0. 0. 10	
2081211	110	16050700.	1248717.	2434408. 0. 0. 11	
2081212	110	16056102.	1248718.	2434263. 0. 0. 12	
2081213	110	16061401.	1248718.	2434121. 0. 0. 13	
2082001	.00696892		1		
2082002	.00696892		2		
2082003	.00696892		3		
2082004	.00696892		4		
2082005	.00696892		5		
2082006	.00696892		6		
2082007	.00696892		7		
2082008	.00696892		8		
2082009	.00696892		9		
2082010	.00696892		10		
2082011	.00696892		11		
2082012	.00696892		12		
2082013	.00696892		13		
2081300	0				
2081301	10.46292	10.9544	0.	1 * 4475.17	
2081302	10.46285	10.9987	0.	2 * 4475.14	
2081303	7.43494	7.88116	0.	3 * 4475.13	
2081304	7.43491	7.88108	0.	4 * 4475.125	
2081305	7.43488	7.881	0.	5 * 4475.12	
2081306	7.43484	7.88092	0.	6 * 4475.11	
2081307	7.43481	7.88084	0.	7 * 4475.1	
2081308	7.43477	7.88076	0.	8 * 4475.09	
2081309	7.43473	7.88067	0.	9 * 4475.08	
2081310	7.4347	7.88059	0.	10 * 4475.075	
2081311	7.43466	7.8805	0.	11 * 4475.06	
2081312	7.43458	7.87898	0.	12 * 4475.04	
2081401	0.366	1.0	2.0	1.0	1 * 1520.63
2081402	0.526	1.0	2.0	1.0	12 * 1520.63

*-----1-----2-----3-----4-----5-----6-----7						
* 308 lower part of downcomer						
*-----1-----2-----3-----4-----5-----6-----7						
3080000	ldca annulus					
3080001	13					
3080101	0.5466		2			
3080102	0.8		13			
3080301	0.445		1			
3080302	0.75		2			
3080303	0.44125		10			
3080304	0.29		11			
3080305	0.566		12			
3080306	0.967		13			
3080601	-90.0		13			
3080801	4.0-5	0.366		2		
3080802	4.0-5	0.526		13		
3080901	0.0	0.0		12		
3081601	0.16287		1			
3081602	0.2745		2			
3081603	0.2321		10			
3081604	0.15254		11			
3081605	0.29772		12			
3081606	0.50864		13			
3082301	4.0-5	.366		2		
3082302	4.0-5	.526		13		
3081001	0		13			
3081101	0001000		12			
3081201	110	15998970.	1248661.	2435799. 0. 0. 1		
3081202	110	16002588.	1248670.	2435702. 0. 0. 2		
3081203	110	16026774.	1248674.	2435051. 0. 0. 3		
3081204	110	16029831.	1248678.	2434969. 0. 0. 4		
3081205	110	16032887.	1248682.	2434887. 0. 0. 5		
3081206	110	16035943.	1248685.	2434805. 0. 0. 6		
3081207	110	1.6039+7	1248688.	2434723. 0. 0. 7		
3081208	110	16042055.	1248690.	2434641. 0. 0. 8		
3081209	110	16045112.	1248691.	2434558. 0. 0. 9		
3081210	110	16048168.	1248692.	2434476. 0. 0. 10		
3081211	110	16050700.	1248692.	2434408. 0. 0. 11		
3081212	110	16056102.	1248694.	2434263. 0. 0. 12		
3081213	110	16061401.	1248694.	2434121. 0. 0. 13		
3082001	.00696892		1			
3082002	.00696892		2			
3082003	.00696892		3			

3082004	.00696892	4	4081602	0.2745	2		
3082005	.00696892	5	4081603	0.2321	10		
3082006	.00696892	6	4081604	0.15254	11		
3082007	.00696892	7	4081605	0.29772	12		
3082008	.00696892	8	4081606	0.50864	13		
3082009	.00696892	9	4082301	4.0-5 .366	2		
3082010	.00696892	10	4082302	4.0-5 .526	13		
3082011	.00696892	11	4081001	0	13		
3082012	.00696892	12	4081101	0001000	12		
3082013	.00696892	13	4081201	110	15998970. 1248623. 2435799. 0. 0. 1		
3081300	0		4081202	110	16002588. 1248631. 2435702. 0. 0. 2		
3081301	10.46286	10.95433	0.	1 * 4475.19	4081203	110	16026774. 1248636. 2435051. 0. 0. 3
3081302	10.4628	10.99866	0.	2 * 4475.17	4081204	110	16029831. 1248640. 2434969. 0. 0. 4
3081303	7.43491	7.88113	0.	3 * 4475.17	4081205	110	16032887. 1248643. 2434887. 0. 0. 5
3081304	7.43489	7.88106	0.	4 * 4475.16	4081206	110	16035943. 1248646. 2434805. 0. 0. 6
3081305	7.43486	7.88099	0.	5 * 4475.16	4081207	110	1.6039+7 1248649. 2434723. 0. 0. 7
3081306	7.43484	7.88092	0.	6 * 4475.15	4081208	110	16042055. 1248651. 2434641. 0. 0. 8
3081307	7.43481	7.88084	0.	7 * 4475.15	4081209	110	16045112. 1248652. 2434558. 0. 0. 9
3081308	7.43478	7.88076	0.	8 * 4475.14	4081210	110	16048168. 1248653. 2434476. 0. 0. 10
3081309	7.43475	7.88068	0.	9 * 4475.14	4081211	110	16050700. 1248654. 2434408. 0. 0. 11
3081310	7.43472	7.8806	0.	10 * 4475.134	4081212	110	16056102. 1248655. 2434263. 0. 0. 12
3081311	7.43468	7.88053	0.	11 * 4475.13	4081213	110	16061401. 1248655. 2434121. 0. 0. 13
3081312	7.43462	7.87902	0.	12 * 4475.12	4082001	.00696892	1
3081401	0.366	1.0	2.0	1.0	4082002	.00696891	2
3081402	0.526	1.0	2.0	1.0	4082003	.00696891	3
*-----1-----2-----3-----4-----5-----6-----7			4082004	.00696891	4		
* 408 lower part of downcomer			4082005	.00696891	5		
*-----1-----2-----3-----4-----5-----6-----7			4082006	.00696891	6		
4080000	ldca annulus		4082007	.00696891	7		
4080001	13		4082008	.00696891	8		
4080101	0.5466	2	4082009	.00696891	9		
4080102	0.8	13	4082010	.00696891	10		
4080301	0.445	1	4082011	.00696891	11		
4080302	0.75	2	4082012	.00696891	12		
4080303	0.44125	10	4082013	.00696891	13		
4080304	0.29	11	4081300	0			
4080305	0.566	12	4081301	10.46276	10.95423	0.	1 * 4475.23
4080306	0.967	13	4081302	10.46273	10.9986	0.	2 * 4475.23
4080601	-90.0	13	4081303	7.43487	7.8811	0.	3 * 4475.23
4080801	4.0-5 .366	2	4081304	7.43486	7.88104	0.	4 * 4475.23
4080802	4.0-5 .526	13	4081305	7.43484	7.88097	0.	5 * 4475.23
4080901	0.0 0.0	12	4081306	7.43483	7.88091	0.	6 * 4475.23
4081601	0.16287	1	4081307	7.43481	7.88085	0.	7 * 4475.23

4081308 7.43479 7.88078 0. 8 \* 4475.23  
 4081309 7.43477 7.88071 0. 9 \* 4475.23  
 4081310 7.43474 7.88064 0. 10 \* 4475.23  
 4081311 7.43472 7.88058 0. 11 \* 4475.23  
 4081312 7.43468 7.87909 0. 12 \* 4475.24  
 4081401 0.366 1.0 2.0 1.0 1 \* 1520.63  
 4081402 0.526 1.0 2.0 1.0 12 \* 1520.63  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 116 Appendix of downcomer  
 \*-----1-----2-----3-----4-----5-----6-----7  
 1160000 udca branch  
 1160001 1 0  
 1160101 0.00 0.95000 0.5058 0 90.0 0.95000 4.3-5 0.356 0  
 1160200 110 16031430. 1255905. 2434926. 0. .00696864  
 1161101 116010001 107010001 0 0. 0. 100  
 1161201 -.01101321 -.01181298 0. \* -3.314757  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 216 Appendix of downcomer  
 \*-----1-----2-----3-----4-----5-----6-----7  
 2160000 udca branch  
 2160001 1 0  
 2160101 0.00 0.95000 0.5058 0 90.0 0.95000 4.3-5 0.356 0  
 2160200 110 16031430. 1256041. 2434926. 0. .00696835  
 2161101 216010001 207010001 0 0. 0. 100  
 2161201 -.0110136 -.01181342 0. \* -3.31465  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 316 Appendix of downcomer  
 \*-----1-----2-----3-----4-----5-----6-----7  
 3160000 udca branch  
 3160001 1 0  
 3160101 0.00 0.95000 0.5058 0 90.0 0.95000 4.3-5 0.356 0  
 3160200 110 16031430. 1256019. 2434926. 0. .00696835  
 3161101 316010001 327010001 0 0. 0. 100  
 3161201 -.01101354 -.01181334 0. \* -3.31467  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 416 Appendix of downcomer  
 \*-----1-----2-----3-----4-----5-----6-----7  
 4160000 udca branch  
 4160001 1 0  
 4160101 0.0 0.95000 0.5058 0 90.0 0.95000 4.3-5 0.356 0  
 4160200 110 16031430. 1255983. 2434926. 0. .00696834  
 4161101 416010001 407010001 0 0. 0. 100  
 4161201 -.01101343 -.01181322 0. \* -3.314695

\*-----1-----2-----3-----4-----5-----6-----7  
 \* 830 lower plenum - mixing cammer  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \*crdno name type  
 8300000 lplenum branch  
 8300001 3 0  
 8300101 0.0 0.56600 5.352 0. 90.0 0.56600 4.3-5 0.0 0  
 8300200 110 15967053. 1248658. 2436659. 0. .00696897  
 8301101 830010002 843010001 0 3.2 3.25 0011000  
 8302101 830010002 845010001 0 3.2 3.25 0011000  
 8303101 830010002 842010001 0 3.2 3.25 0011000  
 8301201 4.46199 4.97555 0. \* 15886.  
 8302201 3.79407 4.14451 0. \* 1488.927  
 8303201 3.72233 4.02448 0. \* 526.01  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 829 lower plenum - elept. botom  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \*crdno name type  
 8290000 lplenum branch  
 8290001 5 0  
 8290101 0.0 .96700 3.5757 0. 90.0 .96700 4.3-5 0.0 0  
 8290200 110 16023877. 1248660. 2435129. 0. .00696897  
 8291101 108130004 829010003 0.8 2.5 2.6 0031003  
 8292101 208130004 829010003 0.8 2.5 2.6 0031003  
 8293101 308130004 829010003 0.8 2.5 2.6 0031003  
 8294101 408130004 829010003 0.8 2.5 2.6 0031003  
 8295101 829010002 830010001 3.2 3.3 3.4 0001000  
 8291201 7.4345 7.4345 0. \* 4475.33  
 8292201 7.43474 7.43474 0. \* 4475.17  
 8293201 7.4347 7.4347 0. \* 4475.2  
 8294201 7.43464 7.43464 0. \* 4475.24  
 8295201 7.435 8.0732 0. \* 17900.93  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* Reactor Core  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 843 core - average channel  
 \*-----1-----2-----3-----4-----5-----6-----7  
 8430000 core pipe  
 8430001 10  
 8430101 4.44985 1  
 8430102 3.8165 9  
 8430103 7.5192 10  
 8430301 0.29000 1

8430302	0.44125	9
8430303	0.75000	10
8430601	90.0	10
8430801	4.4-5 0.3	1
8430802	1.50-5 0.00964	9
8430803	4.4-5 0.3	10
8430901	0.52 0.52	9
8431001	100	10
8431101	0001000	9
8431201	110	15956308. 1248658. 2436949. 0. 0. 1
8431202	110	15935335. 1265960. 2437516. 0. 0. 2
8431203	110	15915043. 1289233. 2438064. 0. 0. 3
8431204	110	15894540. 1313326. 2438577. 0. 0. 4
8431205	110	15873852. 1337172. 2439059. 0. 0. 5
8431206	110	15852977. 1360240. 2439546. 0. 0. 6
8431207	110	15831914. 1382635. 2440038. 0. 0. 7
8431208	110	15810666. 1401763. 2440535. 0. 0. 8
8431209	110	15789274. 1414688. 2441036. 0. 0. 9
8431210	110	15770194. 1414680. 2441484. 0. 0. 10
8432001	.00696897	1
8432002	.00696897	2
8432003	.00696897	3
8432004	.00696897	4
8432005	.00696897	5
8432006	.00696897	6
8432007	.00696897	7
8432008	.00696897	8
8432009	.00696897	9
8432010	.00696897	10
8431300	0	
8431301	5.71084	5.71084 0. 1 * 15886.
8431302	5.75831	5.75831 0. 2 * 15886.
8431303	5.82564	5.82564 0. 3 * 15886.
8431304	5.89825	5.89825 0. 4 * 15886.
8431305	5.974	5.974 0. 5 * 15886.
8431306	6.05149	6.05149 0. 6 * 15886.
8431307	6.12939	6.12939 0. 7 * 15886.
8431308	6.20076	6.20076 0. 8 * 15886.
8431309	6.5808	6.5808 0. 9 * 15886.
8431401	0.3	1.0 2.0 1.0 1 * 1520.63
8431402	0.0106	1.0 2.0 1.0 8 * 1520.63
8431403	0.3	1.0 2.0 1.0 9 * 1520.63

\*----1----2----3----4----5----6----7

\* Hot channel - 845-14 assemblies 8.589%, 8.3313%  
 \*----1----2----3----4----5----6----7  
 8450000 core pipe  
 8450001 10  
 8450101 .4181 1  
 8450102 .3586 9  
 8450103 .77238 10  
 8450301 0.29000 1  
 8450302 0.44125 9  
 8450303 0.75000 10  
 8450601 90.0 10  
 8450801 4.4-5 0.3 1  
 8450802 1.5-5 0.00964 9  
 8450803 4.4-5 0.3 10  
 8450901 0.52 0.52 9  
 8451001 100 10  
 8451101 0001000 9  
 8451201 110 15958845. 1248658. 2436881. 0. 0. 1  
 8451202 110 15937977. 1271654. 2437444. 0. 0. 2  
 8451203 110 15917685. 1302584. 2437993. 0. 0. 3  
 8451204 110 15897104. 1334601. 2438517. 0. 0. 4  
 8451205 110 15876266. 1366281. 2439003. 0. 0. 5  
 8451206 110 15855159. 1396921. 2439495. 0. 0. 6  
 8451207 110 15833779. 1426650. 2439995. 0. 0. 7  
 8451208 110 15812109. 1452042. 2440502. 0. 0. 8  
 8451209 110 15790226. 1469195. 2441014. 0. 0. 9  
 8451210 110 15770759. 1469195. 2441470. 0. 0. 10  
 8452001 .00696897 1  
 8452002 .00696897 2  
 8452003 .00696897 3  
 8452004 .00696897 4  
 8452005 .00696897 5  
 8452006 .00696897 6  
 8452007 .00696897 7  
 8452008 .00696897 8  
 8452009 .00696897 9  
 8452010 .00696897 10  
 8451300 0  
 8451301 5.69651 5.69651 0. 1 \* 1488.927  
 8451302 5.75987 5.75987 0. 2 \* 1488.927  
 8451303 5.85098 5.85098 0. 3 \* 1488.927  
 8451304 5.95042 5.95042 0. 4 \* 1488.927  
 8451305 6.05643 6.05643 0. 5 \* 1488.927

8451306	6.16631	6.16631	0.	6 * 1488.927	8422009	.00696897	9			
8451307	6.28162	6.28162	0.	7 * 1488.927	8422010	.00696897	10			
8451308	6.38641	6.38641	0.	8 * 1488.927	8421300	0				
8451309	6.80265	6.80265	0.	9 * 1488.927	8421301	5.58891	5.91884	0.	1 * 526.01	
8451401	0.3	1.0	2.0	1.0	1 * 1520.63	8421302	5.5891	5.5891	0.	2 * 526.01
8451402	0.0106	1.0	2.0	1.0	8 * 1520.63	8421303	5.58929	5.58929	0.	3 * 526.01
8451403	0.3	1.0	2.0	1.0	9 * 1520.63	8421304	5.58949	5.58949	0.	4 * 526.01
*-----1-----2-----3-----4-----5-----6-----7					8421305	5.58968	5.58968	0.	5 * 526.01	
* 842 bypass					8421306	5.58988	5.58988	0.	6 * 526.01	
*-----1-----2-----3-----4-----5-----6-----7					8421307	5.59007	5.59007	0.	7 * 526.01	
8420000 core pipe					8421308	5.59026	5.59026	0.	8 * 526.01	
8420001	10				8421309	5.88544	6.22669	0.	9 * 526.01	
8420101	0.14604		1		8421401	0.3	1.0	2.0	1.0	1 * 1520.63
8420102	.1253		9		8421402	0.009	1.0	2.0	1.0	8 * 1520.63
8420103	.11883		10		8421403	0.3	1.0	2.0	1.0	9 * 1520.63
8420301	0.29000		1		*-----1-----2-----3-----4-----5-----6-----7					
8420302	0.44125		9		* 850 upper mixing volume					
8420303	0.75000		10		*-----1-----2-----3-----4-----5-----6-----7					
8420601	90.0		10		8500000 uplenum branch					
8420801	4.4-5 0.3		1		8500001 4 0					
8420802	1.5-5 0.00964		9		8500101 0.0 0.44500 3.68976 0 90.0 0.44500 4.2-5 0.0 0					
8420803	4.4-5 0.3		10		8500200 110 15742177. 1414351. 2442141. 0. .00696897					
8420901	0.52 0.52		9		*crdno from to area floss rloss flag					
8421001	0		10		8501101 843100002 850010001 3.51217 1.4 1.5 0101000					
8421101	0001000		9		8502101 850010002 855010001 0.0 1.3 1.4 0001000					
8421201	110	15959294. 1248658. 2436869. 0. 0. 1			8503101 845100002 850010001 .33 1.4 1.5 0101000					
8421202	110	15937893. 1248674. 2437446. 0. 0. 2			8504101 842100002 850010001 .11883 1.4 1.5 0101000					
8421203	110	15916250. 1248690. 2438031. 0. 0. 3			8501201 6.58118 6.58118 0. * 15886.					
8421204	110	15894606. 1248706. 2438575. 0. 0. 4			8502201 2.010203 2.385275 0. * 17900.93					
8421205	110	15872962. 1248722. 2439080 0. 0. 5			8503201 6.80316 6.80316 0. * 1488.927					
8421206	110	15851318. 1248738. 2439585. 0. 0. 6			8504201 5.88557 6.25179 0. * 526.01					
8421207	110	15829673. 1248754. 2440091. 0. 0. 7			*-----1-----2-----3-----4-----5-----6-----7					
8421208	110	15808027. 1248770. 2440597. 0. 0. 8			* 855 down part of upper volume					
8421209	110	15786381. 1248785. 2441104. 0. 0. 9			*-----1-----2-----3-----4-----5-----6-----7					
8421210	110	15767748. 1248785. 2441541. 0. 0. 10			8550000 core_up pipe					
8422001	.00696897		1		8550001 2					
8422002	.00696897		2		8550101 8.2916		2			
8422003	.00696897		3		8550301 0.85000		1			
8422004	.00696897		4		8550302 0.95000		2			
8422005	.00696897		5		8550601 90.0		2			
8422006	.00696897		6		8550801 4.2-5 0.0		2			
8422007	.00696897		7		8550901 0.4 0.45		1			
8422008	.00696897		8		8551001 0		2			

8551101 0001000 1  
 8551201 110 15736695. 1414346. 2442270. 0. 0. 1  
 8551202 110 15730625. 1414340. 2442413. 0. 0. 2  
 8552001 .00696897 1  
 8552002 .00696896 2  
 8551300 0  
 8551301 2.01022 2.385367 0. 1 \* 17900.93  
 \*-----1----2----3----4----5----6----7  
 \* 860 upper volume  
 \*-----1----2----3----4----5----6----7  
 8600000 uplumen branch  
 8600001 5 0  
 8600101 0.0 0.85000 10.04532 0 90.0 .85000 4.2-5 0.0 0  
 8600200 110 15724626. 1414223. 2442554. 0. .00696896  
 \*crdno from to area floss rlloss flag  
 8601101 860010004 446010001 0.5675 0.10 0.15 0001002  
 8602101 860010004 146010001 0.5675 0.10 0.15 0001002  
 8603101 860010004 246010001 0.5675 0.10 0.15 0001002  
 8604101 860010004 346010001 0.5675 0.10 0.15 0001002  
 8605101 855020002 860010001 0. 0.25 .35 0001000  
 8601201 11.478 11.478 0. \* 4477.64  
 8602201 11.4804 11.4804 0. \* 4478.57  
 8603201 11.48118 11.4818 0. \* 4478.88  
 8604201 11.4813 11.4813 0. \* 4478.92  
 8605201 2.181915 2.56975 0. \* 17900.94  
 \*-----1----2----3----4----5----6----7  
 \* 870 upper part of upper volume  
 \*-----1----2----3----4----5----6----7  
 8700000 free-vol branch  
 8700001 1 0  
 8700101 0.0 2.0 17.33224 .0 90. 2.0  
 8700102 4.0-5 0.0 00  
 8700200 110 15716146. 1407376. 2442753. 0. .00695048 \*  
 8701101 860010002 870010001 0.0 0.1 0.1 0001000  
 8701201 5.01044-5 5.01316-5 0. \*.1722118  
 \*-----1----2----3----4----5----6----7  
 \* 880 upper volume below reactor head  
 \*-----1----2----3----4----5----6----7  
 8800000 free-vol branch  
 8800001 1 0  
 8800101 0.0 1.235 8.9 .0 90. 1.235  
 8800102 4.0-5 0.0 00  
 8800200 110 15705243. 1425958. 2443010. 0. .00695  
 8801101 870010002 880010001 0.0 0.1 0.1 0001000  
 8801201 4.98199-5 4.98468-5 0. \*.1719627  
 \*-----1----2----3----4----5----6----7  
 \* Connection between down commer and outlet nozles  
 \*-----1----2----3----4----5----6----7  
 5610000 connec1 mtpljun  
 5610001 4 0  
 5610011 116010002 860010001 0.00035 5. 5. 001000  
 5610012 1.0 1.0 1.0 100000000 000000000 0 4  
 5611011 12.63057 12.63057 1 \* 3.31479  
 5611021 12.63097 12.63098 2 \* 3.31468  
 5611031 12.6309 12.6309 3 \* 3.314696  
 5611041 12.6308 12.6308 4 \* 3.31472  
 5612011 0.0001 0.0 1.0 1.0 4  
 \*-----1----2----3----4----5----6----7  
 \* Crossflow connection in down commer  
 \*-----1----2----3----4----5----6----7  
 1530000 connec1 mtpljun  
 1530001 13 0  
 1530011 108010004 208010003 0. 0.3 0.3 001003  
 1530012 1.0 1.0 1.0 000010000 000010000 0 13  
 1531011 .003947944 .003947944 1 \* .322594  
 1531021 .00532104 .00532104 2 \* .4347924  
 1531031 .00417762 .00417762 3 \* .467107  
 1531041 .0041834 .0041834 4 \* .467754  
 1531051 .00418405 .00418405 5 \* .467827  
 1531061 .00418535 .00418535 6 \* .467974  
 1531071 .00418451 .00418451 7 \* .4678815  
 1531081 .00418993 .00418993 8 \* .468489  
 1531091 .004176 .004176 9 \* .466932  
 1531101 .00421914 .00421914 10 \* .471758  
 1531111 .002638923 .002638923 11 \* .295069  
 1531121 .00788192 .00788192 12 \* .881315  
 1531131 2.28188-4 2.28188-4 13 \* .1373618  
 1532011 0.52 0.0 1.0 1.0 13  
 \*-----1----2----3----4----5----6----7  
 \* Crossflow connection in down commer  
 \*-----1----2----3----4----5----6----7  
 1540000 connec1 mtpljun  
 1540001 13 0  
 1540011 208010004 308010003 0. 0.3 0.3 001003  
 1540012 1.0 1.0 1.0 000010000 000010000 0 13  
 1541011 .00394952 .00394952 1 \* .322701

1541021 .00562994 .00562994 2 \* .460003  
 1541031 .00426467 .00426467 3 \* .476808  
 1541041 .00426479 .00426479 4 \* .476821  
 1541051 .0042648 .0042648 5 \* .4768235  
 1541061 .0042648 .0042648 6 \* .476825  
 1541071 .00426474 .00426474 7 \* .476819  
 1541081 .0042647 .0042647 8 \* .476816  
 1541091 .00426424 .00426424 9 \* .476766  
 1541101 .00426361 .00426361 10 \* .476698  
 1541111 .00276 .00276 11 \* .3085857  
 1541121 .00805219 .00805219 12 \* .900292  
 1541131 1.488061-5 1.488061-5 13 \* .00895704  
 1542011 0.52 0.0 1.0 1.0 13  
 \*----1----2----3----4----5----6----7  
 \* Crossflow connection in down commer  
 \*----1----2----3----4----5----6----7  
 1550000 connec1 mtpljun  
 1550001 13 0  
 1550011 308010004 408010003 0. 0.3 0.3 001003  
 1550012 1.0 1.0 1.0 000010000 000010000 0 13  
 1551011 .00393116 .00393116 1 \* .3212044  
 1551021 .00586485 .00586485 2 \* .479202  
 1551031 .00431444 .00431444 3 \* .482378  
 1551041 .00431133 .00431133 4 \* .482031  
 1551051 .004311 .004311 5 \* .481995  
 1551061 .00431026 .00431026 6 \* .481913  
 1551071 .004310635 .004310635 7 \* .481956  
 1551081 .00430748 .00430748 8 \* .481605  
 1551091 .00431468 .00431468 9 \* .482412  
 1551101 .00428905 .00428905 10 \* .479547  
 1551111 .00282982 .00282982 11 \* .3163955  
 1551121 .00814878 .00814878 12 \* .911102  
 1551131 -1.19309-4 -1.19309-4 13 \* -.0718174  
 1552011 0.52 0.0 1.0 1.0 13  
 \*----1----2----3----4----5----6----7  
 \* Crossflow connection in down commer  
 \*----1----2----3----4----5----6----7  
 1560000 connec1 mtpljun  
 1560001 13 0  
 1560011 108010003 408010004 0. 0.3 0.3 001003  
 1560012 1.0 1.0 1.0 000010000 000010000 0 13  
 1561011 -.00388778 -.00388778 1 \* -.317666  
 1561021 -.00595984 -.00595984 2 \* -.486972

1561031 -.00430546 -.00430546 3 \* -.4813825  
 1561041 -.00430294 -.00430294 4 \* -.481101  
 1561051 -.00430269 -.00430269 5 \* -.481075  
 1561061 -.00430209 -.00430209 6 \* -.481009  
 1561071 -.004302404 -.004302404 7 \* -.481045  
 1561081 -.00429983 -.00429983 8 \* -.480759  
 1561091 -.0043057 -.0043057 9 \* -.481416  
 1561101 -.00428441 -.00428441 10 \* -.479038  
 1561111 -.002817344 -.002817344 11 \* -.3150066  
 1561121 -.00813191 -.00813191 12 \* -.909233  
 1561131 1.23975-4 1.23975-4 13 \* .074629  
 1562011 0.52 0.0 1.0 1.0 13  
 \*----1----2----3----4----5----6----7  
 \* Crossflow connection  
 \*----1----2----3----4----5----6----7  
 1570000 junct1 sngljun  
 1570101 107010004 207010003 0.16 0.3 0.3 0001003  
 1570110 0.52 0. 1. 1.  
 1570201 0 .01411397 .01411397 0. \* 1.69921  
 \*----1----2----3----4----5----6----7  
 \* Crossflow connection  
 \*----1----2----3----4----5----6----7  
 1580000 junct2 sngljun  
 1580101 207010004 327010003 0.16 0.3 0.3 0001003  
 1580110 0.52 0. 1. 1.  
 1580201 0 .0174236 .0174236 0. \* 2.09752  
 \*----1----2----3----4----5----6----7  
 \* Crossflow connection  
 \*----1----2----3----4----5----6----7  
 1590000 junct3 sngljun  
 1590101 327010004 407010003 0.16 0.3 0.3 0001003  
 1590110 0.52 0. 1. 1.  
 1590201 0 .02088496 .02088496 0. \* 2.51424  
 \*----1----2----3----4----5----6----7  
 \* Crossflow connection  
 \*----1----2----3----4----5----6----7  
 1600000 junct4 sngljun  
 1600101 407010004 107010003 0.16 0.3 0.3 0001003  
 1600110 0.52 0. 1. 1.  
 1600201 0 -.03780566 -.03780566 0. \* -.45515  
 \*----1----2----3----4----5----6----7  
 \* 146  
 \*----1----2----3----4----5----6----7

1460000 hlega branch  
 1460001 1 0  
 1460101 0.5675 1.64 0 0 0.0 0.0 4.5-5 0.0 0  
 1460200 110 15656317. 1414221. 2444163. 0. .00696896  
 1461101 146010002 140010001 0.5675 0.0 0.0 0001000  
 1461201 11.48194 11.48194 0. \* 4478.57  
 \*----1----2----3----4----5----6----7  
 \* 140  
 \*----1----2----3----4----5----6----7  
 1400000 hlega branch  
 1400001 1 0  
 1400101 0.5675 5.87 0 0 0.0 0.0 4.5-5 0.0 0  
 1400200 110 15654351. 1414175. 2444209. 0. .0069692  
 1401101 140010002 141010001 0.5675 0.0 0.0 0001000  
 1401201 11.48327 11.48327 0. \* 4479.2  
 \*----1----2----3----4----5----6----7  
 \* 141  
 \*----1----2----3----4----5----6----7  
 1410000 hot-leg pipe  
 1410001 3  
 1410101 0.5675 2  
 1410102 0.546 3  
 1410301 1.71400 1  
 1410302 1.54000 2  
 1410303 0.67000 3  
 1410601 0.0 1  
 1410602 90.0 2  
 1410603 90.0 3  
 1410801 4.5-5 0.85 3  
 1410901 .50 .5 1  
 1410902 .0 .0 2  
 1411001 0 3  
 1411101 0001000 2  
 1411201 110 15652181. 1414176. 2444260. 0. 0. 1  
 1411202 110 1.5637+7 1414177. 2444619. 0. 0. 2  
 1411203 110 15615815. 1414177. 2445119. 0. 0. 3  
 1412001 .0069692 1  
 1412002 .0069692 2  
 1412003 .0069692 3  
 1411300 0  
 1411301 11.48333 11.48333 0. 1 \* 4479.2  
 1411302 11.48368 12.1123 0. 2 \* 4479.2  
 \*----1----2----3----4----5----6----7

\* Cold leg, loop # 1  
 \*----1----2----3----4----5----6----7  
 \* 142  
 \*----1----2----3----4----5----6----7  
 1420000 cold-leg pipe  
 1420001 7  
 1420101 0.546 1  
 1420102 0.5675 7  
 1420301 0.67000 1  
 1420302 3.34000 2  
 1420303 3.26000 3  
 1420304 1.94670 4  
 1420305 1.94670 5  
 1420306 1.94670 6  
 1420307 3.26000 7  
 1420601 -90.0 1  
 1420602 -90.0 3  
 1420603 0.0 6  
 1420604 90.0 7  
 1420801 4.5-5 0.85 7  
 1420901 0.0 0.0 2  
 1420902 0.5 0.5 3  
 1420903 0.0 0.0 5  
 1420904 0.5 0.5 6  
 1421001 0 7  
 1421101 0001000 6  
 1421201 110 15444803. 1248350. 2449182. 0. 0. 1  
 1421202 110 15456869. 1248219. 2448894. 0. 0. 2  
 1421203 110 15456869. 1248219. 2448894. 0. 0. 3  
 1421204 110 15456869. 1248219. 2448894. 0. 0. 4  
 1421205 110 15461203. 1248224. 2448791. 0. 0. 5  
 1421206 110 15461203. 1248224. 2448791. 0. 0. 6  
 1421207 110 15430132. 1248225. 2449532. 0. 0. 7  
 1422001 .00696919 1  
 1422002 .00696916 2  
 1422003 .00696916 3  
 1422004 .00696916 7  
 1421300 0  
 1421301 10.49648 11.11749 0. 1 \* 4479.2  
 1421302 10.51012 11.13133 0. 3 \* 4485.365  
 1421303 10.51009 10.51009 0. 6 \* 4485.365  
 \*----1----2----3----4----5----6----7  
 \* 145

\*-----1-----2-----3-----4-----5-----6-----7  
 1450000 clega pipe  
 1450001 5  
 1450101 0.5675 5  
 1450301 2.3080 5  
 1450601 0.0 5  
 1450801 4.5-5 0.85 5  
 1450901 .05 .05 1  
 1450902 .05 .05 2  
 1450903 .05 .05 3  
 1450904 .05 .05 4  
 1451001 0 5  
 1451101 0001000 4  
 1451201 110 16030824. 1248669. 2434942. 0. 0. 1  
 1451202 110 16027641. 1248670. 2435028. 0. 0. 2  
 1451203 110 16024433. 1248672. 2435114. 0. 0. 3  
 1451204 110 16021225. 1248673. 2435200. 0. 0. 4  
 1451205 110 16018017. 1248675. 2435287. 0. 0. 5  
 1452001 .00696893 1  
 1452002 .00696893 2  
 1452003 .00696893 3  
 1452004 .00696893 4  
 1452005 .00696892 5  
 1451300 0  
 1451301 10.48955 10.48955 0. 1 \* 4478.88  
 1451302 10.4896 10.4896 0. 2 \* 4478.88  
 1451303 10.48965 10.48965 0. 3 \* 4478.88  
 1451304 10.4897 10.4897 0. 4 \* 4478.88  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* Hot leg, loop #2  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 246  
 \*-----1-----2-----3-----4-----5-----6-----7  
 2460000 hlega branch  
 2460001 1 0  
 2460101 0.5675 1.64 0 0 0.0 0.0 4.5-5 0.0 0  
 2460200 110 15656308. 1414221. 2444163. 0. .00696896  
 2461101 246010002 240010001 0.5675 0.0 0.0 0.0 0001000  
 2461201 11.48273 11.48273 0. \* 4478.88  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 240  
 \*-----1-----2-----3-----4-----5-----6-----7  
 2400000 hlega branch

2400001 1 0  
 2400101 0.5675 5.87 0 0 0.0 0.0 4.5-5 0.0 0  
 2400200 110 15654343. 1414226. 2444209. 0. .00696896  
 2401101 240010002 241010001 0.5675 0.0 0.0 0.0 0001000  
 2401201 11.48281 11.48281 0. \* 4478.88  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 241  
 \*-----1-----2-----3-----4-----5-----6-----7  
 2410000 hot-leg pipe  
 2410001 3  
 2410101 0.5675 2  
 2410102 0.546 3  
 2410301 1.71400 1  
 2410302 1.54000 2  
 2410303 0.67000 3  
 2410601 0.0 1  
 2410602 90.0 2  
 2410603 90.0 3  
 2410801 4.5-5 0.85 3  
 2410901 .50 .5 1  
 2410902 .0 .0 2  
 2411001 0 3  
 2411101 0001000 2  
 2411201 110 15652181. 1414176. 2444260. 0. 0. 1  
 2411202 110 1.5637+7 1414177. 2444619. 0. 0. 2  
 2411203 110 15615815. 1414177. 2445119. 0. 0. 3  
 2412001 .0069692 1  
 2412002 .0069692 2  
 2412003 .0069692 3  
 2411300 0  
 2411301 11.48333 11.48333 0. 1 \* 4479.2  
 2411302 11.48368 12.1123 0. 2 \* 4479.2  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* Cold leg, loop #2  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 242  
 \*-----1-----2-----3-----4-----5-----6-----7  
 2420000 cold-leg pipe  
 2420001 7  
 2420101 0.546 1  
 2420102 0.5675 7  
 2420301 0.67000 1  
 2420302 3.34000 2

2420303	3.26000	3	2450904	.05	.05	4						
2420304	1.94670	4	2451001	0		5						
2420305	1.94670	5	2451101	0001000		4						
2420306	1.94670	6	2451201	110	16030824.	1248669.	2434942.	0.	0.	1		
2420307	3.26000	7	2451202	110	16027641.	1248670.	2435028.	0.	0.	2		
2420601	-90.0	1	2451203	110	16024433.	1248672.	2435114.	0.	0.	3		
2420602	-90.0	3	2451204	110	16021225.	1248673.	2435200.	0.	0.	4		
2420603	0.0	6	2451205	110	16018017.	1248675.	2435287.	0.	0.	5		
2420604	90.0	7	2452001	.00696893		1						
2420801	4.5-5 0.85	7	2452002	.00696893		2						
2420901	0.0 0.0	2	2452003	.00696893		3						
2420902	0.5 0.5	3	2452004	.00696893		4						
2420903	0.0 0.0	5	2452005	.00696892		5						
2420904	0.5 0.5	6	2451300	0								
2421001	0	7	2451301	10.48955	10.48955	0.	1	*	4478.88			
2421101	0001000	6	2451302	10.4896	10.4896	0.	2	*	4478.88			
2421201	110	15444803.	1248350.	2449182.	0.	0.	1					
2421202	110	15456869.	1248219.	2448894.	0.	0.	2					
2421203	110	15456869.	1248219.	2448894.	0.	0.	3					
2421204	110	15456869.	1248219.	2448894.	0.	0.	4					
2421205	110	15461203.	1248224.	2448791.	0.	0.	5					
2421206	110	15461203.	1248224.	2448791.	0.	0.	6					
2421207	110	15430132.	1248225.	2449532.	0.	0.	7					
2422001	.00696919	1	2451303	10.48965	10.48965	0.	3	*	4478.88			
2422002	.00696916	2	2451304	10.4897	10.4897	0.	4	*	4478.88			
2422003	.00696916	3	*-----1-----2-----3-----4-----5-----6-----7									
2422004	.00696916	7	* Hot leg, loop # 3									
2421300	0	*-----1-----2-----3-----4-----5-----6-----7										
2421301	10.49648	11.11749	0.	1	*	4479.2						
2421302	10.51012	11.13133	0.	3	*	4485.365						
2421303	10.51009	10.51009	0.	6	*	4485.365						
*-----1-----2-----3-----4-----5-----6-----7		*-----1-----2-----3-----4-----5-----6-----7										
* 245		* 340										
*-----1-----2-----3-----4-----5-----6-----7		*-----1-----2-----3-----4-----5-----6-----7										
2450000	clega pipe		3400000	hlega branch								
2450001	5		3400001	1	0							
2450101	0.5675	5	3400101	0.5675	1.64	0	0	0.0	0.0	4.5-5	0.0	0
2450301	2.3080	5	3400200	110	15656307.	1414221.	2444163.	0.	.00696896			
2450601	0.0	5	3461101	346010002	340010001	0.5675	0.0	0.0	0.0001000			
2450801	4.5-5 0.85	5	3461201	11.48284	11.48284	0.	*	4478.92				
2450901	.05 .05	1	*-----1-----2-----3-----4-----5-----6-----7									
2450902	.05 .05	2	* 340									
2450903	.05 .05	3	*-----1-----2-----3-----4-----5-----6-----7									
		3400000	hlega branch									
		3400001	1	0								
		3400101	0.5675	5.87	0	0	0.0	0.0	4.5-5	0.0	0	
		3400200	110	15654342.	1414226.	2444209.	0.	.00696896				
		3401101	340010002	341010001	0.5675	0.0	0.0	0.0001000				
		3401201	11.48292	11.48292	0.	*	4478.924					
		*-----1-----2-----3-----4-----5-----6-----7										
		* 341										
		*-----1-----2-----3-----4-----5-----6-----7										
		3410000	hot-leg pipe									
		3410001	3									

3410101	0.5675	2	3420901	0.0	0.0	2					
3410102	0.546	3	3420902	0.5	0.5	3					
3410301	1.71400	1	3420903	0.0	0.0	5					
3410302	1.54000	2	3420904	0.5	0.5	6					
3410303	0.67000	3	3421001	0		7					
3410601	0.0	1	3421101	0001000		6					
3410602	90.0	2	3421201	110	15444803.	1248350.	2449182.	0.	0.	1	
3410603	90.0	3	3421202	110	15456869.	1248219.	2448894.	0.	0.	2	
3410801	4.5-5	0.85	3	3421203	110	15456869.	1248219.	2448894.	0.	0.	3
3410901	.50	.5	3421204	110	15456869.	1248219.	2448894.	0.	0.	4	
3410902	.0	.0	3421205	110	15461203.	1248224.	2448791.	0.	0.	5	
3411001	0	3	3421206	110	15461203.	1248224.	2448791.	0.	0.	6	
3411001	0001000	2	3421207	110	15430132.	1248225.	2449532.	0.	0.	7	
3411201	110	15652181.	1414176.	2444260.	0.	0.	1				
3411202	110	1.5637+7	1414177.	2444619.	0.	0.	2				
3411203	110	15615815.	1414177.	2445119.	0.	0.	3				
3412001	.0069692	1	3422001	.00696919		1					
3412002	.0069692	2	3422002	.00696916		2					
3412003	.0069692	3	3422003	.00696916		3					
3411300	0		3422004	.00696916		7					
3411301	11.48333	11.48333	0.	1	* 4479.2						
3411302	11.48368	12.1123	0.	2	* 4479.2						
*-----1-----2-----3-----4-----5-----6-----7			3421301	10.49648	11.11749	0.	1	* 4479.2			
* Cold leg, loop # 3			3421302	10.51012	11.13133	0.	3	* 4485.365			
*-----1-----2-----3-----4-----5-----6-----7			3421303	10.51009	10.51009	0.	6	* 4485.365			
* 342			*-----1-----2-----3-----4-----5-----6-----7								
*-----1-----2-----3-----4-----5-----6-----7			* 345								
3420000	cold-leg	pipe	*-----1-----2-----3-----4-----5-----6-----7								
3420001	7		3450000	clega pipe							
3420101	0.546	1	3450001	5							
3420102	0.5675	7	3450101	0.5675		5					
3420301	0.67000	1	3450301	2.3080		5					
3420302	3.34000	2	3450601	0.0		5					
3420303	3.26000	3	3450801	4.5-5	0.85	5					
3420304	1.94670	4	3450901	.05	.05	4					
3420305	1.94670	5	3451001	0		5					
3420306	1.94670	6	3451101	0001000		4					
3420307	3.26000	7	3451201	110	16030824.	1248651.	2434942.	0.	0.	1	
3420601	-90.0	1	3451202	110	16027640.	1248653.	2435028.	0.	0.	2	
3420602	-90.0	3	3451203	110	16024433.	1248654.	2435114.	0.	0.	3	
3420603	0.0	6	3451204	110	16021225.	1248655.	2435200.	0.	0.	4	
3420604	90.0	7	3451205	110	16018017.	1248657.	2435287.	0.	0.	5	
3420801	4.5-5	0.85	3452001	.00696893		1					
	7		3452002	.00696893		2					
			3452003	.00696893		3					
			3452004	.00696893		4					
			3452005	.00696892		5					

3451300 0  
 3451301 10.48956 10.48956 0. 1 \* 4478.92  
 3451302 10.4896 10.4896 0. 2 \* 4478.92  
 3451303 10.48966 10.48966 0. 3 \* 4478.92  
 3451304 10.4897 10.4897 0. 4 \* 4478.92  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* Hot leg, loop # 4  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 446  
 \*-----1-----2-----3-----4-----5-----6-----7  
 4460000 hlega branch  
 4460001 1 0  
 4460101 0.5675 1.64 0 0 0.0 0.0 4.5-5 0.0 0  
 4460200 110 15656346. 1414221. 2444162. 0. .00696896  
 4461101 446010002 440010001 0.5675 0.0 0.0 0001000  
 4461201 11.47955 11.47955 0. \* 4477.64  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 440  
 \*-----1-----2-----3-----4-----5-----6-----7  
 4400000 hlega branch  
 4400001 1 0  
 4400101 0.5675 5.87 0 0 0.0 0.0 4.5-5 0.0 0  
 4400200 110 15654873. 1414224. 2444197. 0. .00696896  
 4401101 440010002 441010001 0.5675 0.0 0.0 0001000  
 4401201 11.4796 11.4796 0. \* 4477.64  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 441  
 \*-----1-----2-----3-----4-----5-----6-----7  
 4410000 hot-leg pipe  
 4410001 3  
 4410101 0.5675 2  
 4410102 0.546 3  
 4410301 1.71400 1  
 4410302 1.54000 2  
 4410303 0.67000 3  
 4410601 0.0 1  
 4410602 90.0 2  
 4410603 90.0 3  
 4410801 4.5-5 0.85 3  
 4410901 .50 .5 1  
 4410902 .0 .0 2  
 4411001 0 3  
 4411101 0001000 2

4411201 110 15652181. 1414176. 2444260. 0. 0. 1  
 4411202 110 1.5637+7 1414177. 2444619. 0. 0. 2  
 4411203 110 15615815. 1414177. 2445119. 0. 0. 3  
 4412001 .0069692 1  
 4412002 .0069692 2  
 4412003 .0069692 3  
 4411300 0  
 4411301 11.48333 11.48333 0. 1 \* 4479.2  
 4411302 11.48368 12.1123 0. 2 \* 4479.2  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* Cold leg, loop # 4  
 \*-----1-----2-----3-----4-----5-----6-----7  
 \* 442  
 \*-----1-----2-----3-----4-----5-----6-----7  
 4420000 cold-leg pipe  
 4420001 7  
 4420101 0.546 1  
 4420102 0.5675 7  
 4420301 0.67000 1  
 4420302 3.34000 2  
 4420303 3.26000 3  
 4420304 1.94670 4  
 4420305 1.94670 5  
 4420306 1.94670 6  
 4420307 3.26000 7  
 4420601 -90.0 1  
 4420602 -90.0 3  
 4420603 0.0 6  
 4420604 90.0 7  
 4420801 4.5-5 0.85 7  
 4420901 0.0 0.0 2  
 4420902 0.5 0.5 3  
 4420903 0.0 0.0 5  
 4420904 0.5 0.5 6  
 4421001 0 7  
 4421101 0001000 6  
 4421201 110 15444803. 1248350. 2449182. 0. 0. 1  
 4421202 110 15456869. 1248219. 2448894. 0. 0. 2  
 4421203 110 15456869. 1248219. 2448894. 0. 0. 3  
 4421204 110 15456869. 1248219. 2448894. 0. 0. 4  
 4421205 110 15461203. 1248224. 2448791. 0. 0. 5  
 4421206 110 15461203. 1248224. 2448791. 0. 0. 6  
 4421207 110 15430132. 1248225. 2449532. 0. 0. 7

4422001	.00696919		1	*----1----2----3----4----5----6----7	
4422002	.00696916		2	1200000 sg-pr pipe	
4422003	.00696916		3	1200001 5	
4422004	.00696916		7	1200101 0.33395 5	
4421300	0			1200301 0.0 5	
4421301	10.49648	11.11749	0.	1 * 4479.2	1200401 0.7316 5
4421302	10.51012	11.13133	0.	3 * 4485.365	1200501 0.0 5
4421303	10.51009	10.51009	0.	6 * 4485.365	1200601 0.0 5
*-----1-----2-----3-----4-----5-----6-----7				1200701 0.0 5	
* 445				1200801 1.2-5 0.013 5	
*-----1-----2-----3-----4-----5-----6-----7				1200901 0.1 0.1 4	
4450000	clega pipe			1201001 00 5	
4450001	5			1201101 00000 4	
4450101	0.5675		5	1201201 110 15566458. 1358977. 2446288. 0. 0. 1	
4450301	2.3080		5	1201202 110 15542915. 1318275. 2446847. 0. 0. 2	
4450601	0.0		5	1201203 110 15519838. 1288249. 2447395. 0. 0. 3	
4450801	4.5-5 0.85		5	1201204 110 15497079. 1266129. 2447936. 0. 0. 4	
4450901	.05 .05		4	1201205 110 15474547. 1249743. 2448473. 0. 0. 5	
4451001	0		5	1202001 .0069692 1	
4451101	0001000		4	1202002 .0069692 2	
4451201	110	16030720.	1248605.	2434945. 0. 0. 1	1202003 .0069692 3
4451202	110	16027535.	1248607.	2435031. 0. 0. 2	1202004 .0069692 4
4451203	110	16024326.	1248608.	2435117. 0. 0. 3	1202005 .0069692 5
4451204	110	16021281.	1248610.	2435199. 0. 0. 4	1201300 0
4451205	110	16018084.	1248611.	2435285. 0. 0. 5	1201301 4.35669 4.35669 0. 1 * 1023.127
4452001	.00696892		1	1201302 4.26048 4.26048 0. 2 * 1023.127	
4452002	.00696892		2	1201303 4.195135 4.195135 0. 3 * 1023.127	
4452003	.00696892		3	1201304 4.14921 4.14921 0. 4 * 1023.127	
4452004	.00696892		4	*-----1-----2-----3-----4-----5-----6-----7	
4452005	.00696892		5	* 121	
4451300	0			*-----1-----2-----3-----4-----5-----6-----7	
4451301	10.4913	10.4913	0.	1 * 4479.765	1210000 sg-pr pipe
4451302	10.49135	10.49135	0.	2 * 4479.765	1210001 5
4451303	10.472	10.472	0.	3 * 4471.48	1210101 0.636317 5
4451304	10.47205	10.47205	0.	4 * 4471.48	1210301 0.0 5
*-----1-----2-----3-----4-----5-----6-----7				1210401 1.405 5	
* * STEAM GENERATOR *				1210501 0.0 5	
*-----1-----2-----3-----4-----5-----6-----7				1210601 0.0 5	
* Steam generator primary side				1210701 0.0 5	
*-----1-----2-----3-----4-----5-----6-----7				1210801 1.2-5 0.013 5	
* Steam generator # 1 tubes				1210901 0.1 0.1 4	
*-----1-----2-----3-----4-----5-----6-----7				1211001 00 5	
* 120				1211101 00000 4	

1211201	110	15582790.	1357108.	2445901.	0.	0.	1
1211202	110	15561149.	1315423.	2446414.	0.	0.	2
1211203	110	15539937.	1284977.	2446917.	0.	0.	3
1211204	110	15519020.	1262752.	2447414.	0.	0.	4
1211205	110	15498303.	1246451.	2447907.	0.	0.	5
1212001	.0069692				1		
1212002	.0069692				2		
1212003	.0069692				3		
1212004	.0069692				4		
1212005	.00696919				5		
1211300	0						
1211301	4.17252	4.17252	0.	1 * 1892.416			
1211302	4.07848	4.07848	0.	2 * 1892.416			
1211303	4.01523	4.01523	0.	3 * 1892.416			
1211304	3.97139	3.97139	0.	4 * 1892.416			
*-----1-----2-----3-----4-----5-----6-----7							
* 122							
*-----1-----2-----3-----4-----5-----6-----7							
1220000	sg-pr pipe						
1220001	5						
1220101	0.4898	5					
1220301	0.0	5					
1220401	1.0864	5					
1220501	0.0	5					
1220601	0.0	5					
1220701	0.0	5					
1220801	1.2-5	0.013	5				
1220901	0.1	0.1	4				
1221001	00	5					
1221101	00000	4					
1221201	110	15594028.	1359528.	2445635.	0.	0.	1
1221202	110	15569127.	1318963.	2446225.	0.	0.	2
1221203	110	15544718.	1288825.	2446804.	0.	0.	3
1221204	110	15520649.	1266452.	2447375.	0.	0.	4
1221205	110	15496822.	1249734.	2447942.	0.	0.	5
1222001	.0069692				1		
1222002	.0069692				2		
1222003	.0069692				3		
1222004	.0069692				4		
1222005	.00696919				5		
1221300	0						
1221301	4.482995	4.482995	0.	1 * 1563.658			
1221302	4.38428	4.38428	0.	2 * 1563.658			
1221303	4.31677	4.31677	0.	3 * 1563.66			
1221304	4.268944	4.268944	0.	4 * 1563.66			
*-----1-----2-----3-----4-----5-----6-----7							
* Steam generator # 2 tubes							
*-----1-----2-----3-----4-----5-----6-----7							
* 220							
*-----1-----2-----3-----4-----5-----6-----7							
2200000	sg-pr pipe						
2200001	5						
2200101	0.33395	5					
2200301	0.0	5					
2200401	0.7316	5					
2200501	0.0	5					
2200601	0.0	5					
2200701	0.0	5					
2200801	1.2-5	0.013	5				
2200901	0.1	0.1	4				
2201001	00	5					
2201101	00000	4					
2201201	110	15566465.	1359014.	2446288.	0.	0.	1
2201202	110	15542925.	1318301.	2446846.	0.	0.	2
2201203	110	15519851.	1288268.	2447394.	0.	0.	3
2201204	110	15497096.	1266143.	2447936.	0.	0.	4
2201205	110	15474567.	1249754.	2448472.	0.	0.	5
2202001	.00696895					1	
2202002	.00696895					2	
2202003	.00696895					3	
2202004	.00696894					4	
2202005	.00696894					5	
2201300	0						
2201301	4.35645	4.35645	0.	1 * 1023.05			
2201302	4.26022	4.26022	0.	2 * 1023.05			
2201303	4.19486	4.19486	0.	3 * 1023.05			
2201304	4.14893	4.14893	0.	4 * 1023.05			
*-----1-----2-----3-----4-----5-----6-----7							
* 221							
*-----1-----2-----3-----4-----5-----6-----7							
2210000	sg-pr pipe						
2210001	5						
2210101	0.636317	5					
2210301	0.0	5					
2210401	1.405	5					
2210501	0.0	5					



\*----1----2----3----4----5----6----7  
 3210000 sg-pr pipe  
 3210001 5  
 3210101 0.636317 5  
 3210301 0.0 5  
 3210401 1.405 5  
 3210501 0.0 5  
 3210601 0.0 5  
 3210701 0.0 5  
 3210801 1.2-5 0.013 5  
 3210901 0.1 0.1 4  
 3211001 00 5  
 3211101 00000 4  
 3211201 110 15582793. 1357138. 2445901. 0. 0. 1  
 3211202 110 15561155. 1315438. 2446414. 0. 0. 2  
 3211203 110 15539945. 1284982. 2446917. 0. 0. 3  
 3211204 110 15519030. 1262750. 2447414. 0. 0. 4  
 3211205 110 15498317. 1246443. 2447907. 0. 0. 5  
 3212001 .00696895 1  
 3212002 .00696895 2  
 3212003 .00696895 3  
 3212004 .00696894 4  
 3212005 .00696894 5  
 3211300 0  
 3211301 4.17233 4.17233 0. 1 \* 1892.3  
 3211302 4.07826 4.07826 0. 2 \* 1892.3  
 3211303 4.014995 4.014995 0. 3 \* 1892.3  
 3211304 3.97114 3.97114 0. 4 \* 1892.3  
 \*----1----2----3----4----5----6----7  
 \* 322  
 \*----1----2----3----4----5----6----7  
 3220000 sg-pr pipe  
 3220001 5  
 3220101 0.4898 5  
 3220301 0.0 5  
 3220401 1.0864 5  
 3220501 0.0 5  
 3220601 0.0 5  
 3220701 0.0 5  
 3220801 1.2-5 0.013 5  
 3220901 0.1 0.1 4  
 3221001 00 5  
 3221101 00000 4

3221201 110 15594030. 1359559. 2445635. 0. 0. 1  
 3221202 110 15569132. 1318979. 2446225. 0. 0. 2  
 3221203 110 15544726. 1288831. 2446804. 0. 0. 3  
 3221204 110 15520659. 1266451. 2447375. 0. 0. 4  
 3221205 110 15496834. 1249728. 2447942. 0. 0. 5  
 3222001 .00696895 1  
 3222002 .00696895 2  
 3222003 .00696895 3  
 3222004 .00696894 4  
 3222005 .00696894 5  
 3221300 0  
 3221301 4.482805 4.482805 0. 1 \* 1563.565  
 3221302 4.38406 4.38406 0. 2 \* 1563.565  
 3221303 4.31653 4.31653 0. 3 \* 1563.565  
 3221304 4.26869 4.26869 0. 4 \* 1563.566  
 \*----1----2----3----4----5----6----7  
 \* Steam generator # 4 tubes  
 \*----1----2----3----4----5----6----7  
 \* 420  
 \*----1----2----3----4----5----6----7  
 4200000 sg-pr pipe  
 4200001 5  
 4200101 0.33395 5  
 4200301 0.0 5  
 4200401 0.7316 5  
 4200501 0.0 5  
 4200601 0.0 5  
 4200701 0.0 5  
 4200801 1.2-5 0.013 5  
 4200901 0.1 0.1 4  
 4201001 00 5  
 4201101 00000 4  
 4201201 110 15566540. 1359004. 2446286. 0. 0. 1  
 4201202 110 15543014. 1318286. 2446844. 0. 0. 2  
 4201203 110 15519952. 1288251. 2447392. 0. 0. 3  
 4201204 110 15497210. 1266126. 2447933. 0. 0. 4  
 4201205 110 15474693. 1249737. 2448469. 0. 0. 5  
 4202001 .00696895 1  
 4202002 .00696895 2  
 4202003 .00696895 3  
 4202004 .00696895 4  
 4202005 .00696894 5  
 4201300 0

4201301 4.3552 4.3552 0. 1 \* 1022.762  
 4201302 4.25898 4.25898 0. 2 \* 1022.762  
 4201303 4.193645 4.193645 0. 3 \* 1022.762  
 4201304 4.147726 4.147726 0. 4 \* 1022.762  
 \*----1----2----3----4----5----6----7  
 \* 421  
 \*----1----2----3----4----5----6----7  
 4210000 sg-pr pipe  
 4210001 5  
 4210101 0.636317 5  
 4210301 0.0 5  
 4210401 1.405 5  
 4210501 0.0 5  
 4210601 0.0 5  
 4210701 0.0 5  
 4210801 1.2-5 0.013 5  
 4210901 0.1 0.1 4  
 4211001 00 5  
 4211101 00000 4  
 4211201 110 15582857. 1357134. 2445899. 0. 0. 1  
 4211202 110 15561231. 1315433. 2446412. 0. 0. 2  
 4211203 110 15540033. 1284978. 2446915. 0. 0. 3  
 4211204 110 15519131. 1262749. 2447412. 0. 0. 4  
 4211205 110 15498429. 1246444. 2447904. 0. 0. 5  
 4212001 .00696895 1  
 4212002 .00696895 2  
 4212003 .00696895 3  
 4212004 .00696894 4  
 4212005 .00696894 5  
 421300 0  
 4211301 4.17111 4.17111 0. 1 \* 1891.753  
 4211302 4.07707 4.07707 0. 2 \* 1891.752  
 4211303 4.01383 4.01383 0. 3 \* 1891.752  
 4211304 3.96999 3.96999 0. 4 \* 1891.75  
 \*----1----2----3----4----5----6----7  
 \* 422  
 \*----1----2----3----4----5----6----7  
 4220000 sg-pr pipe  
 4220001 5  
 4220101 0.4898 5  
 4220301 0.0 5  
 4220401 1.0864 5  
 4220501 0.0 5

4220601 0.0 5  
 4220701 0.0 5  
 4220801 1.2-5 0.013 5  
 4220901 0.1 0.1 4  
 4221001 00 5  
 4221101 00000 4  
 4221201 110 15594085. 1359555. 2445634. 0. 0. 1  
 4221202 110 15569201. 1318974. 2446223. 0. 0. 2  
 4221203 110 15544808. 1288827. 2446802. 0. 0. 3  
 4221204 110 15520755. 1266449. 2447373. 0. 0. 4  
 4221205 110 15496944. 1249728. 2447939. 0. 0. 5  
 4222001 .00696895 1  
 4222002 .00696895 2  
 4222003 .00696895 3  
 4222004 .00696894 4  
 4222005 .00696894 5  
 4221300 0  
 4221301 4.4815 4.4815 0. 1 \* 1563.114  
 4221302 4.38278 4.38278 0. 2 \* 1563.115  
 4221303 4.31528 4.31528 0. 3 \* 1563.115  
 4221304 4.26745 4.26745 0. 4 \* 1563.115  
 \*----1----2----3----4----5----6----7  
 \* steam generator#1 hot collector  
 \*----1----2----3----4----5----6----7  
 1100000 tube-con branch  
 1100001 3 0  
 1100101 0.546 0.80 0.0 0.0 90.0 0.80  
 1100102 4.5-5 0.834 00  
 1100200 110 15593675. 1414177. 2445643. 0. .0069692  
 1101101 110010000 1110000000 0.0 0.0 0.0 0.00000  
 1101201 9.21031 9.76748 0.\* 3456.074  
 1102101 110010004 1200000000 0.0 0.7 0.7 00100  
 1102201 4.50173 4.50173 0.\* 1023.127  
 1103101 141010000 1100000000 0.0 0.1 0.1 0001000  
 1103201 11.93638 12.5752 0.\* 4479.2  
 \*----1----2----3----4----5----6----7  
 1110000 tube-con branch  
 1110001 2 0  
 1110101 0.546 0.80 0.0 0.0 90.0 0.80  
 1110102 4.5-5 0.834 00  
 1110200 110 15610201. 1414178. 2445252. 0. .0069692  
 1111101 111010000 1120000000 0.0 0.0 0.0 0.00000  
 1111201 4.166955 4.53132 0.\* 1563.657

1112101 111010004 121000000 0.0 0.7 0.7 00100  
 1112201 5.256 5.256 0. \* 1892.417  
 \*----1----2----3----4----5----6----7  
 1120000 tube-con branch  
 1120001 2 0  
 1120101 0.546 0.80 0.0 0.0 90.0 0.80  
 1120102 4.5-5 0.834 00  
 1120200 110 15621690. 1414178. 2444981. 0. .0069692  
 1121101 112010000 115000000 0.0 0.0 0.0 00000  
 1121201 1.271435-6 1.271452-6 0. \* 1.99736-4  
 1122101 112010004 122000000 0.0 0.7 0.7 00100  
 1122201 4.63079 4.63079 0. \* 1563.657  
 \*----1----2----3----4----5----6----7  
 \* steam generator collector upper volume  
 \*----1----2----3----4----5----6----7  
 1150000 sg-col-u branch  
 1150001 0 0  
 1150101 0.0 1.875 0.7238 0.0 90. 1.875  
 1150102 4.5-5 0.0 00  
 1150200 110 15617370. 1429161. 2445083. 0. .00695001  
 \*----1----2----3----4----5----6----7  
 1300000 tube-con branch  
 1300001 3 0  
 1300101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 1300102 4.5-5 0.834 00  
 1300200 110 15460278. 1248349. 2448813. 0. .00696919  
 1301101 131010000 130000000 0.546 0.0 0.0 01000  
 1301201 8.41585 8.9648 0. \* 3456.074  
 1302101 120010000 130010003 0.0 0.7 0.7 00100  
 1302201 4.11692 4.11692 0. \* 1023.127  
 1303101 130010000 142000000 0.546 0.1 0.1 0001000  
 1303201 10.90958 11.53988 0. \* 4479.2  
 \*----1----2----3----4----5----6----7  
 1310000 tube-con branch  
 1310001 2 0  
 1310101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 1310102 4.5-5 0.834 00  
 1310200 110 15476449. 1247936. 2448427. 0. .00696919  
 1311101 132010000 131000000 0.0 0.0 0.0 01000  
 1311201 3.81085 4.17003 0. \* 1563.66  
 1312101 121010000 131010003 0.0 0.7 0.7 00100  
 1312201 4.79925 4.79925 0. \* 1892.416  
 \*----1----2----3----4----5----6----7

1320000 tube-con branch  
 1320001 2 0  
 1320101 0.546 0.80 0.0 0.0 90.0 -0.80  
 1320102 4.5-5 0.834 00  
 1320200 110 15479379. 1249734. 2448357. 0. .00696919  
 1321101 135010000 132000000 0.0 0.0 0.0 00000  
 1321201 6.20814-8 6.20812-8 0. \* 1.066377-5  
 1322101 122010000 132010003 0.0 0.7 0.7 01100  
 1322201 4.23505 4.23505 0. \* 1563.66  
 \*----1----2----3----4----5----6----7  
 \* steam generator cold collector upper volume  
 \*----1----2----3----4----5----6----7  
 1350000 sg-col-u branch  
 1350001 0 0  
 1350101 0.0 1.875 0.7238 0.0 -90. -1.875  
 1350102 4.5-5 0.0 00  
 1350200 110 15470023. 1262863. 2448580. 0. .00695  
 \*----1----2----3----4----5----6----7  
 2100000 tube-con branch  
 2100001 3 0  
 2100101 0.546 0.80 0.0 0.0 90.0 0.80  
 2100102 4.5-5 0.834 00  
 2100200 110 15593677. 1414227. 2445643. 0. .00696895  
 2101101 210010000 211000000 0.0 0.0 0.0 00000  
 2101201 9.20996 9.7671 0. \* 3455.834  
 2102101 210010004 220000000 0.0 0.7 0.7 00100  
 2102201 4.50153 4.50153 0. \* 1023.05  
 2103101 241010000 210000000 0.0 0.1 0.1 0001000  
 2103201 11.93591 12.5747 0. \* 4478.884  
 \*----1----2----3----4----5----6----7  
 2110000 tube-con branch  
 2110001 2 0  
 2110101 0.546 0.80 0.0 0.0 90.0 0.80  
 2110102 4.5-5 0.834 00  
 2110200 110 15610201. 1414228. 2445252. 0. .00696896  
 2111101 211010000 212000000 0.0 0.0 0.0 00000  
 2111201 4.16681 4.53117 0. \* 1563.553  
 2112101 211010004 221000000 0.0 0.7 0.7 00100  
 2112201 5.25579 5.25579 0. \* 1892.28  
 \*----1----2----3----4----5----6----7  
 2120000 tube-con branch  
 2120001 2 0  
 2120101 0.546 0.80 0.0 0.0 90.0 0.80

2120102 4.5-5 0.834 00  
 2120200 110 15621699. 1414229. 2444980. 0. .00696895  
 2121101 212010000 215000000 0.0 0.0 0.0 00000  
 2121201 -1.266622-6 -1.26664-6 0. \* -1.971185-4  
 2122101 212010004 222000000 0.0 0.7 0.7 00100  
 2122201 4.63062 4.63062 0. \* 1563.553  
 \*----1----2----3----4----5----6----7  
 \* steam generator collector upper volume  
 \*----1----2----3----4----5----6----7  
 2150000 sg-col-u branch  
 2150001 0 0  
 2150101 0.0 1.875 0.7238 0.0 90. 1.875  
 2150102 4.5-5 0.0 00  
 2150200 110 15617367. 1429161. 2445083. 0. .00695001  
 \*151101 212010000 215000000 0.0 0.0 0.0 00000  
 \*151201 0.0 0.0 0.0  
 \*----1----2----3----4----5----6----7  
 \* steam generator cold leg tube connection volumes  
 \*----1----2----3----4----5----6----7  
 2300000 tube-con branch  
 2300001 3 0  
 2300101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 2300102 4.5-5 0.834 00  
 2300200 110 15460300. 1248359. 2448812. 0. .00696894  
 2301101 231010000 230000000 0.546 0.0 0.0 01000  
 2301201 8.4153 8.96423 0. \* 3455.83  
 2302101 220010000 230010003 0.0 0.7 0.7 01100  
 2302201 4.11663 4.11663 0. \* 1023.05  
 2303101 230010000 242000000 0.546 0.1 0.1 0001000  
 2303201 10.90886 11.53913 0. \* 4478.88  
 \*----1----2----3----4----5----6----7  
 2310000 tube-con branch  
 2310001 2 0  
 2310101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 2310102 4.5-5 0.834 00  
 2310200 110 15476469. 1247946. 2448427. 0. .00696894  
 2311101 232010000 231000000 0.0 0.0 0.0 01000  
 2311201 3.81061 4.16977 0. \* 1563.55  
 2312101 221010000 231010003 0.0 0.7 0.7 01100  
 2312201 4.79893 4.79893 0. \* 1892.28  
 \*----1----2----3----4----5----6----7  
 2320000 tube-con branch  
 2320001 2 0  
 2320101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 2320102 4.5-5 0.834 00  
 2320200 110 15479397. 1249745. 2448357. 0. .00696894  
 2321101 235010000 232000000 0.0 0.0 0.0 00000  
 2321201 -6.18287-8 -6.18289-8 0. \* -1.055394-5  
 2322101 222010000 232010003 0.0 0.7 0.7 01100  
 2322201 4.23478 4.23478 0. \* 1563.55  
 \*----1----2----3----4----5----6----7  
 \* steam generator collector upper volume  
 \*----1----2----3----4----5----6----7  
 2350000 sg-col-u branch  
 2350001 0 0  
 2350101 0.0 1.875 0.7238 0.0 -90. -1.875  
 2350102 4.5-5 0.0 00  
 2350200 110 15470038. 1262863. 2448580. 0. .00695  
 \*----1----2----3----4----5----6----7  
 3100000 tube-con branch  
 3100001 3 0  
 3100101 0.546 0.80 0.0 0.0 90.0 0.80  
 3100102 4.5-5 0.834 00  
 3100200 110 15593678. 1414227. 2445643. 0. .00696895  
 3101101 310010000 311000000 0.0 0.0 0.0 00000  
 3101201 9.21004 9.7672 0. \* 3455.864  
 3102101 310010004 320000000 0.0 0.7 0.7 00100  
 3102201 4.50157 4.50157 0. \* 1023.06  
 3103101 341010000 310000000 0.0 0.1 0.1 0001000  
 3103201 11.93602 12.57482 0. \* 4478.92  
 \*----1----2----3----4----5----6----7  
 3110000 tube-con branch  
 3110001 2 0  
 3110101 0.546 0.80 0.0 0.0 90.0 0.80  
 3110102 4.5-5 0.834 00  
 3110200 110 15610202. 1414228. 2445252. 0. .00696896  
 3111101 311010000 312000000 0.0 0.0 0.0 00000  
 3111201 4.16684 4.5312 0. \* 1563.564  
 3112101 311010004 321000000 0.0 0.7 0.7 00100  
 3112201 5.25584 5.25584 0. \* 1892.3  
 \*----1----2----3----4----5----6----7  
 3120000 tube-con branch  
 3120001 2 0  
 3120101 0.546 0.80 0.0 0.0 90.0 0.80  
 3120102 4.5-5 0.834 00  
 3120200 110 15621690. 1414229. 2444981. 0. .00696895

3121101 312010000 315000000 0.0 0.0 0.0 00000  
 3121201 1.267122-6 1.26714-6 0.\* 1.99052-4  
 3122101 312010004 322000000 0.0 0.7 0.7 00100  
 3122201 4.63066 4.63066 0.\* 1563.564  
 \*----1----2----3----4----5----6----7  
 \* steam generator collector upper volume  
 \*----1----2----3----4----5----6----7  
 3150000 sg-col-u branch  
 3150001 0 0  
 3150101 0.0 1.875 0.7238 0.0 90. 1.875  
 3150102 4.5-5 0.0 00  
 3150200 110 15617369. 1429161. 2445083. 0. .00695001  
 \*151101 312010000 315000000 0.0 0.0 0.0 00000  
 \*151201 0.0 0.0 0.0  
 \*----1----2----3----4----5----6----7  
 \* steam generator cold leg tube connection volumes  
 \*----1----2----3----4----5----6----7  
 3300000 tube-con branch  
 3300001 3 0  
 3300101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 3300102 4.5-5 0.834 00  
 3300200 110 15460297. 1248342. 2448812. 0. .00696894  
 3301101 331010000 330000000 0.546 0.0 0.0 01000  
 3301201 8.4153 8.96424 0.\* 3455.864  
 3302101 320010000 330010003 0.0 0.7 0.7 01100  
 3302201 4.11663 4.11663 0.\* 1023.06  
 3303101 330010000 342000000 0.546 0.1 0.1 0001000  
 3303201 10.90887 11.53914 0.\* 4478.92  
 \*----1----2----3----4----5----6----7  
 3310000 tube-con branch  
 3310001 2 0  
 3310101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 3310102 4.5-5 0.834 00  
 3310200 110 15476465. 1247929. 2448427. 0. .00696894  
 3311101 332010000 331000000 0.0 0.0 0.0 01000  
 3311201 3.81061 4.16978 0.\* 1563.566  
 3312101 321010000 331010003 0.0 0.7 0.7 01100  
 3312201 4.79893 4.79893 0.\* 1892.3  
 \*----1----2----3----4----5----6----7  
 3320000 tube-con branch  
 3320001 2 0  
 3320101 0.546 0.80 0.0 0.0 -90.0 -0.80  
 3320102 4.5-5 0.834 00

3320200 110 15479394. 1249727. 2448357. 0. .00696894  
 3321101 335010000 332000000 0.0 0.0 0.0 00000  
 3321201 6.19053-8 6.19051-8 0.\* 1.063356-5  
 3322101 322010000 332010003 0.0 0.7 0.7 01100  
 3322201 4.23478 4.23478 0.\* 1563.566  
 \*----1----2----3----4----5----6----7  
 \* steam generator collector upper volume  
 \*----1----2----3----4----5----6----7  
 3350000 sg-col-u branch  
 3350001 0 0  
 3350101 0.0 1.875 0.7238 0.0 -90. -1.875  
 3350102 4.5-5 0.0 00  
 3350200 110 15470038. 1262863. 2448580. 0. .00695  
 \*----1----2----3----4----5----6----7  
 \* steam generator, tube connection volumes  
 \*----1----2----3----4----5----6----7  
 4100000 tube-con branch  
 4100001 3 0  
 4100101 0.546 0.80 0.0 0.0 90.0 0.80  
 4100102 4.5-5 0.834 00  
 4100200 110 15593739. 1414227. 2445642. 0. .00696896  
 4101101 410010000 411000000 0.0 0.0 0.0 00000  
 4101201 9.20738 9.76444 0.\* 3454.866  
 4102101 410010004 420000000 0.0 0.7 0.7 00100  
 4102201 4.500265 4.500265 0.\* 1022.763  
 4103101 441010000 410000000 0.0 0.1 0.1 0001000  
 4103201 11.93257 12.57127 0.\* 4477.63  
 \*----1----2----3----4----5----6----7  
 4110000 tube-con branch  
 4110001 2 0  
 4110101 0.546 0.80 0.0 0.0 90.0 0.80  
 4110102 4.5-5 0.834 00  
 4110200 110 15610251. 1414228. 2445251. 0. .00696896  
 4111101 411010000 412000000 0.0 0.0 0.0 00000  
 4111201 4.165635 4.52994 0.\* 1563.113  
 4112101 411010004 421000000 0.0 0.7 0.7 00100  
 4112201 5.25432 5.25432 0.\* 1891.753  
 \*----1----2----3----4----5----6----7  
 4120000 tube-con branch  
 4120001 2 0  
 4120101 0.546 0.80 0.0 0.0 90.0 0.80  
 4120102 4.5-5 0.834 00  
 4120200 110 15621729. 1414229. 2444980. 0. .00696895

4121101	412010000	415000000	0.0	0.0	0.0	00000	4320101	0.546	0.80	0.0	0.0	-90.0	-0.80
4121201	1.264666-6	1.264683-6	0.	* 1.986663-4			4320102	4.5-5	0.834	00			
4122101	412010004	422000000	0.0	0.7	0.7	00100	4320200	110	15479513.	1249728.	2448354.	0.	.00696894
4122201	4.62932	4.62932	0.	* 1563.114			4321101	435010000	432000000	0.0	0.0	0.0	00000
*-----1-----2-----3-----4-----5-----6-----7							4321201	6.2012-8	6.20119-8	0.	* 1.06519-5		
* steam generator collector upper volume							4322101	422010000	432010003	0.0	0.7	0.7	01100
*-----1-----2-----3-----4-----5-----6-----7							4322201	4.23356	4.23356	0.	* 1563.115		
4150000	sg-col-u	branch					*-----1-----2-----3-----4-----5-----6-----7						
4150001	0	0					* steam generator collector upper volume						
4150101	0.0	1.875	0.7238	0.0	90.	1.875	*-----1-----2-----3-----4-----5-----6-----7						
4150102	4.5-5	0.0	00				4350000	sg-col-u	branch				
4150200	110	15617405.	1429160.	2445082.	0.	.00695001	4350001	0	0				
*151101	412010000	415000000	0.0	0.0	0.0	00000	4350101	0.0	1.875	0.7238	0.0	-90.	-1.875
*151201	0.0	0.0	0.0				4350102	4.5-5	0.0	00			
*-----1-----2-----3-----4-----5-----6-----7							4350200	110	15470157.	1262863.	2448577.	0.	.00695
* steam generator primary side							*-----1-----2-----3-----4-----5-----6-----7						
*-----1-----2-----3-----4-----5-----6-----7							* heat structures steam generator tubing						
* steam generator cold leg tube connection volumes							*-----1-----2-----3-----4-----5-----6-----7						
*-----R-1-----2-----3-----4-----5-----6-----7							11200000	5	5	2	1	0.0065	
4300000	tube-con	branch					11200100	0	1				
4300001	3	0					11200101	4	0.008				
4300101	0.546	0.80	0.0	0.0	-90.0	-0.80	11200201	4	4				
4300102	4.5-5	0.834	00				11200301	0.0	4				
4300200	110	15460434.	1248343.	2448809.	0.	.00696894	11200400	0					
4301101	431010000	430000000	0.546	0.0	0.0	01000	11200401	565.00	5				
4301201	8.41288	8.96173	0.	* 3454.87			11200501	120010000	10000	1	1	5511.	5
4302101	420010000	430010003	0.0	0.7	0.7	01100	11200601	100010000	0	134	1	5511.	5
4302201	4.11544	4.11544	0.	* 1022.762			11200701	0	0.0	0.0	0.0	5	
4303101	430010000	442000000	0.546	0.1	0.1	0001000	11200801	0.	10.	10.0	0.0	0.	0.1.
4303201	10.90572	11.5359	0.	* 4477.63			11200901	0.	10.0	10.0	0.0	0.	0.1.
*-----1-----2-----3-----4-----5-----6-----7							*-----1-----2-----3-----4-----5-----6-----7						
4310000	tube-con	branch					11210000	5	5	2	1	0.0065	
4310001	2	0					11210100	0	1				
4310101	0.546	0.80	0.0	0.0	-90.0	-0.80	11210101	4	0.008				
4310102	4.5-5	0.834	00				11210201	4	4				
4310200	110	15476590.	1247930.	2448424.	0.	.00696894	11210301	0.0	4				
4311101	432010000	431000000	0.0	0.0	0.0	01000	11210400	0					
4311201	3.80951	4.16862	0.	* 1563.115			11210401	565.00	5				
4312101	421010000	431010003	0.0	0.7	0.7	01100	11210501	121010000	10000	1	1	10634.	5
4312201	4.79755	4.79755	0.	* 1891.75			11210601	101010000	0	134	1	10634.	5
*-----1-----2-----3-----4-----5-----6-----7							11210701	0	0.0	0.0	0.0	5	
4320000	tube-con	branch					11210801	0.	10.	10.0	0.0	0.	0.1.
4320001	2	0					11210901	0.	10.	10.0	0.0	0.	0.1.

\*----1----2----3----4----5----6----7  
 11220000 5 5 2 1 0.0065  
 11220100 0 1  
 11220101 4 0.008  
 11220201 4 4  
 11220301 0.0 4  
 11220400 0  
 11220401 565.00 5  
 11220501 122010000 10000 1 1 8187. 5  
 11220601 102010000 0 134 1 8187. 5  
 11220701 0 0.0 0.0 0.0 5  
 11220801 0. 10.0 10.0 0.0 0. 0. 1. 5  
 11220901 0. 10.0 10.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 \* Heat structure steam generator vessel, upper part  
 \*----1----2----3----4----5----6----7  
 11050000 1 3 2 1 2.0  
 11050100 0 1  
 11050101 2 2.125  
 11050201 6 2  
 11050301 0.0 2  
 11050400 0  
 11050401 551.9 3  
 11050501 105010000 0 1 1 3.45 1  
 11050601 0 0 0 1 3.45 1  
 11050701 0 0.0 0.0 0.00 1  
 11050801 3. 10.0 10.0 0.00 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 11040000 1 3 2 1 2.0  
 11040100 0 1  
 11040101 2 2.125  
 11040201 6 2  
 11040301 0.0 2  
 11040400 0  
 11040401 551.9 3  
 11040501 104010000 0 1 1 2.33 1  
 11040601 0 0 0 1 2.33 1  
 11040701 0 0.0 0.0 0.00 1  
 11040801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 11030000 1 3 2 1 2.0  
 11030100 0 1  
 11030101 2 2.125

11030201 6 2  
 11030301 0.0 2  
 11030400 0  
 11030401 551.9 3  
 11030501 103010000 0 1 1 0.73 1  
 11030601 0 0 0 1 0.73 1  
 11030701 0 0.0 0.0 0.00 1  
 11030801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 11520000 1 3 2 1 2.0  
 11520100 0 1  
 11520101 2 2.125  
 11520201 6 2  
 11520301 0.0 2  
 11520400 0  
 11520401 551.9 3  
 11520501 152010000 0 1 1 2.00 1  
 11520601 0 0 0 1 2.00 1  
 11520701 0 0.0 0.0 0.0 1  
 11520801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 11510000 1 3 2 1 2.0  
 11510100 0 1  
 11510101 2 2.125  
 11510201 6 2  
 11510301 0.0 2  
 11510400 0  
 11510401 551.9 3  
 11510501 151010000 0 1 1 2.07 1  
 11510601 0 0 0 1 2.07 1  
 11510701 0 0.0 0.0 0.0 1  
 11510801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 11500000 1 3 2 1 2.0  
 11500100 0 1  
 11500101 2 2.125  
 11500201 6 2  
 11500301 0.0 2  
 11500400 0  
 11500401 551.9 3  
 11500501 150010000 0 1 1 4.43 1  
 11500601 0 0 0 1 4.43 1  
 11500701 0 0.0 0.0 0.0 1

11500801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 12200000 5 5 2 1 0.0065  
 12200100 0 1  
 12200101 4 0.008  
 12200201 4 4  
 12200301 0.0 4  
 12200400 0  
 12200401 565.00 5  
 12200501 220010000 10000 1 1 5511. 5  
 12200601 200010000 0 134 1 5511. 5  
 12200701 0 0.0 0.0 0.0 5  
 12200801 0. 10. 10.0 0.0 0. 0. 0. 1. 5  
 12200901 0. 10.0 10.0 0.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 12210000 5 5 2 1 0.0065  
 12210100 0 1  
 12210101 4 0.008  
 12210201 4 4  
 12210301 0.0 4  
 12210400 0  
 12210401 565.00 5  
 12210501 221010000 10000 1 1 10634. 5  
 12210601 201010000 0 134 1 10634. 5  
 12210701 0 0.0 0.0 0.0 5  
 12210801 0. 10.0 10.0 0.0 0. 0. 0. 1. 5  
 12210901 0. 10.0 10.0 0.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 12220000 5 5 2 1 0.0065  
 12220100 0 1  
 12220101 4 0.008  
 12220201 4 4  
 12220301 0.0 4  
 12220400 0  
 12220401 565.00 5  
 12220501 222010000 10000 1 1 8187. 5  
 12220601 202010000 0 134 1 8187. 5  
 12220701 0 0.0 0.0 0.0 5  
 12220801 0. 10.0 10.0 0.0 0. 0. 0. 1. 5  
 12220901 0. 10.0 10.0 0.0 0. 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 \* Heat structure steam generator vessel, upper part  
 \*----1----2----3----4----5----6----7

12050000 1 3 2 1 2.0  
 12050100 0 1  
 12050101 2 2.125  
 12050201 6 2  
 12050301 0.0 2  
 12050400 0  
 12050401 551.9 3  
 12050501 205010000 0 1 1 3.45 1  
 12050601 0 0 0 1 3.45 1  
 12050701 0 0.0 0.0 0.00 1  
 12050801 3. 10.0 10.0 0.00 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 12040000 1 3 2 1 2.0  
 12040100 0 1  
 12040101 2 2.125  
 12040201 6 2  
 12040301 0.0 2  
 12040400 0  
 12040401 551.9 3  
 12040501 204010000 0 1 1 2.33 1  
 12040601 0 0 0 1 2.33 1  
 12040701 0 0.0 0.0 0.00 1  
 12040801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 12030000 1 3 2 1 2.0  
 12030100 0 1  
 12030101 2 2.125  
 12030201 6 2  
 12030301 0.0 2  
 12030400 0  
 12030401 551.9 3  
 12030501 203010000 0 1 1 0.73 1  
 12030601 0 0 0 1 0.73 1  
 12030701 0 0.0 0.0 0.00 1  
 12030801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 12520000 1 3 2 1 2.0  
 12520100 0 1  
 12520101 2 2.125  
 12520201 6 2  
 12520301 0.0 2  
 12520400 0  
 12520401 551.9 3

12520501 252010000 0 1 1 2.00 1  
 12520601 0 0 0 1 2.00 1  
 12520701 0 0.0 0.0 0.0 1  
 12520801 3. 10.0 10.0 0.0 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* Heat structure steam generator vessel, lower part  
 \*----1----2----3----4----5----6----7  
 12510000 1 3 2 1 2.0  
 12510100 0 1  
 12510101 2 2.125  
 12510201 6 2  
 12510301 0.0 2  
 12510400 0  
 12510401 551.9 3  
 12510501 251010000 0 1 1 2.07 1  
 12510601 0 0 0 1 2.07 1  
 12510701 0 0.0 0.0 0.0 1  
 12510801 3. 10.0 10.0 0.0 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 12500000 1 3 2 1 2.0  
 12500100 0 1  
 12500101 2 2.125  
 12500201 6 2  
 12500301 0.0 2  
 12500400 0  
 12500401 551.9 3  
 12500501 250010000 0 1 1 4.43 1  
 12500601 0 0 0 1 4.43 1  
 12500701 0 0.0 0.0 0.0 1  
 12500801 3. 10.0 10.0 0.0 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 13200000 5 5 2 1 0.0065  
 13200100 0 1  
 13200101 4 0.008  
 13200201 4 4  
 13200301 0.0 4  
 13200400 0  
 13200401 565.00 5  
 13200501 320010000 10000 1 1 5511. 5  
 13200601 300010000 0 134 1 5511. 5  
 13200701 0 0.0 0.0 0.0 5  
 13200801 0. 10. 10.0 0.0 0. 0. 1. 5  
 13200901 0. 10.0 10.0 0.0 0. 0. 1. 5

\*----1----2----3----4----5----6----7  
 13210000 5 5 2 1 0.0065  
 13210100 0 1  
 13210101 4 0.008  
 13210201 4 4  
 13210301 0.0 4  
 13210400 0  
 13210401 565.00 5  
 13210501 321010000 10000 1 1 10634. 5  
 13210601 301010000 0 134 1 10634. 5  
 13210701 0 0.0 0.0 0.0 5  
 13210801 0. 10.0 10.0 0.0 0. 0. 1. 5  
 13210901 0. 10.0 10.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 13220000 5 5 2 1 0.0065  
 13220100 0 1  
 13220101 4 0.008  
 13220201 4 4  
 13220301 0.0 4  
 13220400 0  
 13220401 565.00 5  
 13220501 322010000 10000 1 1 8187. 5  
 13220601 302010000 0 134 1 8187. 5  
 13220701 0 0.0 0.0 0.0 5  
 13220801 0. 10.0 10.0 0.0 0. 0. 1. 5  
 13220901 0. 10.0 10.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 \* Heat structure steam generator vessel, upper part  
 \*----1----2----3----4----5----6----7  
 13050000 1 3 2 1 2.0  
 13050100 0 1  
 13050101 2 2.125  
 13050201 6 2  
 13050301 0.0 2  
 13050400 0  
 13050401 551.9 3  
 13050501 305010000 0 1 1 3.45 1  
 13050601 0 0 0 1 3.45 1  
 13050701 0 0.0 0.0 0.00 1  
 13050801 3. 10.0 10.0 0.00 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 13040000 1 3 2 1 2.0  
 13040100 0 1

13040101 2 2.125  
 13040201 6 2  
 13040301 0.0 2  
 13040400 0  
 13040401 551.9 3  
 13040501 304010000 0 1 1 2.33 1  
 13040601 0 0 0 1 2.33 1  
 13040701 0 0.0 0.0 0.00 1  
 13040801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 13030000 1 3 2 1 2.0  
 13030100 0 1  
 13030101 2 2.125  
 13030201 6 2  
 13030301 0.0 2  
 13030400 0  
 13030401 551.9 3  
 13030501 303010000 0 1 1 0.73 1  
 13030601 0 0 0 1 0.73 1  
 13030701 0 0.0 0.0 0.00 1  
 13030801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 13520000 1 3 2 1 2.0  
 13520100 0 1  
 13520101 2 2.125  
 13520201 6 2  
 13520301 0.0 2  
 13520400 0  
 13520401 551.9 3  
 13520501 352010000 0 1 1 2.00 1  
 13520601 0 0 0 1 2.00 1  
 13520701 0 0.0 0.0 0.0 1  
 13520801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* Heat structure steam generator vessel, lower part  
 \*----1----2----3----4----5----6----7  
 13510000 1 3 2 1 2.0  
 13510100 0 1  
 13510101 2 2.125  
 13510201 6 2  
 13510301 0.0 2  
 13510400 0  
 13510401 551.9 3

13510501 351010000 0 1 1 2.07 1  
 13510601 0 0 0 1 2.07 1  
 13510701 0 0.0 0.0 0.0 1  
 13510801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 13500000 1 3 2 1 2.0  
 13500100 0 1  
 13500101 2 2.125  
 13500201 6 2  
 13500301 0.0 2  
 13500400 0  
 13500401 551.9 3  
 13500501 350010000 0 1 1 4.43 1  
 13500601 0 0 0 1 4.43 1  
 13500701 0 0.0 0.0 0.0 1  
 13500801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* heat structures steam generator tubing  
 \*----1----2----3----4----5----6----7  
 14200000 5 5 2 1 0.0065  
 14200100 0 1  
 14200101 4 0.008  
 14200201 4 4  
 14200301 0.0 4  
 14200400 0  
 14200401 565.00 5  
 14200501 420010000 10000 1 1 5511. 5  
 14200601 400010000 0 134 1 5511. 5  
 14200701 0 0.0 0.0 0.0 5  
 14200801 0. 10. 10.0 0.0 0. 0. 0. 1. 5  
 14200901 0. 10.0 10.0 0.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 14210000 5 5 2 1 0.0065  
 14210100 0 1  
 14210101 4 0.008  
 14210201 4 4  
 14210301 0.0 4  
 14210400 0  
 14210401 565.00 5  
 14210501 421010000 10000 1 1 10634. 5  
 14210601 401010000 0 134 1 10634. 5  
 14210701 0 0.0 0.0 0.0 5  
 14210801 0. 10.0 10.0 0.0 0. 0. 0. 1. 5

14210901 0. 10.0 10.0 0.0 0.0 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 14220000 5 5 2 1 0.0065  
 14220100 0 1  
 14220101 4 0.008  
 14220201 4 4  
 14220301 0.0 4  
 14220400 0  
 14220401 565.00 5  
 14220501 422010000 10000 1 1 8187. 5  
 14220601 402010000 0 134 1 8187. 5  
 14220701 0 0.0 0.0 0.0 5  
 14220801 0. 10.0 10.0 0.0 0. 0. 1. 5  
 14220901 0. 10.0 10.0 0.0 0. 0. 0. 1. 5  
 \*----1----2----3----4----5----6----7  
 \* steam generator vessel, upper part  
 \*----1----2----3----4----5----6----7  
 14050000 1 3 2 1 2.0  
 14050100 0 1  
 14050101 2 2.125  
 14050201 6 2  
 14050301 0.0 2  
 14050400 0  
 14050401 551.9 3  
 14050501 405010000 0 1 1 3.45 1  
 14050601 0 0 0 1 3.45 1  
 14050701 0 0.0 0.0 0.00 1  
 14050801 3. 10.0 10.0 0.00 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 14040000 1 3 2 1 2.0  
 14040100 0 1  
 14040101 2 2.125  
 14040201 6 2  
 14040301 0.0 2  
 14040400 0  
 14040401 551.9 3  
 14040501 404010000 0 1 1 2.33 1  
 14040601 0 0 0 1 2.33 1  
 14040701 0 0.0 0.0 0.00 1  
 14040801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 14030000 1 3 2 1 2.0  
 14030100 0 1

14030101 2 2.125  
 14030201 6 2  
 14030301 0.0 2  
 14030400 0  
 14030401 551.9 3  
 14030501 403010000 0 1 1 0.73 1  
 14030601 0 0 0 1 0.73 1  
 14030701 0 0.0 0.0 0.00 1  
 14030801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 14520000 1 3 2 1 2.0  
 14520100 0 1  
 14520101 2 2.125  
 14520201 6 2  
 14520301 0.0 2  
 14520400 0  
 14520401 551.9 3  
 14520501 452010000 0 1 1 2.00 1  
 14520601 0 0 0 1 2.00 1  
 14520701 0 0.0 0.0 0.0 1  
 14520801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* steam generator vessel, lower part  
 \*----1----2----3----4----5----6----7  
 14510000 1 3 2 1 2.0  
 14510100 0 1  
 14510101 2 2.125  
 14510201 6 2  
 14510301 0.0 2  
 14510400 0  
 14510401 551.9 3  
 14510501 451010000 0 1 1 2.07 1  
 14510601 0 0 0 1 2.07 1  
 14510701 0 0.0 0.0 0.0 1  
 14510801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 14500000 1 3 2 1 2.0  
 14500100 0 1  
 14500101 2 2.125  
 14500201 6 2  
 14500301 0.0 2  
 14500400 0  
 14500401 551.9 3

14500501 450010000 0 1 1 4.43 1  
 14500601 0 0 0 1 4.43 1  
 14500701 0 0.0 0.0 0.0 1  
 14500801 3. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* Heat structures of down part of reactor vessel  
 \*----1----2----3----4----5----6----7  
 \* 108  
 \*----1----2----3----4----5----6----7  
 11080000 15 3 2 1 2.07  
 11080100 0 1  
 11080101 2 2.27  
 11080201 5 2  
 11080301 0.0 2  
 11080400 0  
 11080401 560. 3  
 11080501 116010000 0 1 1 0.2375 1  
 11080502 107010000 0 1 1 0.2125 2  
 11080503 108010000 0 1 1 0.11125 3  
 11080504 108020000 0 1 1 0.1875 4  
 11080505 108030000 10000 1 1 0.110313 12  
 11080506 108110000 0 1 1 0.0725 13  
 11080507 108120000 0 1 1 0.1415 14  
 11080508 108130000 0 1 1 0.24175 15  
 11080601 0 0 0 1 0.2375 1  
 11080602 0 0 0 1 0.2125 2  
 11080603 0 0 0 1 0.11125 3  
 11080604 0 0 0 1 0.1875 4  
 11080605 0 0 0 1 0.110313 12  
 11080606 0 0 0 1 0.0725 13  
 11080607 0 0 0 1 0.1415 14  
 11080608 0 0 0 1 0.24175 15  
 11080701 0 0.0 0.0 0.0 15  
 11080801 0. 10.0 10.0 0.0 0. 0. 0. 1. 15  
 \*----1----2----3----4----5----6----7  
 \* 208  
 \*----1----2----3----4----5----6----7  
 12080000 15 3 2 1 2.07  
 12080100 0 1  
 12080101 2 2.27  
 12080201 5 2  
 12080301 0.0 2  
 12080400 0

12080401 560. 3  
 12080501 216010000 0 1 1 0.2375 1  
 12080502 207010000 0 1 1 0.2125 2  
 12080503 208010000 0 1 1 0.11125 3  
 12080504 208020000 0 1 1 0.1875 4  
 12080505 208030000 10000 1 1 0.110313 12  
 12080506 208110000 0 1 1 0.0725 13  
 12080507 208120000 0 1 1 0.1415 14  
 12080508 208130000 0 1 1 0.24175 15  
 12080601 0 0 0 1 0.2375 1  
 12080602 0 0 0 1 0.2125 2  
 12080603 0 0 0 1 0.11125 3  
 12080604 0 0 0 1 0.1875 4  
 12080605 0 0 0 1 0.110313 12  
 12080606 0 0 0 1 0.0725 13  
 12080607 0 0 0 1 0.1415 14  
 12080608 0 0 0 1 0.24175 15  
 12080701 0 0.0 0.0 0.0 0. 0. 0. 1. 15  
 \*----1----2----3----4----5----6----7  
 \* 308  
 \*----1----2----3----4----5----6----7  
 13080000 15 3 2 1 2.07  
 13080100 0 1  
 13080101 2 2.27  
 13080201 5 2  
 13080301 0.0 2  
 13080400 0  
 13080401 560. 3  
 13080501 316010000 0 1 1 0.2375 1  
 13080502 327010000 0 1 1 0.2125 2  
 13080503 308010000 0 1 1 0.11125 3  
 13080504 308020000 0 1 1 0.1875 4  
 13080505 308030000 10000 1 1 0.110313 12  
 13080506 308110000 0 1 1 0.0725 13  
 13080507 308120000 0 1 1 0.1415 14  
 13080508 308130000 0 1 1 0.24175 15  
 13080601 0 0 0 1 0.2375 1  
 13080602 0 0 0 1 0.2125 2  
 13080603 0 0 0 1 0.11125 3  
 13080604 0 0 0 1 0.1875 4  
 13080605 0 0 0 1 0.110313 12  
 13080606 0 0 0 1 0.0725 13

13080607 0 0 0 1 0.1415 14  
 13080608 0 0 0 1 0.24175 15  
 13080701 0 0.0 0.0 0.0 15  
 13080801 0. 10.0 10.0 0.0 0. 0. 0. 1. 15  
 \*----1---2---3---4---5---6---7  
 \* 408  
 \*----1---2---3---4---5---6---7  
 14080000 15 3 2 1 2.07  
 14080100 0 1  
 14080101 2 2.27  
 14080201 5 2  
 14080301 0.0 2  
 14080400 0  
 14080401 560. 3  
 14080501 416010000 0 1 1 0.2375 1  
 14080502 407010000 0 1 1 0.2125 2  
 14080503 408010000 0 1 1 0.11125 3  
 14080504 408020000 0 1 1 0.1875 4  
 14080505 408030000 10000 1 1 0.110313 12  
 14080506 408110000 0 1 1 0.0725 13  
 14080507 408120000 0 1 1 0.1415 14  
 14080508 408130000 0 1 1 0.24175 15  
 14080601 0 0 0 1 0.2375 1  
 14080602 0 0 0 1 0.2125 2  
 14080603 0 0 0 1 0.11125 3  
 14080604 0 0 0 1 0.1875 4  
 14080605 0 0 0 1 0.110313 12  
 14080606 0 0 0 1 0.0725 13  
 14080607 0 0 0 1 0.1415 14  
 14080608 0 0 0 1 0.24175 15  
 14080701 0 0.0 0.0 0.0 15  
 \*----1---2---3---4---5---6---7  
 \* 830  
 \*----1---2---3---4---5---6---7  
 18300000 1 3 2 1 0.09  
 18300100 0 1  
 18300101 2 0.097  
 18300201 4 2  
 18300301 0.0 2  
 18300400 0  
 18300401 562.48 3  
 18300501 830010000 0 1 1 207. 1

18300601 830010000 0 1 1 207. 1  
 18300701 0 0.0 0.0 0.0 1  
 18300801 0. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 18300901 0. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1---2---3---4---5---6---7  
 \* 870  
 \*----1---2---3---4---5---6---7  
 18700000 5 3 2 1 0.09  
 18700100 0 1  
 18700101 2 0.097  
 18700201 4 2  
 18700301 0.0 2  
 18700400 0  
 18700401 592. 3  
 18700501 850010000 0 1 1 27.145 1  
 18700502 855010000 0 1 1 51.85 2  
 18700503 855020000 0 1 1 57.95 3  
 18700504 860010000 0 1 1 51.85 4  
 18700505 870010000 0 1 1 122. 5  
 18700601 850010000 0 1 1 27.145 1  
 18700602 855010000 0 1 1 51.85 2  
 18700603 855020000 0 1 1 57.95 3  
 18700604 860010000 0 1 1 51.85 4  
 18700605 870010000 0 1 1 122. 5  
 18700701 0 0.0 0.0 0.0 5  
 18700801 0. 10.0 10.0 0.0 0. 0. 0. 1. 5  
 18700901 0. 10.0 10.0 0.0 0. 0. 0. 1. 5  
 \*----1---2---3---4---5---6---7  
 \* 872  
 \*----1---2---3---4---5---6---7  
 18720000 1 3 2 1 2.07  
 18720100 0 1  
 18720101 2 2.270  
 18720201 5 2  
 18720301 0.0 2  
 18720400 0  
 18720401 592. 3  
 18720501 870010000 0 1 1 2.00 1  
 18720601 0 0.0 0.0 1 2.00 1  
 18720701 0 0.0 0.0 0.0 1  
 18720801 0. 10.0 10.0 0.0 0. 0. 0. 1. 1  
 \*----1---2---3---4---5---6---7  
 \* 880

\*----1----2----3----4----5----6----7  
 18800000 1 3 2 1 0.09  
 18800100 0 1  
 18800101 2 0.097  
 18800201 4 2  
 18800301 0.0 2  
 18800400 0  
 18800401 592.48 3  
 18800501 880010000 0 1 1 130. 1  
 18800601 880010000 0 1 1 130. 1  
 18800701 0 0.0 0.0 0.0 1  
 18800801 0. 10.0 10.0 0.0 0. 0. 1. 1  
 18800901 0. 10.0 10.0 0.0 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* 831  
 \*----1----2----3----4----5----6----7  
 18310000 1 3 1 1 0.0  
 18310100 0 1  
 18310101 2 0.06  
 18310201 4 2  
 18310301 0.0 2  
 18310400 0  
 18310401 562.48 3  
 18310501 830010000 0 1 1 10.2 1  
 18310601 829010000 0 1 1 10.2 1  
 18310701 0 0.0 0.0 0.0 1  
 18310801 0. 10.0 10.0 0.0 0. 0. 1. 1  
 18310901 0. 10.0 10.0 0.0 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7  
 \* 882  
 \*----1----2----3----4----5----6----7  
 18820000 1 3 2 1 2.07  
 18820100 0 1  
 18820101 2 2.270  
 18820201 5 2  
 18820301 0.0 2  
 18820400 0  
 18820401 592. 3  
 18820501 880010000 0 1 1 1.235 1  
 18820601 0 0 0 1 1.235 1  
 18820701 0 0.0 0.0 0.0 1  
 18820801 0. 10.0 10.0 0.0 0. 0. 1. 1  
 \*----1----2----3----4----5----6----7

\*----Core barrel - Reactor vessel internals - Lower part  
 \*----1----2----3----4----5----6----7  
 \* 844  
 \*----1----2----3----4----5----6----7  
 18441000 14 3 2 1 1.745  
 18441100 0 1  
 18441101 2 1.805  
 18441201 5 2  
 18441301 0.0 2  
 18441400 0  
 18441401 570. 3  
 18441501 830010000 0 1 1 0.1415 1  
 18441502 843010000 0 1 1 0.0725 2  
 18441503 843020000 10000 1 1 0.1103 10  
 18441504 843100000 0 1 1 0.1875 11  
 18441505 850010000 0 1 1 0.11125 12  
 18441506 855010000 0 1 1 0.2125 13  
 18441507 855020000 0 1 1 0.2375 14  
 18441601 108120000 0 1 1 0.1415 1  
 18441602 108110000 0 1 1 0.0725 2  
 18441603 108100000 0 1 1 0.1103 3  
 18441604 108090000 0 1 1 0.1103 4  
 18441605 108080000 0 1 1 0.1103 5  
 18441606 108070000 0 1 1 0.1103 6  
 18441607 108060000 0 1 1 0.1103 7  
 18441608 108050000 0 1 1 0.1103 8  
 18441609 108040000 0 1 1 0.1103 9  
 18441610 108030000 0 1 1 0.1103 10  
 18441611 108020000 0 1 1 0.1875 11  
 18441612 108010000 0 1 1 0.11125 12  
 18441613 107010000 0 1 1 0.2125 13  
 18441614 116010000 0 1 1 0.2375 14  
 18441701 0 0.0 0.0 0.0 14  
 18441801 0. 10.0 10.0 0.0 0. 0. 0. 1. 14  
 18441901 0. 10.0 10.0 0.0 0. 0. 0. 1. 14  
 \*----1----2----3----4----5----6----7  
 \*----Core barrel - Reactor vessel internals - Lower part  
 \*----1----2----3----4----5----6----7  
 18442000 14 3 2 1 1.745  
 18442100 0 1  
 18442101 2 1.805  
 18442201 5 2  
 18442301 0.0 2

18442400 0  
 18442401 570. 3  
 18442501 830010000 0 1 1 0.1415 1  
 18442502 843010000 0 1 1 0.0725 2  
 18442503 843020000 10000 1 1 0.1103 10  
 18442504 843100000 0 1 1 0.1875 11  
 18442505 850010000 0 1 1 0.11125 12  
 18442506 855010000 0 1 1 0.2125 13  
 18442507 855020000 0 1 1 0.2375 14  
 18442601 208120000 0 1 1 0.1415 1  
 18442602 208110000 0 1 1 0.0725 2  
 18442603 208100000 0 1 1 0.1103 3  
 18442604 208090000 0 1 1 0.1103 4  
 18442605 208080000 0 1 1 0.1103 5  
 18442606 208070000 0 1 1 0.1103 6  
 18442607 208060000 0 1 1 0.1103 7  
 18442608 208050000 0 1 1 0.1103 8  
 18442609 208040000 0 1 1 0.1103 9  
 18442610 208030000 0 1 1 0.1103 10  
 18442611 208020000 0 1 1 0.1875 11  
 18442612 208010000 0 1 1 0.11125 12  
 18442613 207010000 0 1 1 0.2125 13  
 18442614 216010000 0 1 1 0.2375 14  
 18442701 0 0.0 0.0 0.0 14  
 18442801 0. 10.0 10.0 0.0 0. 0. 0. 1. 14  
 18442901 0. 10.0 10.0 0.0 0. 0. 0. 1. 14  
 \*----1----2----3----4----5----6----7  
 \*----Core barrel - Reactor vessel internals - Lower part  
 \*----1----2----3----4----5----6----7  
 18443000 14 3 2 1 1.745  
 18443100 0 1  
 18443101 2 1.805  
 18443201 5 2  
 18443301 0.0 2  
 18443400 0  
 18443401 570. 3  
 18443501 830010000 0 1 1 0.1415 1  
 18443502 843010000 0 1 1 0.0725 2  
 18443503 843020000 10000 1 1 0.1103 10  
 18443504 843100000 0 1 1 0.1875 11  
 18443505 850010000 0 1 1 0.11125 12  
 18443506 855010000 0 1 1 0.2125 13  
 18443507 855020000 0 1 1 0.2375 14

18443601 308120000 0 1 1 0.1415 1  
 18443602 308110000 0 1 1 0.0725 2  
 18443603 308100000 0 1 1 0.1103 3  
 18443604 308090000 0 1 1 0.1103 4  
 18443605 308080000 0 1 1 0.1103 5  
 18443606 308070000 0 1 1 0.1103 6  
 18443607 308060000 0 1 1 0.1103 7  
 18443608 308050000 0 1 1 0.1103 8  
 18443609 308040000 0 1 1 0.1103 9  
 18443610 308030000 0 1 1 0.1103 10  
 18443611 308020000 0 1 1 0.1875 11  
 18443612 308010000 0 1 1 0.11125 12  
 18443613 307010000 0 1 1 0.2125 13  
 18443614 316010000 0 1 1 0.2375 14  
 18443701 0 0.0 0.0 0.0 14  
 18443801 0. 10.0 10.0 0.0 0. 0. 0. 1. 14  
 18443901 0. 10.0 10.0 0.0 0. 0. 0. 1. 14  
 \*----1----2----3----4----5----6----7  
 \*----Core barrel - Reactor vessel internals - Lower part  
 \*----1----2----3----4----5----6----7  
 18444000 14 3 2 1 1.745  
 18444100 0 1  
 18444101 2 1.805  
 18444201 5 2  
 18444301 0.0 2  
 18444400 0  
 18444401 570. 3  
 18444501 830010000 0 1 1 0.1415 1  
 18444502 843010000 0 1 1 0.0725 2  
 18444503 843020000 10000 1 1 0.1103 10  
 18444504 843100000 0 1 1 0.1875 11  
 18444505 850010000 0 1 1 0.11125 12  
 18444506 855010000 0 1 1 0.2125 13  
 18444507 855020000 0 1 1 0.2375 14  
 18444601 408120000 0 1 1 0.1415 1  
 18444602 408110000 0 1 1 0.0725 2  
 18444603 408100000 0 1 1 0.1103 3  
 18444604 408090000 0 1 1 0.1103 4  
 18444605 408080000 0 1 1 0.1103 5  
 18444606 408070000 0 1 1 0.1103 6  
 18444607 408060000 0 1 1 0.1103 7  
 18444608 408050000 0 1 1 0.1103 8  
 18444609 408040000 0 1 1 0.1103 9

18444610	408030000 0	1	1	0.1103	10		8050901	.50	.50	2										
18444611	408020000 0	1	1	0.1875	11		8051001	0		3										
18444612	408010000 0	1	1	0.11125	12		8051101	0001000		2										
18444613	407010000 0	1	1	0.2125	13		8051201	110	15672361.	1461525.	2443784.	0. 0.	1							
18444614	416010000 0	1	1	0.2375	14		8051202	110	15689145.	1503750.	2443389.	0. 0.	2							
18444701	0	0.0	0.0	0.0	14		8051203	110	15683264.	1529307.	2443527.	0. 0.	3							
18444801	0.	10.0	10.0	0.0	0.	0.	0.	0.	1.	14		8052001	.00695037		1					
18444901	0.	10.0	10.0	0.0	0.	0.	0.	0.	1.	14		8052002	.00695002		2					
*----1----	2----	3----	4----	5----	6----	7	8052003	.00694977		3										
*--- Core barrel - Reactor vessel internals - Upper part																				
*----1----	2----	3----	4----	5----	6----	7	8051300	0												
18461000	3	3	2	1	1.745		8051301	1.91311-4	1.91311-4	0.	1	*	.0119874							
18461100	0	1					8051302	1.945838-4	1.945838-4	0.	2	*	.0118324							
18461101	2	1.805					*----1----	2----	3----	4----	5----	6----	7							
18461201	5	2					*	P	R	E	S	S	U	R	I	Z	E	R	*	
18461301	0.0	2					*----1----	2----	3----	4----	5----	6----	7							
18461400	0						*	806	lower	pressurizer										
18461401	590.	3					8060000	lprzer	branch											
18461501	860010000 0	1	1	0.850	1		8060001	2	0											
18461502	870010000 0	1	1	2.00	2		8060101	0.0	.40000	1.43252	0	90.	.40000	0.	0.094	0				
18461503	880010000 0	1	1	1.235	3		8060200	110	15676167.	1556932.	2443695.	0.	.00694989							
18461601	860010000 0	1	1	0.850	1		8061101	806010000	307000000	0	0	0	100							
18461602	870010000 0	1	1	2.00	2		8062101	805030002	806010001	0.094	0.5	0.5	000100							
18461603	880010000 0	1	1	1.235	3		8061201	5.12072-6	5.12101-6	0.	*	.01138047								
18461701	0	0.0	0.0	0.0	3		8062201	1.952666-4	1.953755-4	0.	*	.0116469								
18461801	0.	10.0	10.0	0.0	0.	0.	0.	0.	1.	3		*----1----	2----	3----	4----	5----	6----	7		
18461901	0.	10.0	10.0	0.0	0.	0.	0.	0.	1.	3		*	307	pressurizer						
*----1----	2----	3----	4----	5----	6----	7	*----1----	2----	3----	4----	5----	6----	7							
* Surge Line 805																				
*----1----	2----	3----	4----	5----	6----	7	3070000	przer	pipe											
8050000	surgelin pipe						3070001	5												
8050001	3						3070101	7.0686		1										
8050101	0.094		3				3070102	6.1610		4										
8050301	5.56000		1				3070103	7.0686		5										
8050302	10.5500		2				3070301	2.17720		1										
8050303	1.89000		3				3070302	2.04593		4										
8050601	-90.		1				3070303	1.59000		5										
8050602	0.0		2				3070601	90.0		5										
8050603	90.0		3				3070801	0	0	5										
8050701	-5.13500		1				3071001	0		5										
8050702	0.00000		2				3071101	0001000		4										
8050703	1.89000		3				3071201	110	15668438.	1576622.	2443877.	0.	0.	1						
8050801	2.5-5	0.346		3			3071202	110	15655981.	1608179.	2444171.	0.	0.	2						
							3071203	110	15644103.	1609957.	2444451.	0.	0.	3						
							3071204	110	15632228.	1608646.	2444731.	0.	0.	4						

3071205 110 15625361. 1609066. 2447336. .967415 0. 5  
 3072001 .00694926 1  
 3072002 .0069501 2  
 3072003 .00695028 3  
 3072004 .00694697 4  
 3072005 .00695726 5  
 3071300 0  
 3071301 -1.248884-6 -1.2489-6 0. 1 \* -.00455965  
 3071302 -1.151385-6 -1.1514-6 0. 2 \* -.00419584  
 3071303 -1.120418-6 -1.120432-6 0. 3 \* -.00408814  
 3071304 -3.50111-5 .405436 0. 4 \* -.004160755  
 \*----1----2----3----4----5----6----7  
 3700000 hprzer branch  
 3700001 1 0  
 3700101 0.0 1.44500 6.06 0 90. 1.44500 0. 0. 0  
 3700200 100 15623718. 1609403. 2455042. 1.  
 3701101 307010000 370000000 0 0 0 100  
 3701201 -2.15328 -1.992973-6 0. \* -8.46447-4  
 \*----1----2----3----4----5----6----7  
 3770000 hprzer branch  
 3770001 1 0  
 3770101 0.0 1.00000 3.80 0 90. 1.00000 0. 0. 0  
 3770200 100 15622503. 1609358. 2453594. 1.  
 3771101 370010000 377000000 0 0 0 100  
 3771201 -8.45896-7 -8.45874-7 0. \* -3.26377-4  
 \*----1----2----3----4----5----6----7  
 \* pressurizer spray system pipe  
 \*----1----2----3----4----5----6----7  
 3800000 prz-spr pipe  
 3800001 3  
 3800101 0.02573 3  
 3800301 10.0 1  
 3800302 18.12001 2  
 3800303 9.87999 3  
 3800601 0.0 1  
 3800602 0.0 2  
 3800603 90. 3  
 3800801 4.5-5 0.09 3  
 3800901 .20 .20 2  
 3801001 0 3  
 3801101 0 2  
 3801201 110 16025531. 1258493. 2435085. 0. 0. 1  
 3801202 110 16025531. 1255145. 2435085. 0. 0. 2

3801203 110 15989160. 1253152. 2436064. 0. 0. 3  
 3802001 .00695 1  
 3802002 .00695 2  
 3802003 .00695 3  
 3801300 0  
 3801301 -6.96173-11 -6.96173-11 0. 1 \* -1.343616-9  
 3801302 -4.31736-11 -3.094704-11 0. 2 \* -8.34-10  
 \*----1----2----3----4----5----6----7  
 \* MAIN COOLANT PUMP \*  
 \*----1----2----3----4----5----6----7  
 \* MCP # 1  
 \*----1----2----3----4----5----6----7  
 \* 144  
 \*----1----2----3----4----5----6----7  
 1440000 rcpa pump  
 \*crdno area length volume h-ang v-ang delz ctl  
 1440101 .5 0. 3. 0 0.0 0.0 0  
 \*crdno from area floss rloss flag  
 1440108 142070002 0. .1 .1 0001000  
 \*crdno to area floss rloss flag  
 1440109 145010001 0. .1 .1 0001000  
 \*1040110 0.8 0. 1. 1. \* 0  
 \*1040111 0.8 0. 1. 1. \* 0  
 \*crdno ctl pressure temp  
 1440200 110 15668743. 1248890. 2443870. 0. .00695058  
 \*crdno ctl flowf flowg velj  
 1440201 1 4405. 4405. 0. \* 0 12.09146 12.75088 0. \* 4551.31  
 1440202 1 4405. 4405. 0. \* 0 12.08868 12.08868 0. \* 4551.3  
 \*crdno id 2fafz 2fazd tork pvel ptrip rvrs  
 1440301 0 0 0 -1 0 432 0  
 \*crdno rpvel initv rflo rhead rtork momi rdens  
 1440302 104.1986 1. 5.88889 82.90 47500. 7600. 0.0  
 \*crdno rmotk tf2 tf0 tf1 tf3  
 1440303 0. 0.0 400.0 0.0 0.  
 1440310 0.0 0.0 0.0  
 1446100 499  
 1446101 -1. 104.1964  
 1446102 0. 104.1964  
 1446103 0.5 103.46  
 1446104 1. 98.44  
 1446105 1.5 96.03  
 1446106 2. 93.72  
 1446107 2.5 91.42

1446108 3.0 89.33  
 1446109 3.5 87.23  
 1446110 4.0 85.14  
 1446111 5.0 81.68  
 1446112 7.0 74.98  
 1446113 10. 67.02  
 1446114 15.0 56.76  
 1446115 20.0 45.87  
 1446116 25.0 43.77  
 1446117 30.0 39.06  
 1446118 50.0 26.91  
 1446119 90.0 15.71  
 1446120 135.0 9.42  
 1446121 180.0 5.76  
 1446122 210. 3.98  
 1446123 232. 0.  
 1446124 10000. 0.  
 1446125 10.+6 0.  
 \*----1----2----3----4----5----6----7  
 \*- Single phase head curve  
 1441100 1 1  
 \* independ dependent  
 1441101 0.0 1.56 0.179 1.47 0.304 1.42  
 1441102 0.431 1.39 0.582 1.35 0.86 1.18  
 1441103 0.966 1.08 1.0 1.0  
 1441200 1 2  
 1441201 0.0 -1.4 0.161 -1.1 0.247 -0.93  
 1441202 0.315 -.78 0.424 -.54 0.5 -.35  
 1441203 0.556 -.21 0.61 -.08 0.673 0.1  
 1441204 0.736 0.26 0.815 0.45 0.904 0.73  
 1441205 1.0 1.00  
 \*----1----2----3----4----5----6----7  
 1441300 1 3  
 1441301 -1.0 4.00 -.823 2.3 -.770 2.13  
 1441302 -.720 2.13 -.5710 2.07 -.4500 1.92  
 1441303 -.12 1.70 0.0 1.56  
 \*----1----2----3----4----5----6----7  
 1441400 1 4  
 1441401 -1.0 4.00 -.767 2.94 -.5000 2.5  
 1441402 0.0 1.76  
 \*----1----2----3----4----5----6----7  
 1441500 1 5  
 1441501 0.0 0.0 0.077 0.08 0.110 0.11

1441502 0.15 0.15 0.208 0.21 0.25 0.25  
 1441503 0.286 0.29 0.333 0.330 0.381 0.38  
 1441504 0.73 0.73 0.80 0.8 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 1441600 1 6  
 1441601 0.0 1.76 0.041 1.70 0.2111 1.53  
 1441602 0.324 1.41 0.3804 1.34 0.473 1.25  
 1441603 0.611 1.11 0.8652 1.01 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 1441700 1 7  
 1441701 -1.0 -2.78 -.913 -2.54 -.839 -2.33  
 1441702 -.659 -1.830 -.570 -1.58 -.5260 -1.46  
 1441703 -.475 -1.32 -.410 -1.14 -.327 -.91  
 1441704 -.210 -.58 -.119 -.33 -.0600 -.17  
 1441705 0.0 0.0  
 \*----1----2----3----4----5----6----7  
 1441800 1 8  
 1441801 -1.0 -2.78 -.881 -2.62 -.730 -2.41  
 1441802 -.453 -2.03 -.368 -.191 0.0 -.14  
 \*----1----2----3----4----5----6----7  
 \* Single phase torque curve  
 1441900 2 1  
 1441901 0.0 0.8 0.084 0.80 0.294 0.82  
 1441902 0.406 0.83 0.575 0.880 0.920 0.98  
 1441903 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 1442000 2 2  
 1442002 0.0 -.81 0.111 -.590 0.185 -.440  
 1442003 0.240 -.33 0.308 -.20 0.340 -.140  
 1442004 0.378 -.06 0.418 0.03 0.483 0.17  
 1442005 0.530 0.230 0.574 0.30 0.633 0.39  
 1442006 0.694 0.500 0.790 0.63 0.97 0.95  
 1442007 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 1442100 2 3  
 1442101 -1.0 2.46 -.969 2.340 -.930 2.19  
 1442102 -.796 1.68 -.615 1.37 -.476 1.09  
 1442103 -.359 0.98 -.307 0.930 -.088 0.81  
 1442104 0.0 0.8  
 \*----1----2----3----4----5----6----7  
 1442200 2 4  
 1442201 -1.0 2.460 -.950 2.40 -.86 2.280  
 1442202 -.702 2.120 -.440 1.86 0.0 1.5

\*----1----2----3----4----5----6----7  
 1442300 2 5  
 1442301 0.0 -1.3 0.091 -1.10 0.194 -.880  
 1442302 0.313 -.70 0.4650 -.38 0.754 0.190  
 1442303 0.876 0.43 1.0 0.67  
 \*----1----2----3----4----5----6----7  
 1442400 2 6  
 1442401 0.0 1.5 0.067 1.45 0.113 1.410  
 1442402 0.239 1.33 0.565 1.06 0.681 0.96  
 1442403 0.956 0.710 1.0 0.670  
 \*----1----2----3----4----5----6----7  
 1442500 2 7  
 1442501 -1.0 -3.97 0.0 -1.3  
 \*4----1----2----3----4----5----6----7  
 1442600 2 8  
 1442601 -1.0 -3.97 -.833 -3.440 -.60 -2.7  
 1442602 -.333 -1.860 -.186 -1.4 -.075 -1.05  
 1442603 0.0 -.810  
 \*4----1----2----3----4----5----6----7  
 1443000 0 0.0 0.0 0.07 0.0 0.08 0.74  
 1443001 0.165 1.0 0.9 1.0 1.0 0.0  
 \*4----1----2----3----4----5----6----7  
 1443100 0 0.0 0.0 1.00 0.0  
 \*4----1----2----3----4----5----6----7  
 1444100 1 1 0.0 0.0 0.10 0.83 0.20 1.09  
 1444101 0.5 1.02 0.7 1.01 0.90 0.94  
 1444102 1.00 1.00  
 \*4----1----2----3----4----5----6----7  
 1444200 1 2 0.0 0.0 0.10 -0.04 0.20 0.00  
 1444201 0.3 0.10 0.4 0.21 0.80 0.67  
 1444202 0.90 0.80 1.00 1.00  
 \*4----1----2----3----4----5----6----7  
 1444300 1 3 -1.00 -1.16 -0.90 -1.24 -0.80 -1.77  
 1444301 -0.70 -2.36 -0.60 -2.79 -0.50 -2.91  
 1444302 -.40 -2.67 -0.25 -1.69 -0.10 -0.50  
 1444303 0.00 0.00  
 \*4----1----2----3----4----5----6----7  
 1444400 1 4 -1.00 -1.16 -0.90 -0.78 -0.80 -0.50  
 1444401 -0.70 -0.31 -0.60 -0.17 -0.50 -0.08  
 1444402 -.35 0.00 -0.20 0.05 -0.10 0.08  
 1444403 0.00 0.11  
 \*4----1----2----3----4----5----6----7  
 1444500 1 5 0.00 0.00 0.20 -0.34 0.40 -0.65

1444501 0.60 -0.95 0.80 -1.19 1.00 -1.47  
 \*4----1----2----3----4----5----6----7  
 1444600 1 6 0.00 0.11 0.10 0.13 0.25 0.15  
 1444601 0.40 0.13 0.50 0.07 0.60 -0.04  
 1444602 0.70 -0.23 0.80 -0.51 0.90 -0.91  
 1444603 1.00 -1.47  
 \*4----1----2----3----4----5----6----7  
 1444700 1 7 -1.00 0.00 0.00 0.00  
 \*4----1----2----3----4----5----6----7  
 1444800 1 8 -1.00 0.00 0.00 0.00  
 \*----1----2----3----4----5----6----7  
 1444900 2 1 0.00 0.00 1.00 0.00  
 1445000 2 2 0.00 0.00 1.00 0.00  
 1445100 2 3 -1.00 0.00 0.00 0.00  
 1445200 2 4 -1.00 0.00 0.00 0.00  
 1445300 2 5 0.00 0.00 1.00 0.00  
 1445400 2 6 0.00 0.00 1.00 0.00  
 1445500 2 7 -1.00 0.00 0.00 0.00  
 1445600 2 8 -1.00 0.00 0.00 0.00  
 \*----1----2----3----4----5----6----7  
 \* MCP # 2  
 \*----1----2----3----4----5----6----7  
 \* 244  
 \*----1----2----3----4----5----6----7  
 2440000 rcpa pump  
 \*crdno area length volume h-ang v-ang delz ctl  
 2440101 .5 0. 3. 0 0.0 0.0 0  
 \*crdno from area floss rlloss flag  
 2440108 242070002 0. .1 .1 0001000  
 \*crdno to area floss rlloss flag  
 2440109 245010001 0. .1 .1 0001000  
 \*1040110 0.8 0. 1. 1. \* 0  
 \*1040111 0.8 0. 1. 1. \* 0  
 \*crdno ctl pressure temp  
 2440200 110 15669981. 1249018. 2443840. 0. .00695058  
 \*crdno ctl flowf flowg velj  
 2440201 1 4405. 4405. 0. \* 0 12.09146 12.7508 0. \* 4544.935  
 2440202 1 4405. 4405. 0. \* 0 12.08868 12.08868 0. \* 4544.93  
 \*crdno id 2fafz 2fafzd tork pvel ptrip rvrs  
 2440301 0 144 144 -1 0 432 0  
 \*crdno rpvel initv rflo rhead rtork momi rdens  
 2440302 104.1986 1. 5.88889 82.90 47500. 7600. 0.0  
 \*crdno rmotk tf2 tf0 tfl tf3

2440303 0. 0.0 400.0 0.0 0.  
 2440310 0.0 0.0 0.0  
 2446100 499  
 2446101 -1. 104.1964  
 2446102 0. 104.1964  
 2446103 0.5 103.46  
 2446104 1. 98.44  
 2446105 1.5 96.03  
 2446106 2. 93.72  
 2446107 2.5 91.42  
 2446108 3.0 89.33  
 2446109 3.5 87.23  
 2446110 4.0 85.14  
 2446111 5.0 81.68  
 2446112 7.0 74.98  
 2446113 10. 67.02  
 2446114 15.0 56.76  
 2446115 20.0 45.87  
 2446116 25.0 43.77  
 2446117 30.0 39.06  
 2446118 50.0 26.91  
 2446119 90.0 15.71  
 2446120 135.0 9.42  
 2446121 180.0 5.76  
 2446122 210. 3.98  
 2446123 232. 0.  
 2446124 10000. 0.  
 2446125 10.+6 0.  
 \*----1----2----3----4----5----6----7  
 \*- Single phase head curve  
 2441100 1 1  
 \* indep dependent  
 2441101 0.0 1.56 0.179 1.47 0.304 1.42  
 2441102 0.431 1.39 0.582 1.35 0.86 1.18  
 2441103 0.966 1.08 1.0 1.0  
 2441200 1 2  
 2441201 0.0 -1.4 0.161 -1.1 0.247 -0.93  
 2441202 0.315 -.78 0.424 -.54 0.5 -.35  
 2441203 0.556 -.21 0.61 -.08 0.673 0.1  
 2441204 0.736 0.26 0.815 0.45 0.904 0.73  
 2441205 1.0 1.00  
 \*----1----2----3----4----5----6----7  
 2441300 1 3

2441301 -1.0 4.00 -.823 2.3 -.770 2.13  
 2441302 -.720 2.13 -.5710 2.07 -.4500 1.92  
 2441303 -.12 1.70 0.0 1.56  
 \*----1----2----3----4----5----6----7  
 2441400 1 4  
 2441401 -1.0 4.00 -.767 2.94 -.5000 2.5  
 2441402 0.0 1.76  
 \*----1----2----3----4----5----6----7  
 2441500 1 5  
 2441501 0.0 0.0 0.077 0.08 0.110 0.11  
 2441502 0.15 0.15 0.208 0.21 0.25 0.25  
 2441503 0.286 0.29 0.333 0.330 0.381 0.38  
 2441504 0.73 0.73 0.80 0.8 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 2441600 1 6  
 2441601 0.0 1.76 0.041 1.70 0.2111 1.53  
 2441602 0.324 1.41 0.3804 1.34 0.473 1.25  
 2441603 0.611 1.11 0.8652 1.01 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 2441700 1 7  
 2441701 -1.0 -2.78 -.913 -2.54 -.839 -2.33  
 2441702 -.659 -1.830 -.570 -1.58 -.5260 -1.46  
 2441703 -.475 -1.32 -.410 -1.14 -.327 -0.91  
 2441704 -.210 -.58 -.119 -.33 -.0600 -.17  
 2441705 0.0 0.0  
 \*----1----2----3----4----5----6----7  
 2441800 1 8  
 2441801 -1.0 -2.78 -.881 -2.62 -.730 -2.41  
 2441802 -.453 -2.03 -.368 -1.91 0.0 -1.4  
 \*----1----2----3----4----5----6----7  
 \*4 Single phase torque curve  
 2441900 2 1  
 2441901 0.0 0.8 0.084 0.80 0.294 0.82  
 2441902 0.406 0.83 0.575 0.880 0.920 0.98  
 2441903 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 2442000 2 2  
 2442002 0.0 -.81 0.111 -.590 0.185 -.440  
 2442003 0.240 -.33 0.308 -.20 0.340 -.140  
 2442004 0.378 -.06 0.418 0.03 0.483 0.17  
 2442005 0.530 0.230 0.574 0.30 0.633 0.39  
 2442006 0.694 0.500 0.790 0.63 0.97 0.95  
 2442007 1.0 1.0

\*----1----2----3----4----5----6----7  
 2442100 2 3  
 2442101 -1.0 2.46 -.969 2.340 -.930 2.19  
 2442102 -.796 1.68 -.615 1.37 -.476 1.09  
 2442103 -.359 0.98 -.307 0.930 -.088 0.81  
 2442104 0.0 0.8  
 \*----1----2----3----4----5----6----7  
 2442200 2 4  
 2442201 -1.0 2.460 -.950 2.40 -.86 2.280  
 2442202 -.702 2.120 -.440 1.86 0.0 1.5  
 \*----1----2----3----4----5----6----7  
 2442300 2 5  
 2442301 0.0 -1.3 0.091 -1.10 0.194 -.880  
 2442302 0.313 -.70 0.4650 -.38 0.754 0.190  
 2442303 0.876 0.43 1.0 0.67  
 \*----1----2----3----4----5----6----7  
 2442400 2 6  
 2442401 0.0 1.5 0.067 1.45 0.113 1.410  
 2442402 0.239 1.33 0.565 1.06 0.681 0.96  
 2442403 0.956 0.710 1.0 0.670  
 \*----1----2----3----4----5----6----7  
 2442500 2 7  
 2442501 -1.0 -3.97 0.0 -1.3  
 \*----1----2----3----4----5----6----7  
 2442600 2 8  
 2442601 -1.0 -3.97 -.833 -3.440 -.60 -2.7  
 2442602 -.333 -1.860 -.186 -1.4 -.075 -1.05  
 \*----1----2----3----4----5----6----7  
 \* MCP #3  
 \*----1----2----3----4----5----6----7  
 \* 344  
 \*----1----2----3----4----5----6----7  
 3440000 rcpa pump  
 \*crdno area length volume h-ang v-ang delz ctl  
 3440101 .5 0. 3. 0 0.0 0.0 0  
 \*crdno from area floss rlloss flag  
 3440108 342070002 0. .1 .1 0001000  
 \*crdno to area floss rlloss flag  
 3440109 345010001 0. .1 .1 0001000  
 \*1040110 0.8 0. 1. 1. \* 0  
 \*1040111 0.8 0. 1. 1. \* 0  
 \*crdno ctl pressure temp  
 3440200 110 15669981. 1249018. 2443840. 0. .00695058

\*crdno ctl flowf flowg velj  
 3440201 1 4405. 4405. 0. \* 0 12.09146 12.7508 0. \* 4544.935  
 3440202 1 4405. 4405. 0. \* 0 12.08868 12.08868 0. \* 4544.93  
 \*crdno id 2faz 2fazd tork pvel ptrip rvrs  
 3440301 0 144 144 -1 0 432 0  
 \*crdno rpvel initv rflo rhead rtork momi rdens  
 3440302 104.1986 1. 5.88889 82.90 47500. 7600. 0.0  
 \*crdno rmotk tf2 tf0 tf1 tf3  
 3440303 0. 0.0 400.0 0.0 0.  
 3440310 0.0 0.0 0.0  
 3446100 499  
 3446101 -1. 104.1964  
 3446102 0. 104.1964  
 3446103 0.5 103.46  
 3446104 1. 98.44  
 3446105 1.5 96.03  
 3446106 2. 93.72  
 3446107 2.5 91.42  
 3446108 3.0 89.33  
 3446109 3.5 87.23  
 3446110 4.0 85.14  
 3446111 5.0 81.68  
 3446112 7.0 74.98  
 3446113 10. 67.02  
 3446114 15.0 56.76  
 3446115 20.0 45.87  
 3446116 25.0 43.77  
 3446117 30.0 39.06  
 3446118 50.0 26.91  
 3446119 90.0 15.71  
 3446120 135.0 9.42  
 3446121 180.0 5.76  
 3446122 210. 3.98  
 3446123 232. 0.  
 3446124 10000. 0.  
 3446125 10.+6 0.  
 \*----1----2----3----4----5----6----7  
 \* Single phase head curve  
 3441100 1 1  
 \* indep dependent  
 3441101 0.0 1.56 0.179 1.47 0.304 1.42  
 3441102 0.431 1.39 0.582 1.35 0.86 1.18  
 3441103 0.966 1.08 1.0 1.0

3441200 1 2  
 3441201 0.0 -1.4 0.161 -1.1 0.247 -0.93  
 3441202 0.315 -.78 0.424 -.54 0.5 -.35  
 3441203 0.556 -.21 0.61 -.08 0.673 0.1  
 3441204 0.736 0.26 0.815 0.45 0.904 0.73  
 3441205 1.0 1.00  
 \*----1----2----3----4----5----6----7  
 3441300 1 3  
 3441301 -1.0 4.00 -.823 2.3 -.770 2.13  
 3441302 -.720 2.13 -.5710 2.07 -.4500 1.92  
 3441303 -.12 1.70 0.0 1.56  
 \*----1----2----3----4----5----6----7  
 3441400 1 4  
 3441401 -1.0 4.00 -.767 2.94 -.5000 2.5  
 3441402 0.0 1.76  
 \*----1----2----3----4----5----6----7  
 3441500 1 5  
 3441501 0.0 0.0 0.077 0.08 0.110 0.11  
 3441502 0.15 0.15 0.208 0.21 0.25 0.25  
 3441503 0.286 0.29 0.333 0.330 0.381 0.38  
 3441504 0.73 0.73 0.80 0.8 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 3441600 1 6  
 3441601 0.0 1.76 0.041 1.70 0.2111 1.53  
 3441602 0.324 1.41 0.3804 1.34 0.473 1.25  
 3441603 0.611 1.11 0.8652 1.01 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 3441700 1 7  
 3441701 -1.0 -2.78 -.913 -2.54 -.839 -2.33  
 3441702 -.659 -1.830 -.570 -1.58 -.5260 -1.46  
 3441703 -.475 -1.32 -.410 -1.14 -.327 -.91  
 3441704 -.210 -.58 -.119 -.33 -.0600 -.17  
 3441705 0.0 0.0  
 \*----1----2----3----4----5----6----7  
 3441800 1 8  
 3441801 -1.0 -2.78 -.881 -2.62 -.730 -2.41  
 3441802 -.453 -2.03 -.368 -1.91 0.0 -1.4  
 \*----1----2----3----4----5----6----7  
 \* Single phase torque curve  
 3441900 2 1  
 3441901 0.0 0.8 0.084 0.80 0.294 0.82  
 3441902 0.406 0.83 0.575 0.880 0.920 0.98  
 3441903 1.0 1.0

\*----1----2----3----4----5----6----7  
 3442000 2 2  
 3442002 0.0 -.81 0.111 -.590 0.185 -.440  
 3442003 0.240 -.33 0.308 -.20 0.340 -.140  
 3442004 0.378 -.06 0.418 0.03 0.483 0.17  
 3442005 0.530 0.230 0.574 0.30 0.633 0.39  
 3442006 0.694 0.500 0.790 0.63 0.97 0.95  
 3442007 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 3442100 2 3  
 3442101 -1.0 2.46 -.969 2.340 -.930 2.19  
 3442102 -.796 1.68 -.615 1.37 -.476 1.09  
 3442103 -.359 0.98 -.307 0.930 -.088 0.81  
 3442104 0.0 0.8  
 \*----1----2----3----4----5----6----7  
 3442200 2 4  
 3442201 -1.0 2.460 -.950 2.40 -.86 2.280  
 3442202 -.702 2.120 -.440 1.86 0.0 1.5  
 \*----1----2----3----4----5----6----7  
 3442300 2 5  
 3442301 0.0 -1.3 0.091 -1.10 0.194 -.880  
 3442302 0.313 -.70 0.4650 -.38 0.754 0.190  
 3442303 0.876 0.43 1.0 0.67  
 \*----1----2----3----4----5----6----7  
 3442400 2 6  
 3442401 0.0 1.5 0.067 1.45 0.113 1.410  
 3442402 0.239 1.33 0.565 1.06 0.681 0.96  
 3442403 0.956 0.710 1.0 0.670  
 \*----1----2----3----4----5----6----7  
 3442500 2 7  
 3442501 -1.0 -3.97 0.0 -1.3  
 \*----1----2----3----4----5----6----7  
 3442600 2 8  
 3442601 -1.0 -3.97 -.833 -3.440 -.60 -2.7  
 3442602 -.333 -1.860 -.186 -1.4 -.075 -1.05  
 3442603 0.0 -.810  
 \*----1----2----3----4----5----6----7  
 \* MCP # 4  
 \*----1----2----3----4----5----6----7  
 \* 444  
 \*----1----2----3----4----5----6----7  
 4440000 rcpa pump  
 \*crdno area length volume h-ang v-ang delz ctl

4440101 .5 0. 3. 0 0.0 0.0 0  
 \*crdno from area floss rloss flag  
 4440108 442070002 0. .1 .1 0001000  
 \*crdno to area floss rloss flag  
 4440109 445010001 0. .1 .1 0001000  
 \*1040110 0.8 0. 1. 1. \* 0  
 \*1040111 0.8 0. 1. 1. \* 0  
 \*crdno ctl pressure temp  
 4440200 110 15669979. 1248960. 2443840. 0. .00695058  
 \*crdno ctl flowf flowg velj  
 4440201 1 4405. 4405. 0. \* 0 12.0934 12.75281 0. \* 4545.79  
 4440202 1 4405. 4405. 0. \* 0 12.09063 12.09063 0. \* 4545.79  
 \*crdno id 2fazd tork pvel ptrip rvs  
 4440301 0 144 144 -1 0 432 0  
 \*crdno rpvel initv rflo rhead rtork momi rdens  
 4440302 104.1986 1. 5.88889 82.90 47500. 7600. 0.0  
 \*crdno rmotk tf2 tf0 tf1 tf3  
 4440303 0. 0.0 400.0 0.0 0.  
 4440310 0.0 0.0 0.0  
 4446100 499  
 4446101 -1. 104.1964  
 4446102 0. 104.1964  
 4446103 0.5 103.46  
 4446104 1. 98.44  
 4446105 1.5 96.03  
 4446106 2. 93.72  
 4446107 2.5 91.42  
 4446108 3.0 89.33  
 4446109 3.5 87.23  
 4446110 4.0 85.14  
 4446111 5.0 81.68  
 4446112 7.0 74.98  
 4446113 10. 67.02  
 4446114 15.0 56.76  
 4446115 20.0 45.87  
 4446116 25.0 43.77  
 4446117 30.0 39.06  
 4446118 50.0 26.91  
 4446119 90.0 15.71  
 4446120 135.0 9.42  
 4446121 180.0 5.76  
 4446122 210. 3.98  
 4446123 232. 0.

4446124 10000. 0.  
 4446125 10.+6 0.  
 \*----1----2----3----4----5----6----7  
 \* Single phase head curve  
 4441100 1 1  
 \* indep dependent  
 4441101 0.0 1.56 0.179 1.47 0.304 1.42  
 4441102 0.431 1.39 0.582 1.35 0.86 1.18  
 4441103 0.966 1.08 1.0 1.0  
 4441200 1 2  
 4441201 0.0 -1.4 0.161 -1.1 0.247 -0.93  
 4441202 0.315 -.78 0.424 -.54 0.5 -.35  
 4441203 0.556 -.21 0.61 -.08 0.673 0.1  
 4441204 0.736 0.26 0.815 0.45 0.904 0.73  
 4441205 1.0 1.00  
 \*----1----2----3----4----5----6----7  
 4441300 1 3  
 4441301 -1.0 4.00 -.823 2.3 -.770 2.13  
 4441302 -.720 2.13 -.5710 2.07 -.4500 1.92  
 4441303 -.12 1.70 0.0 1.56  
 \*----1----2----3----4----5----6----7  
 4441400 1 4  
 4441401 -1.0 4.00 -.767 2.94 -.5000 2.5  
 4441402 0.0 1.76  
 \*----1----2----3----4----5----6----7  
 4441500 1 5  
 4441501 0.0 0.0 0.077 0.08 0.110 0.11  
 4441502 0.15 0.15 0.208 0.21 0.25 0.25  
 4441503 0.286 0.29 0.333 0.330 0.381 0.38  
 4441504 0.73 0.73 0.80 0.8 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 4441600 1 6  
 4441601 0.0 1.76 0.041 1.70 0.2111 1.53  
 4441602 0.324 1.41 0.3804 1.34 0.473 1.25  
 4441603 0.611 1.11 0.8652 1.01 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 4441700 1 7  
 4441701 -1.0 -2.78 -.913 -2.54 -.839 -2.33  
 4441702 -.659 -1.830 -.570 -1.58 -.5260 -1.46  
 4441703 -.475 -1.32 -.410 -1.14 -.327 -0.91  
 4441704 -.210 -.58 -.119 -.33 -.0600 -.17  
 4441705 0.0 0.0  
 \*----1----2----3----4----5----6----7

4441800 1 8  
 4441801 -1.0 -2.78 -.881 -2.62 -.730 -2.41  
 4441802 -.453 -2.03 -.368 -1.91 0.0 -1.4  
 \*----1----2----3----4----5----6----7  
 \* Single phase torque curve  
 4441900 2 1  
 4441901 0.0 0.8 0.084 0.80 0.294 0.82  
 4441902 0.406 0.83 0.575 0.880 0.920 0.98  
 4441903 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 4442000 2 2  
 4442002 0.0 -.81 0.111 -.590 0.185 -.440  
 4442003 0.240 -.33 0.308 -.20 0.340 -.140  
 4442004 0.378 -.06 0.418 0.03 0.483 0.17  
 4442005 0.530 0.230 0.574 0.30 0.633 0.39  
 4442006 0.694 0.500 0.790 0.63 0.97 0.95  
 4442007 1.0 1.0  
 \*----1----2----3----4----5----6----7  
 4442100 2 3  
 4442101 -1.0 2.46 -.969 2.340 -.930 2.19  
 4442102 -.796 1.68 -.615 1.37 -.476 1.09  
 4442103 -.359 0.98 -.307 0.930 -.088 0.81  
 4442104 0.0 0.8  
 \*----1----2----3----4----5----6----7  
 4442200 2 4  
 4442201 -1.0 2.460 -.950 2.40 -.86 2.280  
 4442202 -.702 2.120 -.440 1.86 0.0 1.5  
 \*----1----2----3----4----5----6----7  
 4442300 2 5  
 4442301 0.0 -1.3 0.091 -1.10 0.194 -.880  
 4442302 0.313 -.70 0.4650 -.38 0.754 0.190  
 4442303 0.876 0.43 1.0 0.67  
 \*----1----2----3----4----5----6----7  
 4442400 2 6  
 4442401 0.0 1.5 0.067 1.45 0.113 1.410  
 4442402 0.239 1.33 0.565 1.06 0.681 0.96  
 4442403 0.956 0.710 1.0 0.670  
 \*----1----2----3----4----5----6----7  
 4442500 2 7  
 4442501 -1.0 -3.97 0.0 -1.3  
 \*----1----2----3----4----5----6----7  
 4442600 2 8  
 4442601 -1.0 -3.97 -.833 -3.440 -.60 -2.7

4442602 -.333 -1.860 -.186 -1.4 -.075 -1.05  
 4442603 0.0 -.810  
 \*----1----2----3----4----5----6----7  
 . \* end of input \*



## ***ALSO AVAILABLE***

### **NEA Publications of General Interest**

*2001 Annual Report* (2002)

*Free: paper or Web.*

*NEA News*

ISSN 1605-9581

Yearly subscription: € 40 US\$ 45 GBP 26 ¥ 4 800

### **Nuclear Science**

*Physics of Plutonium Recycling* (2002)

*Volume VI – Multiple Pu Recycling in Advanced PWRs*

ISBN 92-64-1995768

Price: € 45 US\$ 45 GBP 28 ¥ 5 250

*Advanced Reactors with Innovative Fuels* (2002)

ISBN 92-64-19847-4

Price: € 130 US\$ 113 GBP 79 ¥ 15 000

*Basic Studies in the Field of High-temperature Engineering* (2002)

ISBN 92-64-19796-6

Price: € 75 US\$ 66 GBP 46 ¥ 8 600

*Fission Gas Behaviour in Water Reactor Fuels* (2002)

ISBN 92-64-19715-X

Price: € 120 US\$ 107 GBP 74 ¥ 12 100

*Shielding Aspects of Accelerators, Targets and Irradiation Facilities – SATIF 5* (2001)

ISBN 92-64-18691-3

Price: € 84 US\$ 75 GBP 52 ¥ 8 450

*Nuclear Production of Hydrogen* (2001)

ISBN 92-64-18696-4

Price: € 55 US\$ 49 GBP 34 ¥ 5 550

*Utilisation and Reliability of High Power Proton Accelerators* (2001)

(ISBN 92-64-18749-9

Price: € 130 US\$ 116 GBP 80 ¥ 13 100

*Pyrochemical Separations* (2001)

ISBN 92-64-18443-0

Price: € 77 US\$ 66 GBP 46 ¥ 7 230

*Evaluation of Speciation Technology* (2001)

ISBN 92-64-18667-0

Price: € 80 US\$ 70 GBP 49 ¥ 7 600

*Comparison Calculations for an Accelerator-driven Minor Actinide Burner* (2002)

ISBN 92-64-18478-3

*Free: paper or web.*

*Speciation, Techniques and Facilities for Radioactive Materials at Synchrotron Light Sources* (2002)

Workshop Proceedings, Grenoble, France, 10-12 September 2000

ISBN 92-64-18485-5

*Free: paper or web.*

*Forsmark 1 & 2 Boiling Water Reactor Stability Benchmark* (2001)

ISBN 92-64-18669-4

*Free: paper or web.*

*Pressurised Water Reactor Main Steam Line Break (MSLB) Benchmark (Volume III)* (2002)

ISBN 92-64-18495-3

*Free: paper or web.*

***Order form on reverse side.***

## **ORDER FORM**

**OECD Nuclear Energy Agency, 12 boulevard des Iles, F-92130 Issy-les-Moulineaux, France**  
Tel. 33 (0)1 45 24 10 15, Fax 33 (0)1 45 24 11 10, E-mail: [neapub@nea.fr](mailto:neapub@nea.fr), Internet: [www.nea.fr](http://www.nea.fr)

\* Prices include postage fees.

Payment enclosed (cheque payable to OECD Publications).

Charge my credit card  VISA  Mastercard  American Express

Card No.	Expiration date	Signature
Name		
Address	Country	
Telephone	Fax	
E-mail		

OECD PUBLICATIONS, 2 rue André-Pascal, 75775 PARIS CEDEX 16  
Printed in France.